



SLOVENSKI STANDARD SIST EN ISO 14644-3:2020

01-januar-2020

Nadomešča:

SIST EN ISO 14644-3:2006

Čiste sobe in podobna nadzorovana okolja - 3. del: Preskusne metode (ISO 14644-3:2019, popravljena verzija 2020-06)

Cleanrooms and associated controlled environments - Part 3: Test methods (ISO 14644-3:2019, Corrected version 2020-06)

Reinräume und zugehörige Reinraumbereiche - Teil 3: Prüfverfahren (ISO 14644-3:2019, korrigierte Fassung 2020-06)

Salles propres et environnements maîtrisés apparentés - Partie 3: Méthodes d'essai (ISO 14644-3:2019, Version corrigée 2020-06)

<https://standards.iteh.ai/catalog/standards/sist/8c564dcc-a3b7-455c-9a22-6ebcfid7664c3/sist-en-iso-14644-3-2020>

Ta slovenski standard je istoveten z: EN ISO 14644-3:2019

ICS:

13.040.35	Brezprašni prostori in povezana nadzorovana okolja	Cleanrooms and associated controlled environments
-----------	--	---

SIST EN ISO 14644-3:2020

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 14644-3:2020](#)

<https://standards.iteh.ai/catalog/standards/sist/8c564dcc-a3b7-455c-9a22-6ebcf7664c3/sist-en-iso-14644-3-2020>

EUROPEAN STANDARD

EN ISO 14644-3

NORME EUROPÉENNE

EUROPÄISCHE NORM

October 2019

ICS 13.040.35

Supersedes EN ISO 14644-3:2005

English Version

Cleanrooms and associated controlled environments - Part 3: Test methods (ISO 14644-3:2019, Corrected version 2020-06)

Salles propres et environnements maîtrisés apparentés
- Partie 3: Méthodes d'essai (ISO 14644-3:2019,
Version corrigée 2020-06)

Reinräume und zugehörige Reinraumbereiche - Teil 3:
Prüfverfahren (ISO 14644-3:2019, korrigierte Fassung
2020-06)

This European Standard was approved by CEN on 24 July 2019.

This European Standard was corrected and reissued by the CEN-CENELEC Management Centre on 17 June 2020.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

(standards.iteh.ai)

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

<https://standards.iteh.ai/catalog/standards/sist/8c564dcc-a3b7-455c-9a22->

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	3

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 14644-3:2020](https://standards.iteh.ai/catalog/standards/sist/8c564dcc-a3b7-455c-9a22-6ebcf7664c3/sist-en-iso-14644-3-2020)
<https://standards.iteh.ai/catalog/standards/sist/8c564dcc-a3b7-455c-9a22-6ebcf7664c3/sist-en-iso-14644-3-2020>

European foreword

This document (EN ISO 14644-3:2019) has been prepared by Technical Committee ISO/TC 209 "Cleanrooms and associated controlled environments" in collaboration with Technical Committee CEN/TC 243 "Cleanroom technology" the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2020, and conflicting national standards shall be withdrawn at the latest by April 2020.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 14644-3:2005.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

iTeh STANDARD PREVIEW
Endorsement notice
(standards.iteh.ai)

The text of ISO 14644-3:2019, Corrected version 2020-06 has been approved by CEN as EN ISO 14644-3:2019 without any modification.

[SIST EN ISO 14644-3:2020
https://standards.iteh.ai/catalog/standards/sist/8c564dcc-a3b7-455c-9a22-6ebcf7664c3/sist-en-iso-14644-3-2020](https://standards.iteh.ai/catalog/standards/sist/8c564dcc-a3b7-455c-9a22-6ebcf7664c3/sist-en-iso-14644-3-2020)

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 14644-3:2020](#)

<https://standards.iteh.ai/catalog/standards/sist/8c564dcc-a3b7-455c-9a22-6ebcf7664c3/sist-en-iso-14644-3-2020>

INTERNATIONAL
STANDARD

ISO
14644-3

Second edition
2019-08

Corrected version
2020-06

Cleanrooms and associated controlled environments —

**Part 3:
Test methods**

Salles propres et environnements maîtrisés apparentés —

Partie 3: Méthodes d'essai
iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 14644-3:2020](https://standards.iteh.ai/catalog/standards/sist/8c564dcc-a3b7-455c-9a22-6ebcfd7664c3/sist-en-iso-14644-3-2020)

<https://standards.iteh.ai/catalog/standards/sist/8c564dcc-a3b7-455c-9a22-6ebcfd7664c3/sist-en-iso-14644-3-2020>



Reference number
ISO 14644-3:2019(E)

© ISO 2019

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN ISO 14644-3:2020](https://standards.iteh.ai/catalog/standards/sist/8c564dcc-a3b7-455c-9a22-6ebcf7664c3/sist-en-iso-14644-3-2020)

<https://standards.iteh.ai/catalog/standards/sist/8c564dcc-a3b7-455c-9a22-6ebcf7664c3/sist-en-iso-14644-3-2020>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2019

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
3.1 General terms.....	1
3.2 Terms related to airborne particles.....	3
3.3 Terms related to air filters and systems.....	3
3.4 Terms related to airflow and other physical states.....	4
3.5 Terms related to electrostatic measurement.....	5
3.6 Terms related to measuring apparatus and measuring conditions.....	5
3.7 Terms related to occupancy states.....	6
4 Test procedures	6
4.1 Cleanroom tests.....	6
4.1.1 General.....	6
4.1.2 Supporting tests.....	7
4.2 Principle.....	7
4.2.1 Air pressure difference test.....	7
4.2.2 Airflow test.....	7
4.2.3 Airflow direction test and visualization.....	8
4.2.4 Recovery test.....	8
4.2.5 Temperature test.....	8
4.2.6 Humidity test.....	8
4.2.7 Installed filter system leakage tests.....	8
4.2.8 Containment leak test.....	8
4.2.9 Electrostatic and ion generator tests.....	8
4.2.10 Particle deposition test.....	8
4.2.11 Segregation test.....	9
5 Test reports	9
Annex A (informative) Choice of supporting tests and checklist	10
Annex B (informative) Supporting test methods	14
Annex C (informative) Test apparatus	43
Bibliography	51

ISO 14644-3:2019(E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by ISO/TC 209, *Cleanrooms and associated controlled environments*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

This second edition of ISO 14644-3 cancels and replaces the first edition (ISO 14644-3:2005), which has been technically revised. The main changes compared to the previous edition are as follows:

- [Clause B.7](#) has been simplified and corrected to address concerns over its complexity and noted errors;
- guidance concerning classification of air cleanliness by airborne particle concentration has been moved to 14644-1^[1]
- the text of the whole document has been revised or clarified to aid in application.

A list of all parts in the ISO 14644 series can be found on the ISO website.

This corrected version of ISO 14644-3:2019 incorporates the following corrections:

- cross-references have been corrected in Table A.1, [B.4.4](#), [C.1](#), [C.4.2](#) and [C.4.3](#);
- the wording has been changed in [B.2.1](#) a), Table B.2;
- old Figure B.2 has been removed.

Introduction

Cleanrooms and associated controlled environments provide control of contamination to levels appropriate for accomplishing contamination-sensitive activities. Products and processes that benefit from the control of airborne contamination include those in such industries as aerospace, microelectronics, pharmaceuticals, medical devices, healthcare and food.

This document sets out appropriate test methods for measuring the performance of a cleanroom, a clean zone or an associated controlled environment, including separative devices and controlled zones, together with all associated structures, air treatment systems, services and utilities.

NOTE Not all cleanroom parameter test procedures are shown in this document. The procedure and apparatus for the test carried out for the air cleanliness classes by particle concentration and for macroparticles are provided in ISO 14644-1,^[1] and specifications for monitoring air cleanliness by nanoscale particle concentrations are provided in ISO 14644-12.^[8] The procedures and apparatus to characterize other parameters, of concern in cleanrooms and clean zones used for specific products or processes, are discussed elsewhere in other documents prepared by ISO/TC 209 [for example, procedures for control and measurement of viable materials (ISO 14698 series), testing cleanroom functionality (ISO 14644-4^[3]), and testing of separative devices (ISO 14644-7^[4])]. In addition, other standards can be considered to be applicable. Other cleanliness attribute levels can be determined using ISO 14644-8^[5] (levels of air cleanliness by chemicals), ISO 14644-9^[6] (levels of surface cleanliness by particle concentration) and ISO 14644-10^[7] (levels of surface cleanliness by chemical concentration).

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN ISO 14644-3:2020](https://standards.iteh.ai/catalog/standards/sist/8c564dcc-a3b7-455c-9a22-6ebcf7664c3/sist-en-iso-14644-3-2020)

<https://standards.iteh.ai/catalog/standards/sist/8c564dcc-a3b7-455c-9a22-6ebcf7664c3/sist-en-iso-14644-3-2020>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 14644-3:2020](#)

<https://standards.iteh.ai/catalog/standards/sist/8c564dcc-a3b7-455c-9a22-6ebcf7664c3/sist-en-iso-14644-3-2020>

Cleanrooms and associated controlled environments —

Part 3: Test methods

1 Scope

This document provides test methods in support of the operation for cleanrooms and clean zones to meet air cleanliness classification, other cleanliness attributes and related controlled conditions.

Performance tests are specified for two types of cleanrooms and clean zones: those with unidirectional airflow and those with non-unidirectional airflow, in three possible occupancy states: as-built, at-rest and operational.

The test methods, recommended test apparatus and test procedures for determining performance parameters are provided. Where the test method is affected by the type of cleanroom or clean zone, alternative procedures are suggested.

For some of the tests, several different methods and apparatus are recommended to accommodate different end-use considerations. Alternative methods not included in this document can be used by agreement between customer and supplier. Alternative methods do not necessarily provide equivalent measurements.

This document is not applicable to the measurement of products or of processes in cleanrooms, clean zones or separative devices.

NOTE This document does not purport to address safety considerations associated with its use (for example, when using hazardous materials, operations and equipment). It is the responsibility of the user of this document to establish appropriate safety and health practices and to determine the applicability of regulatory limitations prior to use.

2 Normative references

There are no normative references in this document.

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1 General terms

3.1.1

cleanroom

room within which the number concentration of *airborne particles* (3.2.1) is controlled and classified, and which is designed, constructed and operated in a manner to control the introduction, generation and retention of particles inside the room

Note 1 to entry: The class of airborne *particle concentration* (3.2.4) is specified.

ISO 14644-3:2019(E)

Note 2 to entry: Levels of other cleanliness attributes such as chemical, viable or nanoscale concentrations in the air, and also surface cleanliness in terms of particle, nanoscale, chemical and viable concentrations might also be specified and controlled.

Note 3 to entry: Other relevant physical parameters might also be controlled as required, e.g. temperature, humidity, pressure, vibration and electrostatic.

[SOURCE: ISO 14644-1:2015, 3.1.1]

3.1.2 clean zone

defined space within which the number concentration of *airborne particles* (3.2.1) is controlled and classified, and which is constructed and operated in a manner to control the introduction, generation and retention of contaminants inside the space

Note 1 to entry: The class of airborne *particle concentration* (3.2.4) is specified.

Note 2 to entry: Levels of other cleanliness attributes such as chemical, viable or nanoscale concentrations in the air, and also surface cleanliness in terms of particle, nanoscale, chemical and viable concentrations might also be specified and controlled.

Note 3 to entry: A clean zone(s) can be a defined space within a *cleanroom* (3.1.1) or might be achieved by a separative device. Such a device can be located inside or outside a cleanroom.

Note 4 to entry: Other relevant physical parameters might also be controlled as required, e.g. temperature, humidity, pressure, vibration and electrostatic.

[SOURCE: ISO 14644-1:2015, 3.1.2]

3.1.3 installation

cleanroom (3.1.1) or one or more *clean zones* (3.1.2), together with all associated structures, air-treatment systems, services and utilities

[SOURCE: ISO 14644-1:2015, 3.1.3]

3.1.4 separative device

equipment utilizing constructional and dynamic means to create assured levels of separation between the inside and outside of a defined volume

Note 1 to entry: Some industry-specific examples of separative devices are clean air hoods, containment enclosures, glove boxes, isolators and mini-environments.

[SOURCE: ISO 14644-7:2004, 3.17]

3.1.5 resolution

smallest change in a quantity being measured that causes a perceptible change in the corresponding indication

Note 1 to entry: Resolution can depend on, for example, noise (internal or external) or friction. It may also depend on the value of a quantity being measured.

[SOURCE: ISO 14644-1:2015, 3.4.1]

3.1.6 sensitivity

quotient of the change in an indication of a measuring system and the corresponding change in a value of the quantity being measured

3.2 Terms related to airborne particles

3.2.1

airborne particle

solid or liquid object suspended in air, viable or non-viable, sized between 1 nm and 100 µm

Note 1 to entry: For classification purposes, refer to ISO 14644-1:2015, 3.2.1.

3.2.2

count median particle diameter

median particle diameter based on the number of particles

Note 1 to entry: For the count median, one half of the particle number is contributed by the particles with a size smaller than the count median size, and one half by particles larger than the count median size.

3.2.3

mass median particle diameter

median particle diameter based on the particle mass

Note 1 to entry: For the mass median, one half of mass of all particles is contributed by particles with a size smaller than the mass median size, and one half by particles larger than the mass median size.

3.2.4

particle concentration

number of individual particles per unit volume of air

[SOURCE: ISO 14644-1:2015, 3.2.3]

3.2.5

particle size

diameter of a sphere that produces a response, by a given particle-sizing instrument, that is equivalent to the response produced by the particle being measured

Note 1 to entry: For light-scattering airborne-particle instruments, the equivalent optical diameter is used.

[SOURCE: ISO 14644-1:2015, 3.2.2]

3.2.6

particle size distribution

cumulative distribution of *particle concentration* (3.2.4) as a function of *particle size* (3.2.5)

[SOURCE: ISO 14644-1:2015, 3.2.4]

3.2.7

test aerosol

gaseous suspension of solid and/or liquid particles with known and controlled size distribution and concentration

3.3 Terms related to air filters and systems

3.3.1

aerosol challenge

challenging of a filter or an *installed filter system* (3.3.6) by *test aerosol* (3.2.7)

3.3.2

designated leak

maximum allowable penetration, which is determined by agreement between customer and supplier, through a *leak* (3.3.8), detectable during *scanning* (3.3.9) of a filter *installation* (3.1.3) with light-scattering airborne-particle counters (LSAPC) or *aerosol photometers* (3.6.2)