

SLOVENSKI STANDARD
SIST EN ISO 16924:2018
01-junij-2018

Polnilne postaje za oskrbo z zemeljskim plinom - Postaje za oskrbo vozil z utekočinjenim zemeljskim plinom (ISO 16924:2016)

Natural gas fuelling stations - LNG stations for fuelling vehicles (ISO 16924:2016)

Erdgastankstellen - Tankstellen für verflüssigtes Erdgas (LNG) zur Betankung von Fahrzeugen (ISO 16924:2016)

Stations-service de gaz naturel - Stations GNL pour le ravitaillement de véhicules (ISO 16924:2016)

iTeh STANDARD PREVIEW

(standards.iteh.ai)

[SIST EN ISO 16924:2018](https://standards.iteh.ai/catalog/standards/sist/0e33fb80-b718-42a7-b7d7-a457d4dda651/sist-en-iso-16924-2018)

Ta slovenski standard je istoveten z: EN ISO 16924:2018

<https://standards.iteh.ai/catalog/standards/sist/0e33fb80-b718-42a7-b7d7-a457d4dda651/sist-en-iso-16924-2018>

ICS:

75.200

Oprema za skladiščenje nafte, naftnih proizvodov in zemeljskega plina

Petroleum products and natural gas handling equipment

SIST EN ISO 16924:2018

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN ISO 16924:2018

<https://standards.iteh.ai/catalog/standards/sist/0e33fb80-b718-42a7-b7d7-a457d4dda651/sist-en-iso-16924-2018>

EUROPEAN STANDARD

EN ISO 16924

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2018

ICS 75.200

English Version

Natural gas fuelling stations - LNG stations for fuelling vehicles (ISO 16924:2016)

Stations-service de gaz naturel - Stations GNL pour le ravitaillement de véhicules (ISO 16924:2016)

Erdgastankstellen - Tankstellen für verflüssigtes Erdgas (LNG) zur Betankung von Fahrzeugen (ISO 16924:2016)

This European Standard was approved by CEN on 26 January 2018.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

| Contents | Page |
|-------------------------------|-------------|
| European foreword..... | 3 |

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 16924:2018](https://standards.iteh.ai/catalog/standards/sist/0e33fb80-b718-42a7-b7d7-a457d4dda651/sist-en-iso-16924-2018)
<https://standards.iteh.ai/catalog/standards/sist/0e33fb80-b718-42a7-b7d7-a457d4dda651/sist-en-iso-16924-2018>

European foreword

The text of ISO 16924:2016 has been prepared by ISO/TMBG “Technical Management Board - groups” of the International Organization for Standardization (ISO) and has been taken over as EN ISO 16924:2018 by Technical Committee CEN/TC 326 “Natural Gas Vehicles - Fuelling and Operation” the secretariat of which is held by NEN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2018, and conflicting national standards shall be withdrawn at the latest by October 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

This document has been prepared under the standardization request M/533 given to CEN by the European Commission and the European Free Trade Association in the framework of Directive 2014/94/EU on the deployment of alternative fuels infrastructure.

The standardization request M/533 focuses on interoperability aspects of the alternative fuels infrastructure, which for LNG fuelling stations are covered in this document by the following items:

- Fuelling pressure (service pressure): This document requires that the pressure of LNG at the nozzle is lower than the maximum allowable working pressure of the vehicle tank.
- Connector profile: The harmonized connector profile is described in EN ISO 12617:2017, that specifies LNG refuelling nozzles and receptacles constructed entirely of new and unused parts and materials for road vehicles powered by LNG, and which is referenced in this document.

In addition to interoperability aspects, the following aspects are relevant for applying this document in Europe:

- Fuel quality: The quality of LNG for use as automotive fuel is covered in EN 16723-2:2017, that specifies the requirements and test methods for natural gas, biomethane and blends of both.
- Fuel labelling: The fuel label for LNG at dispensers is covered by EN 16942:2016, that lays down harmonized identifiers for marketed liquid and gaseous fuels, and which has also been developed to support Directive 2014/94/EU.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

EN ISO 16924:2018 (E)

Endorsement notice

The text of ISO 16924:2016 has been approved by CEN as EN ISO 16924:2018 without any modification.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 16924:2018](https://standards.iteh.ai/catalog/standards/sist/0e33fb80-b718-42a7-b7d7-a457d4dda651/sist-en-iso-16924-2018)

<https://standards.iteh.ai/catalog/standards/sist/0e33fb80-b718-42a7-b7d7-a457d4dda651/sist-en-iso-16924-2018>

INTERNATIONAL
STANDARD

ISO
16924

First edition
2016-12-01

**Natural gas fuelling stations — LNG
stations for fuelling vehicles**

*Stations-service de gaz naturel — Stations GNL pour le ravitaillement
de véhicules*

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 16924:2018](https://standards.iteh.ai/catalog/standards/sist/0e33fb80-b718-42a7-b7d7-a457d4dda651/sist-en-iso-16924-2018)

[https://standards.iteh.ai/catalog/standards/sist/0e33fb80-b718-42a7-b7d7-
a457d4dda651/sist-en-iso-16924-2018](https://standards.iteh.ai/catalog/standards/sist/0e33fb80-b718-42a7-b7d7-a457d4dda651/sist-en-iso-16924-2018)



Reference number
ISO 16924:2016(E)

© ISO 2016

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN ISO 16924:2018

<https://standards.iteh.ai/catalog/standards/sist/0e33fb80-b718-42a7-b7d7-a457d4dda651/sist-en-iso-16924-2018>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

Page

| | |
|---|------------|
| Foreword | vii |
| 1 Scope | 1 |
| 2 Normative references | 1 |
| 3 Terms and definitions | 2 |
| 4 Abbreviated terms | 9 |
| 5 Risk management | 10 |
| 5.1 Risk assessment..... | 10 |
| 5.1.1 General..... | 10 |
| 5.1.2 Protection against overpressure..... | 10 |
| 5.1.3 Static electricity..... | 11 |
| 5.2 Fire protection..... | 11 |
| 5.2.1 Hazardous area classification..... | 11 |
| 5.2.2 Sources of ignition..... | 11 |
| 5.2.3 Fire fighting..... | 12 |
| 5.3 Explosion protection measures..... | 12 |
| 6 General design requirements | 12 |
| 6.1 General..... | 12 |
| 6.1.1 Design philosophy..... | 12 |
| 6.1.2 Buildings and civil works..... | 13 |
| 6.1.3 Installation and construction..... | 14 |
| 6.2 Site layout..... | 15 |
| 6.2.1 Separation distances..... | 15 |
| 6.2.2 Traffic management..... | 15 |
| 6.2.3 Security..... | 15 |
| 6.2.4 Requirements for location of equipment..... | 15 |
| 6.3 Environmental considerations..... | 16 |
| 6.3.1 Noise attenuation..... | 16 |
| 6.3.2 Prevention of venting of natural gas..... | 16 |
| 7 Fuel supply to the fuelling station | 16 |
| 7.1 Application..... | 16 |
| 7.2 Equipment compatibility..... | 16 |
| 7.3 Filling connector..... | 17 |
| 7.4 Requirements for filling..... | 17 |
| 7.4.1 General requirements..... | 17 |
| 7.4.2 Prevention of overpressurization and overfilling..... | 17 |
| 7.5 Prevention of back flow..... | 17 |
| 7.6 Bleed connections..... | 17 |
| 7.7 Draining of liquid from the LNG storage tank..... | 18 |
| 7.8 LNG tanker..... | 18 |
| 7.8.1 Immobility..... | 18 |
| 7.8.2 Anti-drive-away equipment..... | 18 |
| 7.8.3 Turning off the engine..... | 18 |
| 7.8.4 Equalizing the potentials..... | 18 |
| 8 Storage | 18 |
| 8.1 LNG storage..... | 18 |
| 8.1.1 Design and construction..... | 18 |
| 8.1.2 Safety requirements..... | 20 |
| 8.1.3 Installation guidance..... | 24 |
| 8.2 CNG buffer storage..... | 25 |
| 9 Pumps and compressors | 25 |
| 9.1 Connection of LNG pumps to the LNG storage tank..... | 25 |

ISO 16924:2016(E)

| | | |
|-----------|---|-----------|
| 9.1.1 | General | 25 |
| 9.1.2 | NPSH requirements | 25 |
| 9.1.3 | Vapour return | 25 |
| 9.1.4 | Protection against weather | 25 |
| 9.1.5 | Accessibility | 26 |
| 9.2 | LNG centrifugal pump (including ancillaries) | 26 |
| 9.2.1 | General provisions | 26 |
| 9.2.2 | Liquid inlet to the centrifugal pump | 26 |
| 9.2.3 | Centrifugal pump design | 26 |
| 9.2.4 | Vibration | 26 |
| 9.2.5 | Detection of shaft seal leak | 27 |
| 9.2.6 | Detection of cavitation | 27 |
| 9.3 | LNG reciprocating pump for LCNG fuelling stations (including ancillaries) | 27 |
| 9.3.1 | General provisions | 27 |
| 9.3.2 | Liquid supplied to the reciprocating pump | 27 |
| 9.3.3 | Design | 27 |
| 9.3.4 | Vibration | 27 |
| 9.3.5 | Pulsation | 27 |
| 9.4 | Commonalities for LNG centrifugal and reciprocating pumps | 27 |
| 9.4.1 | Suction line | 27 |
| 9.4.2 | Instrumentation | 28 |
| 9.4.3 | Markings of a pump | 28 |
| 9.4.4 | Instructions | 28 |
| 9.5 | Natural gas compressor | 29 |
| 10 | Dispensers | 29 |
| 10.1 | LNG dispensers | 29 |
| 10.1.1 | General requirements | 29 |
| 10.1.2 | Breakaway system | 31 |
| 10.1.3 | Fuelling hoses | 31 |
| 10.1.4 | Fuelling nozzles | 32 |
| 10.1.5 | Dispenser enclosure | 32 |
| 10.1.6 | Other requirements | 33 |
| 10.2 | CNG dispensers | 33 |
| 11 | Vaporizers and heaters | 34 |
| 11.1 | Application | 34 |
| 11.2 | Design of vaporizers and heaters | 34 |
| 11.3 | Ambient air vaporizer | 35 |
| 11.3.1 | General | 35 |
| 11.3.2 | Defrosting | 35 |
| 11.3.3 | Aluminium vaporizers | 35 |
| 11.4 | Electric vaporizer/heater | 35 |
| 11.5 | Water bath vaporizer | 36 |
| 11.6 | Fired vaporizers | 36 |
| 11.7 | Remotely heated vaporizers | 36 |
| 12 | Odorization | 36 |
| 12.1 | General requirements | 36 |
| 12.2 | High-pressure odorizer | 37 |
| 12.3 | Safety | 37 |
| 12.4 | Monitoring | 37 |
| 12.5 | Odorant | 38 |
| 12.6 | Dynamics of function | 38 |
| 13 | Pipework | 38 |
| 13.1 | General | 38 |
| 13.2 | Pipework design | 38 |
| 13.2.1 | General | 38 |
| 13.2.2 | Overground pipework | 39 |

| | | | |
|-----------|--------|---|-----------|
| | 13.2.3 | Underground pipework..... | 39 |
| | 13.2.4 | Pipework in ducts..... | 39 |
| | 13.2.5 | Flexible connections..... | 40 |
| 14 | | Electrical equipment and wiring..... | 40 |
| | 14.1 | General..... | 40 |
| | 14.2 | Main considerations..... | 40 |
| | 14.2.1 | Grounding..... | 40 |
| | 14.2.2 | Lightning..... | 40 |
| | 14.2.3 | Contact with live parts..... | 40 |
| | 14.2.4 | Cables..... | 40 |
| | 14.2.5 | Static electricity..... | 41 |
| | 14.3 | Other considerations..... | 41 |
| | 14.3.1 | Interface..... | 41 |
| | 14.3.2 | Primary seal..... | 41 |
| | 14.3.3 | Additional seal..... | 41 |
| | 14.3.4 | Conduit seals..... | 41 |
| | 14.3.5 | Detection vents..... | 42 |
| 15 | | Instrumentation and control system..... | 42 |
| | 15.1 | General..... | 42 |
| | 15.2 | Gas detectors..... | 42 |
| | 15.3 | Flame detectors..... | 42 |
| | 15.4 | Pressure gauges..... | 42 |
| | 15.5 | Temperature sensors..... | 42 |
| | 15.6 | Manual emergency shutdown devices..... | 42 |
| | 15.7 | Emergency power supply unit..... | 43 |
| 16 | | Emergency shutdown..... | 43 |
| | 16.1 | Application..... | 43 |
| | 16.2 | Procedure..... | 43 |
| | 16.3 | Activation..... | 43 |
| | 16.4 | ESD action..... | 43 |
| | 16.5 | Reset..... | 44 |
| 17 | | Special configurations..... | 44 |
| | 17.1 | Movable LNG fuelling station..... | 44 |
| | 17.1.1 | General requirements..... | 44 |
| | 17.1.2 | Anchoring..... | 44 |
| | 17.1.3 | Containment..... | 44 |
| | 17.2 | Mobile LNG fuelling station..... | 44 |
| | 17.2.1 | General requirements..... | 44 |
| | 17.2.2 | Anchoring..... | 45 |
| | 17.2.3 | Containment..... | 45 |
| | 17.2.4 | Design..... | 45 |
| | 17.2.5 | Additional requirements for operation..... | 45 |
| 18 | | Testing and commissioning..... | 45 |
| | 18.1 | Testing..... | 45 |
| | 18.1.1 | Electrical testing..... | 45 |
| | 18.1.2 | Pressure strength testing..... | 46 |
| | 18.1.3 | Leak testing..... | 46 |
| | 18.2 | Commissioning..... | 46 |
| | 18.2.1 | General provisions..... | 46 |
| | 18.2.2 | Purging..... | 47 |
| | 18.2.3 | Functional testing..... | 47 |
| | 18.2.4 | First filling of the LNG storage tank and other components..... | 47 |
| 19 | | Operations..... | 47 |
| | 19.1 | LNG tanker offloading..... | 47 |
| | 19.2 | Fuelling procedure..... | 47 |

ISO 16924:2016(E)

| | | |
|---------------------|---|-----------|
| 19.3 | Safety signs..... | 48 |
| 19.3.1 | General on identification labels..... | 48 |
| 19.3.2 | Equipment marking..... | 48 |
| 19.4 | Equipment and pipework identification..... | 49 |
| 19.5 | Training..... | 49 |
| 19.6 | Installation and operating instructions..... | 50 |
| 19.7 | Emergency plan..... | 51 |
| 19.8 | Maintaining the emergency shutdown..... | 51 |
| 20 | Inspection and maintenance..... | 51 |
| 20.1 | Inspection..... | 51 |
| 20.1.1 | General requirements..... | 51 |
| 20.1.2 | Inspection and testing of electrical systems..... | 52 |
| 20.1.3 | Inspection and re-testing of the safety relief valves..... | 52 |
| 20.1.4 | Safety and fire protection equipment..... | 53 |
| 20.2 | Maintenance..... | 53 |
| 20.2.1 | Preventive maintenance planning..... | 53 |
| 20.2.2 | Maintenance procedures..... | 53 |
| 20.2.3 | Maintenance safety..... | 53 |
| 20.2.4 | Draining of the LNG storage tank..... | 54 |
| Annex A | (informative) Examples of hazardous zones classification..... | 55 |
| Annex B | (normative) Separation distances..... | 59 |
| Annex C | (informative) Example flow diagram of an LNG fuelling station..... | 63 |
| Annex D | (informative) Example flow diagram of an LCNG fuelling station..... | 64 |
| Annex E | (informative) Example flow diagram of an LNG and LCNG fuelling station..... | 65 |
| Annex F | (informative) Process requirements for the effective cryogenic pump operation..... | 66 |
| Annex G | (informative) Recommendations for installation of a centrifugal pump..... | 68 |
| Annex H | (informative) Recommendations for centrifugal pump design..... | 69 |
| Annex I | (informative) Recommendations for installation of a reciprocating pump..... | 70 |
| Annex J | (informative) Recommendations on the content of the cryogenic pump operation instructions..... | 72 |
| Annex K | (informative) Example flow diagram of a high-pressure odorizer..... | 74 |
| Annex L | (informative) LNG identification mark of an LNG fuelling station..... | 75 |
| Bibliography | | 76 |

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

The committee responsible for this document is ISO/PC 252, *Natural gas fuelling stations for vehicles*.

SIST EN ISO 16924:2018

<https://standards.iteh.ai/catalog/standards/sist/0e33fb80-b718-42a7-b7d7-a457d4dda651/sist-en-iso-16924-2018>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN ISO 16924:2018

<https://standards.iteh.ai/catalog/standards/sist/0e33fb80-b718-42a7-b7d7-a457d4dda651/sist-en-iso-16924-2018>

Natural gas fuelling stations — LNG stations for fuelling vehicles

1 Scope

This document specifies the design, construction, operation, maintenance and inspection of stations for fuelling liquefied natural gas (LNG) to vehicles, including equipment, safety and control devices.

This document also specifies the design, construction, operation, maintenance and inspection of fuelling stations for using LNG as an onsite source for fuelling CNG to vehicles (LCNG fuelling stations), including safety and control devices of the station and specific LCNG fuelling station equipment.

NOTE Specific CNG equipment is dealt with in ISO 16923.

This document is applicable to fuelling stations receiving LNG and other liquefied methane-rich gases that comply with local applicable gas composition regulation or with the gas quality requirements of ISO 13686.

This document includes all equipment from the LNG storage tank filling connection up to the fuelling nozzle on the vehicle. The LNG storage tank filling connection itself and the vehicle fuelling nozzle are not covered in this document.

This document includes fuelling stations having the following characteristics:

- private access;
- public access (self-service or assisted);
- metered dispensing and non metered dispensing;
- fuelling stations with fixed LNG storage;
- fuelling stations with mobile LNG storage;
- movable fuelling stations;
- mobile fuelling stations;
- multi-fuel stations.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 4126 (all parts), *Safety devices for protection against excessive pressure*

ISO 9606-1, *Qualification testing of welders — Fusion welding — Part 1: Steels*

ISO 12100, *Safety of machinery — General principles for design — Risk assessment and risk reduction*

ISO 12617, *Road vehicles — Liquefied natural gas (LNG) refuelling connector — 3,1 MPa connector*

ISO 13709, *Centrifugal pumps for petroleum, petrochemical and natural gas industries*