
Akustika - Ugotavljanje ravni zvočnih moči virov hrupa z meritvami v odmevnici za zračne izpuste ter dušilne in zaporne elemente za zrak (ISO/DIS 5135:2019)

Acoustics - Determination of sound power levels of noise from air-terminal devices, air-terminal units, dampers and valves by measurement in a reverberation test room (ISO/DIS 5135:2019)

Akustik - Bestimmung des Schalleistungspegels von Geräuschen von Luftdurchlässen, Volumendurchflussreglern, Drossel- und Absperelementen durch Messungen im Hallraum (ISO/DIS 5135:2019)

Acoustique - Détermination des niveaux de puissance acoustique du bruit émis par les bouches d'air, les unités terminales, les registres et clapets au moyen de mesurages en salle réverbérante (ISO/DIS 5135:2019)

Ta slovenski standard je istoveten z: prEN ISO 5135

ICS:

17.140.20	Emisija hrupa naprav in opreme	Noise emitted by machines and equipment
91.120.20	Akustika v stavbah. Zvočna izolacija	Acoustics in building. Sound insulation

oSIST prEN ISO 5135:2019**en**

ITeH STANDARD PREVIEW
(standards.iteh.ai)

Full standard:
<https://standards.iteh.ai/catalog/standard/s/sist/740b66a7-1115-416-9d4a-1389c48389ec/osist-pr-en-iso-5135-2019>

DRAFT INTERNATIONAL STANDARD

ISO/DIS 5135

ISO/TC 43/SC 1

Secretariat: DIN

Voting begins on:
2019-05-24Voting terminates on:
2019-08-16

Acoustics — Determination of sound power levels of noise from air-terminal devices, air-terminal units, dampers and valves by measurement in a reverberation test room

Acoustique — Détermination des niveaux de puissance acoustique du bruit émis par les bouches d'air, les unités terminales, les registres et clapets au moyen de mesurages en salle réverbérante

ICS: 17.140.20

ITEH STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standard/sists/740b66a7-1115-4f16-9d4a-1389c48389ec/iso-prn-iso-5135-2019>

THIS DOCUMENT IS A DRAFT CIRCULATED FOR COMMENT AND APPROVAL. IT IS THEREFORE SUBJECT TO CHANGE AND MAY NOT BE REFERRED TO AS AN INTERNATIONAL STANDARD UNTIL PUBLISHED AS SUCH.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

This document is circulated as received from the committee secretariat.

ISO/CEN PARALLEL PROCESSING



Reference number
ISO/DIS 5135:2019(E)

© ISO 2019

ITeH STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standard/s/sist/740b66a7-1115-416-9d4a-1389c48389ec/osist-pr-en-iso-5135-2019>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2019

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword.....	iv
Introduction.....	v
1 Scope.....	1
2 Normative references.....	1
3 Terms and Definitions.....	1
4 Acoustic test facilities and procedures.....	2
5 Installation and operation of equipment to be tested.....	3
5.1 General.....	3
5.2 Test installation of air-terminal units, dampers and valves for measurement of the sound radiated to the reverberation room.....	3
5.3 Test installation of air-terminal units, dampers and valves for the measurement of the sound radiated to the reverberation room by the connecting duct.....	3
5.4 Test installation of air-terminal units for the determination of casing radiated noise.....	4
5.5 Test procedures.....	4
6 Auxiliary facilities for acoustic testing.....	5
7 Measurements and calculations.....	5
8 Measurement uncertainty.....	6
9 Test report.....	7
Bibliography.....	15

TEH STANDARD PREVIEW
 (standards.iteh.ai)
 Full standard:
<https://standards.iteh.ai/can/buy/standard/sisw/740666a7-1115-416-9d4a-1389c48389ec/osist-pr-en-iso-5135-2019>

ISO/DIS 5135:2019(E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by ISO/TC 43, *Acoustics*, Subcommittee SC 1, *Noise*.

This third edition cancels and replaces the second edition (ISO 5135:1997), of which it constitutes a technical revision. The main changes are the following:

- Replacement of rescinded and unavailable reference standards ISO 5219:1984 and 5220:1981 with currently available and up to date standards ANSI/ASHRAE 70 and ANSI/ASHRAE 130;
- a reference to a companion document ISO 7235 was added to deal with transmission elements and physical elements used in the test setup;
- a clause on uncertainty was added.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This document defines requirements for acoustic testing of air-terminal units, dampers and valves used in air diffusion and air distribution systems in reverberation rooms. It is based on the use of ISO 3741, which describes the acoustic test facilities, instrumentation and procedures to be used for precision grade determination of sound power levels in octave or one-third-octave bands of a noise source.

ITeH STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standard/sisr/740b66a7-1115-416-9d4a-1389c48389ec/osist-pre-iso-5135-2019>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Full standard:
<https://standards.iteh.ai/catalog/standard/s/sist/740b66a7-1115-416-9d4a-1389c48389ec/osist-pr-en-iso-5135-2019>

Acoustics — Determination of sound power levels of noise from air-terminal devices, air-terminal units, dampers and valves by measurement in a reverberation test room

1 Scope

This document establishes general rules for the acoustic testing of air-terminal units, dampers and valves used in air diffusion and air distribution systems in order to determine sound power levels as defined in ISO 3741.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3741:2010, *Acoustics — Determination of sound power levels and sound energy levels of noise sources using sound pressure — Precision methods for reverberation test rooms*

ISO 5167 (all parts), *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full*

ISO 5801, *Fans — Performance testing using standardized airways*

ISO 7235, *Acoustics — Laboratory measurement procedures for ducted silencers and air-terminal units — Insertion loss, flow noise and total pressure loss*

ISO/IEC Guide 98-3, *Uncertainty of measurement — Part 3: Guide to the expression of uncertainty in measurement (GUM:1995)*

ANSI/ASHRAE 130, *Laboratory Methods of Testing Air Terminal Units*

ANSI/ASHRAE 70, *Method of Testing the Performance of Air Outlets and Air Inlets*

EN 1751, *Ventilation for buildings — Air terminal devices — Aerodynamic testing of damper and valves*

EN 12238, *Ventilation for buildings — Air terminal devices — Aerodynamic testing and rating for mixed flow application*

EN 12239, *Ventilation for buildings — Air terminal devices — Aerodynamic testing and rating for displacement flow applications*

3 Terms and Definitions

For the purposes of this document, the following definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

ISO/DIS 5135:2019(E)

3.1 sound pressure level

L_p
ten times the logarithm to the base 10 of the ratio of the square of the sound pressure, p , to the square of a reference value, p_0 , expressed in decibels

$$L_p = 10 \lg \frac{p^2}{p_0^2} \text{ dB}$$

where the reference value p_0 is 20 μPa

[SOURCE: ISO/TR 25417:2007,^[2] 2.2, modified — Notes 1 and 2 deleted.]

3.2 sound power level

L_W
ten times the logarithm to the base 10 of the ratio of the sound power, P , to a reference value, P_0 , expressed in decibels

$$L_W = 10 \lg \frac{P}{P_0} \text{ dB}$$

where the reference value, P_0 , is 1 pW

Note 1 to entry: If a specific frequency weighting as specified in IEC 61672-1^[3] and/or specific frequency bands are applied, this is indicated by appropriate subscripts; e.g. L_{WA} denotes the A-weighted sound power level.

Note 2 to entry: This definition is technically in accordance with ISO 80000-8:2007,^[1] 8-23.

[SOURCE: ISO/TR 25417:2007,^[2] 2.9]

3.3 frequency range of interest

the range which includes the octave bands with nominal mid-band frequencies between 125 Hz and 8 000 Hz (optional between 63 Hz and 8000 Hz) or the one-third-octave bands with mid-band frequencies between 100 Hz and 10 000 Hz (optional between 50 Hz and 10 000 Hz)

Note 1 to entry: The user is encouraged to qualify the room in the 63 Hz octave band and include this sound. Some equipment can generate significant sound in the 63 Hz octave band.

3.4 reverberant sound field

that portion of the sound field in the test room over which the influence of sound received directly from the source is negligible

[SOURCE: ISO 3741:2010, 3.7]

4 Acoustic test facilities and procedures

The acoustic test facilities, instrumentation and procedures to be used, including room qualification tests, are described in ISO 3741.

This document is applicable to equipment operating under steady state conditions and with a volume not greater than 5% of the volume of the reverberation room.

If the equipment is greater than 2% up to 5% of the room volume then the test room shall be qualified according to ISO 3741 with all equipment present in the room. The test facilities shall be qualified for broad-band sound per the corresponding annex in ISO 3741.