

INTERNATIONAL
STANDARD

ISO
1608-1

Second edition
1993-12-01

**Vapour vacuum pumps — Measurement
of performance characteristics —**

Part 1:

Measurement of volume rate of flow
(pumping speed)

ISO 1608-1:1993

<https://standards.iteh.ai/catalog/standards/sist/3c410fd6-b693-4371-8611-24b9641d0140/iso-1608-1-1993>

*Pompes à vide à jet de vapeur — Mesurage des caractéristiques
fonctionnelles —*

Partie 1: Mesurage du débit-volume



Reference number
ISO 1608-1:1993(E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

International Standard ISO 1608-1 was prepared by Technical Committee ISO/TC 112, *Vacuum technology*, Sub-Committee SC 3, *Measurement of the performance characteristics of vacuum pumps*. [ISO 1608-1:1993](https://standards.iteh.ai/catalog/standards/sist/3c410fd6-b693-4371-8611-119964e309/iso-1608-1)

This second edition cancels and replaces the first edition (ISO 1608-1:1980), which has been technically revised.

ISO 1608 consists of the following parts, under the general title *Vapour vacuum pumps — Measurement of performance characteristics*:

- Part 1: *Measurement of volume rate of flow (pumping speed)*
- Part 2: *Measurement of critical backing pressure*

© ISO 1993

All rights reserved. No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Organization for Standardization
Case Postale 56 • CH-1211 Genève 20 • Switzerland

Printed in Switzerland

Introduction

The purpose of ISO 1608 is to ensure that measurements of the performance characteristics of vapour vacuum pumps are, as far as possible, carried out by uniform procedures and under uniform conditions. It is hoped that, as a result, measurements conducted by different manufacturers or in different laboratories, and statements of performance quoted in manufacturers' literature will be on a properly comparable basis to the benefit of both user and manufacturer.

It is envisaged that the complete International Standard will, in due course, deal comprehensively with the measurement of a wide range of performance characteristics of the main types of vapour vacuum pumps. In order, however, that useful agreements of more restricted scope may be implemented with the least possible delay, ISO 1608 is published in parts.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[ISO 1608-1:1993](https://standards.iteh.ai/catalog/standards/sist/3c410fd6-b693-4371-8611-727b5964e1d0/iso-1608-1-1993)

<https://standards.iteh.ai/catalog/standards/sist/3c410fd6-b693-4371-8611-727b5964e1d0/iso-1608-1-1993>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

This page intentionally left blank

ISO 1608-1:1993

<https://standards.iteh.ai/catalog/standards/sist/3c410fd6-b693-4371-8611-727b5964e1d0/iso-1608-1-1993>

Vapour vacuum pumps — Measurement of performance characteristics —

Part 1:

Measurement of volume rate of flow (pumping speed)

1 Scope

This part of ISO 1608 specifies methods of measuring the volume rate of flow of vapour vacuum pumps.

The pumps considered comprise the following three classes of oil and mercury vapour pumps:

- diffusion pumps;
- ejector pumps;
- booster pumps (i.e. pumps capable of operation in both the molecular and laminar flow regions, so combining the properties of diffusion and ejector pumps).

These pumps may be with or without baffle(s) or trap(s).

2 Definitions

For the purposes of this part of ISO 1608, the following definitions apply.

2.1 volume rate of flow; pumping speed: Under ideal conditions, the volume of gas which flows in unit time through the pump inlet.

For practical purposes, however, the volume rate of flow (S) of a given pump for a given gas is, by convention, taken to be the quotient of the throughput (Q) of that gas and the equilibrium pressure (p) at a specified position in a given test dome, and under specified conditions of operation. Thus

$$S = Q/p$$

The units adopted for the volume rate of flow are the cubic metre per hour (m^3/h) or the litre per second

(l/s). For vapour pumps this form of expression of volume rate of flow is considered to be valid only if p exceeds $10p_0$ where p_0 is the ultimate pressure measured by means of the same gauge (see 3.2).

2.2 test dome; test header: A chamber of specific form and dimensions, attached to the inlet of the pump, through which a measured flow of gas may be admitted to the pump, and which is equipped with means of pressure measurement.

2.3 ultimate pressure: Limiting pressure approached asymptotically in the dome, with the gas inlet valve closed and the pump in normal operation.

3 Apparatus

3.1 Test dome, cylindrical and of the form shown in figure 1. The axial dimension of the dome is $1,5D$, where D is the internal diameter, and the test gas entrance is on the axis at a distance D from the connecting flange and so arranged that the gas entrance into the dome is in a direction away from the pump mouth. The connection to the pressure-measuring gauge is at a distance $0,5D$ from the connecting flange with its axis perpendicular to that of the dome. The axis of the test dome shall be perpendicular to the plane of the inlet flange (or inlet) of the pump.

The internal diameter of the test dome shall be the same as that of the mouth of the pump, or of the inlet of any baffle or trap which may be incorporated.

NOTE 1 If internal parts of the pump protrude beyond the flange (or inlet plane) of the pump, the reference plane is at the highest point of these internal parts and at this plane the pump mouth diameter is defined by the arrangement specified by the manufacturer.

3.2 Pressure gauge, calibrated to an accuracy of

± 5 % for pressures greater than or equal to 1 Pa¹⁾ and of ± 10 % for lower pressures.

3.3 Test gas

Dry air shall be used unless otherwise specified.

3.4 Gas throughput measuring device

The method adopted for measuring the throughput of gas will depend on the throughput required. The accuracy shall reach

- a) ± 3 % for throughputs greater than $9,9 \times 10^{-1} \text{ Pa}\cdot\text{m}^3/\text{s}$;
- b) ± 5 % for throughputs between $9,9 \times 10^{-1} \text{ Pa}\cdot\text{m}^3/\text{s}$ and $9,9 \times 10^{-5} \text{ Pa}\cdot\text{m}^3/\text{s}$;
- c) ± 10 % for lower throughputs.

NOTE 2 Ideal gas behaviour at 20 °C is assumed.

4 Test method

4.1 Principle

The method adopted is the "constant-pressure" method, in which the pressure at the mouth of the pump is intended to be kept constant during the measuring procedure. In practice, this condition is considered satisfied if the pressure measured in the test dome remains constant.

4.2 Procedure

For measurement of the volume rate of flow, the test dome, pressure-measuring gauge and flowmeter shall be fitted to the pump as indicated in clause 3. For the purpose of the test, the pump shall be run with the prescribed charge and grade of fluid and at the heating power specified by the manufacturer. The ambient temperature shall be kept constant to within ± 1 °C, for the period of the test, in the range 15 °C to 25 °C unless otherwise specified. The test dome shall be evacuated when isolated from the gas inlet system until, over a period of 1 h, no further pressure drop is observed in the dome and the pump has reached its equilibrium operating temperature. Gas shall then be admitted into the dome in such a manner as to produce the required measurement pressure (taken as an arithmetic mean of pressure gauge readings) and the system shall be allowed to reach a state of pressure equilibrium before measurements are commenced.

The volume rate of flow (pumping speed) shall be measured, starting at the lowest pressure, point-by-point at different inlet pressures (at least five

measurements within one power of ten, i.e. 1,6; 2,5; 4; 6,3 and 10 approximately). In the case of vapour booster pumps, it is desirable to include a corresponding series of measurements commencing at the highest pressure. For each measurement point, the inlet pressure, ambient atmospheric pressure and the throughput of gas shall be determined.

Inlet pressure and input flow of gas shall, as far as possible, be measured simultaneously. If the metering of the input gas takes more than 60 s, a pressure measurement shall be taken for each period of 60 s and the mean value recorded. If the highest and lowest readings differ by more than 10 %, the measurement shall be repeated.

5 Test results

The relationship between the inlet pressure and the volume rate of flow shall be shown on a graph using a logarithmic abscissa for pressure, covering the range from the ultimate pressure up to atmospheric pressure, or such other range as may be appropriate to the design of pump, and a linear ordinate for the volume rate of flow. The corresponding relationship between the inlet pressure and the throughput of gas shall be shown on a graph using a logarithmic abscissa for the pressure and a logarithmic ordinate for the throughput.

6 Test report

The test report shall include the following:

- a) type and conditions of operation of all gauges used;
- b) type of gasket used on the pump inlet flange;
- c) type of any baffle(s) and/or trap(s) employed, and their temperatures during the test;
- d) maximum and minimum inlet and outlet temperatures, of vapour pump cooling water or refrigerant, during the test;
- e) cooling water flowrate;
- f) type and quantity of vapour pump fluid;
- g) type and flowrate of backing pump, if used;
- h) heating power of the pump and limits of variation during the test;
- i) backing pressure and the type of gauge used to measure it;
- j) ambient temperature.

1) 100 Pa = 100 N/m² = 1 mbar; 133 Pa = 1 torr

Dimensions in millimetres




Figure 1 — Test dome

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[ISO 1608-1:1993](https://standards.iteh.ai/catalog/standards/sist/3c410fd6-b693-4371-8611-727b5964e1d0/iso-1608-1-1993)

<https://standards.iteh.ai/catalog/standards/sist/3c410fd6-b693-4371-8611-727b5964e1d0/iso-1608-1-1993>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 1608-1:1993

<https://standards.iteh.ai/catalog/standards/sist/3c410fd6-b693-4371-8611-727b5964e1d0/iso-1608-1-1993>

UDC 621.527.5:532.575.2

Descriptors: vacuum apparatus, vacuum pumps, steam jet pumps, tests, performance evaluation, flow measurement.

Price based on 3 pages
