

SLOVENSKI STANDARD
kSIST-TP FprCEN ISO/TR 52010-2:2017
01-januar-2017

Energetska učinkovitost stavb - Zunanje podnebne razmere - 2. del: Obrazložitev in utemeljitev ISO 52010-1 (ISO/DTR 52010-2:2016)

Energy performance of buildings - External climatic conditions - Part 2: Explanation and justification of ISO 52010-1 (ISO/DTR 52010-2:2016)

Energieeffizienz von Gebäuden - Äußere Klimabedingungen - Teil 2: Erläuterung und Begründung von ISO 52010-1 (ISO/DTR 52010-2:2016)

Performance énergétique des bâtiments - Conditions climatiques extérieures - Partie 2: Explication et justification de l'ISO 52010-1 (ISO/DTR 52010-2:2016)

Ta slovenski standard je istoveten z: FprCEN ISO/TR 52010-2

ICS:

27.015	Energijska učinkovitost. Ohranjanje energije na splošno	Energy efficiency. Energy conservation in general
91.120.10	Toplotna izolacija stavb	Thermal insulation of buildings

kSIST-TP FprCEN ISO/TR 52010-2:2017 en

TECHNICAL REPORT

**ISO/TR
52010-2**

First edition

Energy performance of buildings - External climatic conditions —

Part 2: Explanation and justification of ISO 52010-1

*Performance énergétique des bâtiments — Conditions climatiques
extérieures —*

Partie 2: Explication et justification de l'ISO 52010-1

PROOF/ÉPREUVE



Reference number
ISO/TR 52010-2:2016(E)

© ISO 2016

**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Symbols and subscripts	1
5 Description of the methods	1
5.1 Output of the method	1
5.2 General description of the method	2
5.2.1 Calculation of the distribution of solar irradiance on a non-horizontal plane	2
5.2.2 Calculation of solar shading by distant objects	3
6 Calculation method	4
6.1 Output data	4
6.2 Calculation time intervals	4
6.3 Input data	4
6.4 Calculation procedure	4
6.4.1 Calculation of the sun path	4
6.4.2 Split between direct and diffuse solar irradiance	4
6.4.3 Solar reflectivity of the ground	4
6.4.4 Calculation of the total solar irradiance at given orientation and tilt angle	4
6.4.5 Calculation of shading by external objects	5
6.4.6 Calculation of illuminance	5
7 Quality control	5
8 Compliance check	5
9 Directional (spatial) distribution of hourly solar irradiation or illumination (not covered in ISO 52010-1)	5
9.1 General	5
9.2 Tregenza elements	6
9.3 Allocation of the radiation in each element	6
9.4 Plane at certain orientation and tilt	7
9.5 References	9
10 Worked out examples	9
10.1 Method calculation of the total solar irradiation at given orientation and tilt angle	9
10.2 Calculation of shading by external objects	9
11 Validation	9
12 Information on the accompanying spreadsheet	12
Annex A (informative) Input and method selection data sheet — Template	13
Annex B (informative) Input and method selection data sheet — Default choices	14
Annex C (informative) Calculation examples on the solar irradiation at given orientation and tilt angle	15
Annex D (informative) Calculation examples on the effect of solar shading	20
Bibliography	23

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

The committee responsible for this document is ISO/TC 163, *Thermal performance and energy use in the built environment*, Subcommittee SC 2, *Calculation methods*.

A list of all parts in the ISO 52010- series, published under the general title *Energy performance of buildings — External climatic conditions*, can be found on the ISO website.

Introduction

In order to facilitate the necessary overall consistency and coherence, in terminology, approach, input/output relations and formats, for the whole set of EPB-standards, the following documents and tools are available:

- a) a document with basic principles to be followed in drafting EPB-standards: CEN/TS 16628^[2];
- b) a document with detailed technical rules to be followed in drafting EPB-standards: CEN/TS 16629^[3];
- c) detailed technical rules are the basis for the following tools:
 - 1) a common template for each EPB standard, including specific drafting instructions for the relevant clauses;
 - 2) a common template for each technical report that accompanies an EPB standard or a cluster of EPB standards, including specific drafting instructions for the relevant clauses;
 - 3) a common template for the spreadsheet that accompanies each EPB (calculation) standard, to demonstrate the correctness of the EPB calculation procedures.

Each EPB standard follows the basic principles and the detailed technical rules and relates to the overarching EPB standard, ISO 52000-1¹⁾^[4].

One of the main purposes of the revision of the EPB standards has been to enable that laws and regulations directly refer to the EPB standards and make compliance with them compulsory. This requires that the set of EPB standards consists of a systematic, clear, comprehensive and unambiguous set of energy performance procedures. The number of options provided is kept as low as possible, taking into account national and regional differences in climate, culture and building tradition, policy and legal frameworks (subsidiarity principle). For each option, an informative default option is provided ([Annex B](#)).

Rationale behind the EPB technical reports

There is a risk that the purpose and limitations of the EPB standards will be misunderstood, unless the background and context to their contents – and the thinking behind them – is explained in some detail to readers of the standards. Consequently, various types of informative contents are recorded and made available for users to properly understand, apply and nationally or regionally implement the EPB standards.

If this explanation would have been attempted in the standards themselves, the result is likely to be confusing and cumbersome, especially if the standards are implemented or referenced in national or regional building codes.

Therefore each EPB standard is accompanied by an informative technical report, like this one, where all informative content is collected, to ensure a clear separation between normative and informative contents (see CEN/TS 16629^[3]):

- to avoid flooding and confusing the actual normative part with informative content,
- to reduce the page count of the actual standard, and
- to facilitate understanding of the set of EPB standards.

This was also one of the main recommendations from the European CENSE project^[8] that laid the foundation for the preparation of the set of EPB standards.

1) To be published.

ISO/TR 52010-2:2016(E)

This technical report

This technical report accompanies ISO 52010-1,^[1] which forms part of the set of EPB standards.

The role and the positioning of the accompanied standard in the set of EPB standards is defined in the Introduction to ISO 52010-1. More information on the use of EPB module numbers, in all EPB standards, for normative references to other EPB standards is given in ISO/TR 52000-2^[5].

A brief article on the subject can be found in^[28].

ISO 52010-1 provides the common standard climatic data to be used as input by all EPB standards. It builds on ISO 15927-1, ISO 15927-2 and ISO 15927-4 and completes a missing link: the calculation of the distribution of solar irradiation and illuminance on a non-horizontal plane based on measured hourly solar radiation data on a horizontal surface; with or without taking into account solar shading.

Typical inputs for ISO 52010-1 are the hourly values for diffuse horizontal and direct beam solar irradiation. However, these quantities are not necessarily directly measured. In many cases, only the global horizontal irradiation is available as measured parameter, and the two components need to be calculated with a model. There are alternative models provided, open for choice at national or regional level.

For ground reflectivity often a constant value of, e.g., 0,2 is used. However, the value depends greatly on the surface conditions, and the influence on the irradiation is not negligible. Therefore, the option of providing hourly values is included. This may be especially of importance for mountain regions or for high latitudes.

For the solar shading calculation, the height and distance of each shading object are given per sector of the horizon (360 degrees). The subdivision into sectors (small or large) is open for national or regional choice. The same solar shading calculation procedure is adopted in ISO 52016-1²⁾,^[6] for the calculation of the building energy needs and loads. This is especially important because if there are different shading objects in the same sector, it will not be correct to calculate the effects separately in different standards. It is up to national or regional choice to decide about the details of the solar shading calculations.

Accompanying spreadsheet

In line with the common template for all EPB standards, a spreadsheet has been prepared for demonstration and validation. This spreadsheet shows an overview of all input variables, the (step by step) hourly calculation procedures and an overview of all output variables.

This accompanying calculation spreadsheet (July 2016) provides:

- full year of hourly calculations of solar irradiance (split in components) on plane with any azimuth and tilt angle;
- validated against BESTEST cases;
- hourly calculations of solar shading by multiple shading objects along the skyline. These calculations also cover the calculation procedures for overhangs from ISO 52016-1^[6].

2) To be published.

Energy performance of buildings - External climatic conditions —

Part 2: Explanation and justification of ISO 52010-1

1 Scope

This document contains information to support the correct understanding and use of ISO 52010-1.

This document does not contain any normative provision.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

There are no normative references in this document.

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 52010-1,^[1] apply.

More information on some key EPB terms and definitions is given in ISO/TR 52000-2.^[5]

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

4 Symbols and subscripts

For the purposes of this document, the symbols and subscripts given in ISO 52010-1,^[1] apply.

More information on key EPB symbols and subscripts is given in ISO/TR 52000-2^[5].

5 Description of the methods

5.1 Output of the method

Beside solar radiation data, ISO 52010-1 also contains data regarding

- air temperature;
- atmospheric humidity;
- wind speed;
- wind direction;

ISO/TR 52010-2:2016(E)

— longwave radiation.

The definitions and data are obtained from the ISO 15927 series regarding hygrothermal performance of buildings ([8],[9]).

The reason for passing these data via this standard is to have one single and consistent source for all EPB standards and to enable any treatment if needed for specific application. The above mentioned climatic data are not processed in this standard.

5.2 General description of the method

5.2.1 Calculation of the distribution of solar irradiance on a non-horizontal plane

It is (Torres 2006^[21]) of paramount importance for HVAC (heating, ventilating and air conditioning) and photovoltaic systems designers to have suitable models requiring usually available data in order to calculate the irradiance on the plane where conversion systems are located.

From all the models developed to fulfil this objective, the one of conversion or translation proposed by Perez et al. (1986) has been widely used, as it considers all sky conditions ranging from completely covered to clear sky (Pohlen et al., 1996^[18]).


Essentially, the model is composed of three different components:

- 1) a geometric representation of the sky dome,
- 2) a parametric representation of the insolation conditions, and
- 3) a statistic component linking both components mentioned before (Perez et al., 1987^[16]).

It is a model of anisotropic sky, where the sky dome is geometrically divided into three areas, each of them showing a constant radiance, different from the other two (see [Figure 1](#)).

These three areas are:

- isotropic diffuse (for the sky hemisphere);
- circumsolar radiation;
- horizon brightness.



Key

- a circum-solar radiation
- b sunbeam
- c atmosphere
- d horizon brightening

Figure 1 — Sky hemisphere areas according to Perez

And to be added to these three:

— Isotropic ground reflected radiation.

This anisotropic diffuse (sky) radiation for the plane uses as input hourly values the diffuse horizontal and direct beam solar radiation. Other inputs to the model include the sun's incident angle to the plane, the plane tilt angle from the horizontal, and the sun's zenith angle.

The model is named after Mr Perez. Several improvements were made in the course of time, see the list of references in the bibliography.

The calculation procedure described in ISO 52010-1 is based on the "simplified Perez model" proposed in the early 90s.

5.2.2 Calculation of solar shading by distant objects

Objects in the environment may block part of the solar irradiation on a plane (e.g., hills, trees, other buildings).

The same or other objects may also reflect solar radiation and consequently lead to a higher irradiation.

NOTE For example, on the northern hemisphere, a highly reflecting surface (e.g., glazed adjacent building) in front of the North facing façade of the assessed building.

In order to avoid that for those objects, specific solar reflectivity data are gathered. It is, as simplification, assumed that:

- a) The direct radiation (including circum-solar irradiation) is partially blocked, if the object is in the path between sun and plane;
- b) the diffuse irradiation (including irradiation from ground reflectance) remains unaffected.

This is physically equal to the situation where the radiation reflected (and/or transmitted) by the objects in the environment is equal to the diffuse radiation blocked by these objects.