



SLOVENSKI STANDARD
oSIST prEN 1555-1:2019

01-december-2019

Cevni sistemi iz polimernih materialov za oskrbo s plinastimi gorivi - Polietilen (PE) - 1. del: Splošno

Plastics piping systems for the supply of gaseous fuels - Polyethylene (PE) - Part 1: General

Kunststoff-Rohrleitungssysteme für die Gasversorgung - Polyethylen (PE) - Teil 1: Allgemeines

Systèmes de canalisations en plastique pour la distribution de combustibles gazeux - Polyéthylène (PE) - Partie 1 : Généralités

Ta slovenski standard je istoveten z: prEN 1555-1

SIST EN 1555-1:2021

ICS:

83.140.30	Polimerne cevi in fittingi za snovi, ki niso tekočine	Plastics pipes and fittings for non fluid use
91.140.40	Sistemi za oskrbo s plinom	Gas supply systems

oSIST prEN 1555-1:2019

en,fr,de

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

DRAFT
prEN 1555-1

October 2019

ICS 23.040.01

Will supersede EN 1555-1:2010

English Version

Plastics piping systems for the supply of gaseous fuels - Polyethylene (PE) - Part 1: General

Systèmes de canalisations en plastique pour la
distribution de combustibles gazeux - Polyéthylène
(PE) - Partie 1 : Généralités

Kunststoff-Rohrleitungssysteme für die Gasversorgung
- Polyethylen (PE) - Teil 1: Allgemeines

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 155.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword	3
Introduction	4
1 Scope	5
2 Normative references	5
3 Terms and definitions, symbols and abbreviations	6
4 Material	12
4.1 Material of the components	12
4.2 Compound	12
4.2.1 Additives and pigments	12
4.2.2 Colour	12
4.2.3 Characteristics	12
Table 1 — Characteristics of the compound in the form of granules	13
Table 2 — Characteristics of compound in the form of pipe	15
4.3 Fusion compatibility	16
4.4 Classification and designation	17
Table 4 — Classification and designation of compounds	17
4.5 Design coefficient and design stress	17
Annex A (informative) Additional information related to the installation of PE100-RC systems for non-conventional installations	18
A.1 Pipe material	18
Table A.1 — Resistance to slow crack growth for PE 100 and PE 100-RC	18
A.2 Installation Conditions	19
The usual conventional installation method for PE 80 and PE 100 piping systems is often open trench installation with sand bedding around the pipe.	19
Other non-conventional installation techniques using specialized machinery and trenchless ‘No-Dig’ techniques can increase the risk of scratches and damage to the pipe in more undefined conditions. Using the PE100-RC material with the lower notch sensitivity and reduced rates of crack growth increases the safety, reliability and lifetime of the pipe system, and therefore is used especially for:	19
Bibliography	21

European foreword

This document (prEN 1555-1:2019) has been prepared by Technical Committee CEN/TC 155 “Plastics piping and ducting systems”, the secretariat of which is held by NEN.

This document is currently submitted to the CEN Enquiry.

This document will supersede EN 1555-1:2010.

It has been prepared in liaison with Technical Committee CEN/TC 234 “Gas infrastructure”.

System Standards are based on the results of the work being undertaken in ISO/TC 138 “Plastics pipes, fittings and valves for the transport of fluids”, which is a Technical Committee of the International Organization for Standardization (ISO).

They are supported by separate standards on test methods to which references are made throughout the System Standard.

The System Standards are consistent with general standards on functional requirements and on recommended practice for installation.

EN 1555 consists of the following parts:

- EN 1555-1, *Plastics piping systems for the supply of gaseous fuels - Polyethylene (PE) — Part 1: General* (this document);
- EN 1555-2, *Plastics piping systems for the supply of gaseous fuels - Polyethylene (PE) — Part 2: Pipes*;
- EN 1555-3, *Plastics piping systems for the supply of gaseous fuels - Polyethylene (PE) — Part 3: Fittings*;
- EN 1555-4, *Plastics piping systems for the supply of gaseous fuels - Polyethylene (PE) — Part 4: Valves*;
- EN 1555-5, *Plastics piping systems for the supply of gaseous fuels - Polyethylene (PE) — Part 5: Fitness for purpose of the system*;
- CEN/TS 1555-7, *Plastics piping systems for the supply of gaseous fuels — Polyethylene (PE) — Part 7: Guidance for assessment of conformity*.

NOTE EN 12007-2:2012 [3] prepared by CEN/TC 234 “Gas infrastructure” deals with the recommended practice for installation of plastics pipes system in accordance with EN 1555 (all parts).

prEN 1555-1:2019 (E)

Introduction

This document specifies the requirements for a piping system and its components made from polyethylene (PE) and which is intended to be used for the supply of gaseous fuels.

Requirements and test methods for components of the piping system are specified in prEN 1555-2:2019, prEN 1555-3:2019 and prEN 1555-4:2019.

Characteristics for fitness for purpose are covered in prEN 1555-5:2019 [1]. CEN/TS 1555-7:2019 [2] gives guidance for assessment of conformity. Recommended practices for installation re given in EN 12007-2:2012 [3], prepared by CEN/TC 234.

This part of EN 1555 covers the general aspects of the plastics piping system.

iTeh Standards (<https://standards.iteh.ai>) Document Preview

[SIST EN 1555-1:2021](https://standards.iteh.ai/catalog/standards/sist/1c9fa435-1abb-406f-acfd-8a0de531edc1/sist-en-1555-1-2021)

<https://standards.iteh.ai/catalog/standards/sist/1c9fa435-1abb-406f-acfd-8a0de531edc1/sist-en-1555-1-2021>

1 Scope

This document specifies the general aspects of polyethylene (PE) piping systems in the field of the supply of gaseous fuels.

It also specifies the test parameters for the test methods referred to in this document.

In conjunction with Parts 2 to 5 of EN 1555, this document is applicable to PE pipes, fittings, and valves, their joints and to joints with components of other materials intended to be used under the following conditions:

- a) a maximum operating pressure, MOP, up to and including 10 bar ¹;
- b) an operating temperature of 20 °C as reference temperature.

NOTE 1 For other operating temperatures, derating coefficients can be used, see prEN 1555-5:2019 [1].

EN 1555 (all parts) covers a range of maximum operating pressures and gives requirements concerning colours.

NOTE 2 It is the responsibility of the purchaser or specifier to make the appropriate selections from these aspects, taking into account their particular requirements and any relevant national regulations and installation practices or codes.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

prEN 1555-2:2019, *Plastics piping systems for the supply of gaseous fuels — Polyethylene (PE) — Part 2: Pipes*

prEN 1555-3:2019, *Plastics piping systems for the supply of gaseous fuels — Polyethylene (PE) — Part 3: Fittings*

prEN 1555-4:2019, *Plastics piping systems for the supply of gaseous fuels — Polyethylene (PE) — Part 4: Valves*

EN ISO 472, *Plastics — Vocabulary (ISO 472)*

EN ISO 1043-1, *Plastics — Symbols and abbreviated terms — Part 1: Basic polymers and their special characteristics (ISO 1043-1)*

EN ISO 1133-1, *Plastics — Determination of the melt mass-flow rate (MFR) and the melt volume-flow rate (MVR) of thermoplastics — Part 1: Standard method (ISO 1133-1)*

EN ISO 1167-1:2006, *Thermoplastics pipes, fittings and assemblies for the conveyance of fluids — Determination of the resistance to internal pressure — Part 1: General method (ISO 1167-1:2006)*

EN ISO 1167-2, *Thermoplastics pipes, fittings and assemblies for the conveyance of fluids — Determination of the resistance to internal pressure — Part 2: Preparation of pipe test pieces (ISO 1167-2)*

EN ISO 1183-1, *Plastics — Methods for determining the density of non-cellular plastics — Part 1: Immersion method, liquid pycnometer method and titration method (ISO 1183-1)*

EN ISO 1183-2, *Plastics — Methods for determining the density of non-cellular plastics — Part 2: Density gradient column method (ISO 1183-2)*

¹ 1 bar = 0,1 MPa.

prEN 1555-1:2019 (E)

EN ISO 6259-1, *Thermoplastics pipes — Determination of tensile properties — Part 1: General test method (ISO 6259-1)*

EN ISO 6259-3, *Thermoplastics pipes — Determination of tensile properties — Part 3: Polyolefin pipes (ISO 6259-3)*

EN ISO 9080, *Plastics piping and ducting systems — Determination of the long-term hydrostatic strength of thermoplastics materials in pipe form by extrapolation (ISO 9080)*

EN ISO 11357-6, *Plastics — Differential scanning calorimetry (DSC) — Part 6: Determination of oxidation induction time (isothermal OIT) and oxidation induction temperature (dynamic OIT) (ISO 11357-6)*

EN ISO 12162, *Thermoplastics materials for pipes and fittings for pressure applications — Classification, designation and design coefficient (ISO 12162)*

EN ISO 13477, *Thermoplastics pipes for the conveyance of fluids — Determination of resistance to rapid crack propagation (RCP) — Small-scale steady-state test (S4 test) (ISO 13477)*

EN ISO 13478, *Thermoplastics pipes for the conveyance of fluids — Determination of resistance to rapid crack propagation (RCP) — Full-scale test (FST) (ISO 13478)*

EN ISO 13479, *Polyolefin pipes for the conveyance of fluids — Determination of resistance to crack propagation — Test method for slow crack growth on notched pipes (ISO 13479)*

EN ISO 15512, *Plastics — Determination of water content (ISO 15512)*

EN ISO 16871, *Plastics piping and ducting systems — Plastics pipes and fittings — Method for exposure to direct (natural) weathering (ISO 16871)*

ISO 6964, *Polyolefin pipes and fittings — Determination of carbon black content by calcination and pyrolysis — Test method*

ISO 11413:2018, *Plastics pipes and fittings — Preparation of test piece assemblies between a polyethylene (PE) pipe and an electrofusion fitting*

ISO 11414:2009, *Plastics pipes and fittings — Preparation of polyethylene (PE) pipe/pipe or pipe/fitting test piece assemblies by butt fusion*

ISO 13953, *Polyethylene (PE) pipes and fittings — Determination of the tensile strength and failure mode of test pieces from a butt-fused joint*

ISO 13954, *Plastics pipes and fittings — Peel decohesion test for polyethylene (PE) electrofusion assemblies of nominal outside diameter greater than or equal to 90 mm*

ISO 18553, *Method for the assessment of the degree of pigment or carbon black dispersion in polyolefin pipes, fittings and compounds*

3 Terms and definitions, symbols and abbreviations

For the purposes of this document, the terms and definitions given in EN ISO 472 and EN ISO 1043-1 and the following apply.

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1 Terms and definitions

3.1.1 Geometrical definitions

3.1.1.1

nominal size

DN/OD

numerical designation of by thread the size of a component related to the outside diameter

Note 1 to entry: It is a convenient round number approximately equal to the manufacturing dimension in millimetres (mm). It is not applicable to component designated size.

3.1.1.2

nominal outside diameter

d_n

specified outside diameter assigned to a nominal size DN/OD

Note 1 to entry: Nominal outside diameter is expressed in millimetres.

3.1.1.3

outside diameter at any point

d_e

value of the measurement of the outside diameter through its cross-section at any point of the pipe, rounded to the next greater 0,1 mm

3.1.1.4

mean outside diameter

d_{em}

value of the measurement of the outer circumference of the pipe or spigot end of a fitting in any cross-section divided by π (= 3,142), rounded to the next greater 0,1 mm

3.1.1.5

minimum mean outside diameter

$d_{em,min}$

minimum value for the mean outside diameter as specified for a given nominal size

3.1.1.6

maximum mean outside diameter

$d_{em,max}$

maximum value for the mean outside diameter as specified for a given nominal size

3.1.1.7

out-of-roundness

ovality

difference between the maximum and the minimum outside diameter in the same cross-section of a pipe or spigot

prEN 1555-1:2019 (E)**3.1.1.8****nominal wall thickness** e_n

numerical designation of the wall thickness of a component, which is a convenient round number, approximately equal to the manufacturing dimension in millimetres (mm)

Note 1 to entry: For thermoplastics components conforming to the different parts of EN 1555, the value of the nominal wall thickness, e_n , is identical to the specified minimum wall thickness at any point, e_{\min} .

3.1.1.9**wall thickness at any point** e

wall thickness at any point around the circumference of a component rounded to the next greater 0,1 mm

Note 1 to entry: The symbol for the wall thickness of the fittings and valves body at any point is E .

3.1.1.10**minimum wall thickness at any point** e_{\min}

minimum value for the wall thickness at any point around the circumference of a component, as specified

3.1.1.11**maximum wall thickness at any point** e_{\max}

maximum value for the wall thickness at any point around the circumference of a component, as specified

3.1.1.12**mean wall thickness** e_m

arithmetical mean of a number of measurements of the wall thickness, regularly spaced around the circumference and in the same cross-section of a component, including the measured minimum and the measured maximum values of the wall thickness in that cross-section

[SIST EN 1555-1:2021](https://standards.iteh.ai/catalog/standards/sist/1c9fa435-1abb-406f-acfd-8a0de531edc1/sist-en-1555-1-2021)

3.1.1.13 standards.iteh.ai/catalog/standards/sist/1c9fa435-1abb-406f-acfd-8a0de531edc1/sist-en-1555-1-2021
tolerance

permitted variation of the specified value of a quantity, expressed as the difference between the permitted maximum and the permitted minimum value

3.1.1.14**wall thickness tolerance** t_y

permitted difference between the wall thickness at any point, e , and the nominal wall thickness, e_n

Note 1 to entry: $e_n \leq e \leq e_n + t_y$

3.1.1.15**standard dimension ratio****SDR**

numerical designation of a pipe series, which is a convenient round number, approximately equal to the dimension ratio of the nominal outside diameter, d_n , and the nominal wall thickness, e_n