

SLOVENSKI STANDARD SIST EN 62920:2017

01-december-2017

Fotonapetostni energetski sistemi - Zahteve EMC in preskusne metode za opremo močnostnih pretvornikov

Photovoltaic power generating systems - EMC requirements and test methods for power conversion equipment

iTeh STANDARD PREVIEW (standards.iteh.ai)

Ta slovenski standard je istoveten z: EN 62920:2017 https://standards.iten.avcatalog/standards/stst/ba4eoa2d-74c6-42e6-b963-15022bf79dec/sist-en-62920-2017

ICS:

27.160	Sončna energija	Solar energy engineering
33.100.01	Elektromagnetna združljivost na splošno	Electromagnetic compatibility in general

SIST EN 62920:2017

en



iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 62920:2017 https://standards.iteh.ai/catalog/standards/sist/ba4e6a2d-74c6-42e6-b963-15022bf79dec/sist-en-62920-2017

SIST EN 62920:2017

EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

EN 62920

October 2017

ICS 27.160

English Version

Photovoltaic power generating systems - EMC requirements and test methods for power conversion equipment (IEC 62920:2017)

Systèmes de production d'énergie photovoltaïque -Exigences de CEM et méthodes d'essai pour les équipements de conversion de puissance (IEC 62920:2017) Photovoltaische Stromerzeugungssysteme - EMV-Anforderungen und Prüfverfahren für Leistungsumrichter (IEC 62920:2017)

This European Standard was approved by CENELEC on 2017-08-30. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

SIST EN 62920:2017

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgara, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

© 2017 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

European foreword

The text of document 82/1288/FDIS, future edition 1 of IEC 62920, prepared by IEC/TC 82 "Solar photovoltaic energy systems" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62920:2017.

The following dates are fixed:

•	latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement	(dop)	2018-05-30
•	latest date by which the national standards conflicting with the document have to be withdrawn	(dow)	2020-08-30

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62920:2017 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated: **Teh STANDARD PREVIEW**

IEC 60364-1:2005	(SNOTED	Harmonized as HD 60364-1:2008.
IEC 60974-10	NOTE <u>SI</u>	Harmonized as EN 60974-10. <u>ST EN 62920:2017</u>
IEC 61000 (series) s://standards	iteh <u>ajóre</u> ak 15022bf	perstandards/sist/had 6620-7466-42e6-b963- 79dec/sist-en-62920-2017
IEC 61800-3	NOTE	Harmonized as EN 61800-3.
IEC 61851-21-2 ¹⁾	NOTE	Harmonized as FprEN 61851-21-2.
IEC 62040-2	NOTE	Harmonized as EN 62040-2.

¹⁾ To be published. At draft stage.

Annex ZA

(normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

Publication	<u>Year</u>	<u>Title</u> <u>EN/HD</u>	Year
IEC 61000-3-2	2014	Electromagnetic compatibility (EMC) - Part EN 61000-3-2 3-2: Limits - Limits for harmonic current	2014
		emissions (equipment input current 16 A	
	2012	per phase)	2012
IEC 61000-3-3	2013	Electromagnetic compatibility (EMC) - Part EN 61000-3-3	2013
		3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public	
		low-voltage supply systems, for equipment	
		with rated current ¿ 16 A per phase and	
		not subject to conditional connection	
IEC 61000-3-11	2000	Electromagnetic compatibility (EMC) PartEN 61000-3-11	2000
	iT	3-11: Limits - Limitation of voltage	
		changes, voltage fluctuations and flicker in VV public low-voltage supply systems -	
		Equipment with rated current <= 75 A and	
		subject to conditional connection	
IEC 61000-3-12	2011	Electromagnetic compatibility (EMC) PartEN 61000-3-12	2011
	https://sta	an 3 12: thim its tabinits for barmonic currents 42e6-b963-	
		produced by equipment connected to	
		public low-voltage systems with input	
	2000	current > 16 A and <= 75 A per phase	2000
IEC 61000-4-2	2008	Electromagnetic compatibility (EMC) PartEN 61000-4-2	2009
		4-2: Testing and measurement techniquesElectrostatic discharge immunity test	
IEC 61000-4-3	2006	Electromagnetic compatibility (EMC) PartEN 61000-4-3	2006
	2000	4-3: Testing and measurement techniques	2000
		- Radiated, radio-frequency,	
		electromagnetic field immunity test	
+ A1	2007	÷ + A1	2008
+ A2	2010	+ A2	2010
IEC 61000-4-4	2012	Electromagnetic compatibility (EMC) PartEN 61000-4-4	2012
		4-4: Testing and measurement techniques	
		- Electrical fast transient/burst immunity	
	0044	test	0044
IEC 61000-4-5	2014	Electromagnetic compatibility (EMC) - Part EN 61000-4-5	2014
		 4-5: Testing and measurement techniques Surge immunity test 	
IEC 61000-4-6	2013	Electromagnetic compatibility (EMC) PartEN 61000-4-6	2014
	2010	4-6: Testing and measurement techniques	2014
		- Immunity to conducted disturbances,	
		induced by radio-frequency fields	
IEC 61000-4-7	2002	Electromagnetic compatibility (EMC) PartEN 61000-4-7	2002
		4-7: Testing and measurement techniques	
		- General guide on harmonics and	
		interharmonics measurements and	
		instrumentation, for power supply systems	
		and equipment connected thereto	

EN 62920:2017

+ A1 IEC 61000-4-11	2008 2004	+ A1 Electromagnetic compatibility (EMC) PartEN 61000-4-11	2009 2004
120 01000-4-11	2004	4-11: Testing and measurement techniques - Voltage dips, short interruptions and voltage variations immunity tests	2004
IEC 61000-4-34	2005	Electromagnetic compatibility (EMC) PartEN 61000-4-34 4-34: Testing and measurement techniques - Voltage dips, short interruptions and voltage variations immunity tests for equipment with input current more than 16 A per phase	2007
IEC/TR 61000-3-6	2008	Electromagnetic compatibility (EMC) - Part - 3-6: Limits - Assessment of emission limits for the connection of distorting installations to MV, HV and EHV power systems	-
IEC/TR 61000-3-14	2011	Electromagnetic compatibility (EMC) - Part - 3-14: Assessment of emission limits for harmonics, interharmonics, voltage fluctuations and unbalance for the connection of disturbing installations to LV power systems	-
CISPR 11 (mod)	2015	Industrial, scientific and medical equipment EN 55011 - Radio-frequency disturbance characteristics - Limits and methods of measurement	2016
+ A1 CISPR 16-1-2	2016 2014	Specification for radio disturbance and EN 55016-1-2 immunity measuring apparatus and methods - Part 1-2: Radio disturbance and immunity measuring apparatus - Coupling devices for conducted disturbance	2017 2014
CISPR 32	https://sta 2015	nmeasurementsg/standards/sist/ba4e6a2d-74c6-42e6-b963- Electromagneticcompatibility2ofmultimediaEN 55032 equipment - Emission requirements	2015



Edition 1.0 2017-07

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Photovoltaic power generating systems - EMC requirements and test methods for power conversion equipment dards.iteh.ai)

Systèmes de production d'énergie photovoltaïque – Exigences de CEM et méthodes d'essais pour les équipements de conversion de puissance

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMISSION ELECTROTECHNIQUE INTERNATIONALE

ICS 27.160

ISBN 978-2-8322-4603-0

Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

 Registered trademark of the International Electrotechnical Commission Marque déposée de la Commission Electrotechnique Internationale

CONTENTS

FC	FOREWORD			
IN	INTRODUCTION			
1	Scop	e	8	
2	Norm	native references	8	
3	Term	is and definitions	9	
4		sification of PCE		
т	4.1	Category of environment		
	4.1	Division into classes		
	4.2	Information for users		
5		setup for type test		
5				
	5.1	General		
	5.2	Configuration of test setups		
	5.2.1	-		
	5.2.2			
	5.2.3			
~	5.2.4			
6	•	ating conditions during testing		
	6.1	GeneraliTeh.STANDARD PREVIEW	. 17	
	6.2	Operating conditions for immunity requirement test		
	6.3	Operating conditions for low frequency emission requirement test		
	6.4	Operating conditions for high frequency emission requirement test	.17	
7	Immu	unity requirements <u>SIST EN 62920:2017</u> https://standards.iteh.ai/catalog/standards/sist/ba4e6a2d-74c6-42e6-b963-	. 18	
	7.1	Requirements15022bf79dec/sist-en-62920-2017	.18	
	7.2	Performance criteria		
8	Emis	sion requirements	.22	
	8.1	Low frequency	. 22	
	8.2	High frequency	.24	
	8.2.1	Conducted emission	.24	
	8.2.2	Radiated emission	.27	
9	Test	results and test report	.28	
Ar	nnex A ((informative) Configuration examples of test setups	.29	
	A.1	General	.29	
	A.2	Setups for immunity requirement test		
	A.2.1			
	A.2.2	.		
	A.2.3	B Electrical fast transient/burst	. 32	
	A.2.4	Surge	. 34	
	A.2.5	5 Conducted disturbances, induced by radio-frequency fields	36	
	A.2.6			
	A.3	Setups for high frequency emission requirement test		
	A.3.1			
	A.3.2			
Ar		(informative) Setups for low frequency emission requirement test		
	B.1	General		
	B.2	Example of a test circuit for low frequency emission requirement test		
	B.2.1			

- 3 -

B.2.2 Voltage fluctuations and flicker	
Annex C (informative) Test setup for conducted disturbance measurement	44
C.1 General	
C.2 Examples of a test setup	
Annex D (informative) Alternative test methods for high-power PCE	
D.1 General	
D.2 Alternative method for immunity requirement test	
D.2.1 Alternative method for EFT/burst immunity test	
D.2.2 Alternative method for surge test	47
D.2.3 Alternative test method for conducted disturbances, induced by radio- frequency fields	48
D.2.4 Conducted disturbances measurement	
Bibliography	
Figure 1 – Example of ports	10
Figure 2 – Examples of installation of PV systems in both environments	
Figure 3 – Overview of harmonic requirements up to 75 A	
Figure 4 – Overview of voltage change requirements up to 75 A	
Figure A.1 – Example of a test setup for direct application of discharges to PCE	
Figure A.2 – Example of a test setup for indirect application of discharges to PCE	
Figure A.3 – Example of a test setup for wall-mounted PCE	32
Figure A.4 – Example of a test setup for direct coupling of the test voltage to AC mains power ports	33
Figure A.5 – Example of a test setup for application of the test voltage with a	
capacitive coupling clamp	
Figure A.6 – Example of a test setup for AC mains power ports	
Figure A.7 – Example of a test setup for DC power ports	35
Figure A.8 – Example of a setup of conducted disturbances immunity test applied for wall-mounted PCE	36
Figure A.9 – Example of a test setup using a generator for voltage dips and short interruptions	37
Figure A.10 – Example of a test setup of conducted disturbances measurement applied for wall-mounted PCE	
Figure A.11 – Example of a test setup of conducted disturbances measurement applied for wall-mounted PCE with power circulation	
Figure A.12 – Example of a test setup of conducted disturbances measurement applied for wall-mounted PCE with direct connection to AC mains	
Figure A.13 – Example of a test setup of radiated disturbances measurement applied	
for wall-mounted PCE	
Figure B.1 – Measurement circuit for single-phase two-wire PCE	
Figure B.2 – Measurement circuit for single-phase three-wire PCE	
Figure B.3 – Measurement circuit for three-phase three-wire PCE	
Figure B.4 – Measurement circuit for three-phase four-wire PCE	
Figure B.5 – Measurement circuit for single-phase two-wire PCE	
Figure B.6 – Measurement circuit for single-phase three-wire PCE	
Figure B.7 – Measurement circuit for three-phase three-wire PCE	43
Figure B.8 – Measurement circuit for three-phase four-wire PCE	43

Figure C.1 – Example of a standardized test setup for conducted disturbances measurement with AC mains power supply	45
Figure C.2 – Example of a standardized test setup for conducted disturbances measurement with a laboratory AC power source	46
Figure D.1 – Example of an alternative method for EFT/Burst immunity test	47
Figure D.2 – Example of an alternative coupling/decoupling network for AC mains	48
Figure D.3 – Example of a test setup applying clamp injection method to AC mains power ports	49
Figure D.4 – Alternative test method of conduced disturbances measurement using artificial networks as voltage probes	50
Table 1 – Immunity requirements for class B PCE	19
Table 2 – Immunity requirements for class A PCE	20
Table 3 – Voltage dips and interruption immunity requirements for class B PCE	21
Table 4 – Voltage dips and interruption immunity requirements for class A PCE	21
Table 5 – Performance criteria for immunity tests	22
Table 6 – Disturbance voltage limits at the AC mains power port for class A PCE measured on a test site	25
Table 7 – Disturbance voltage limits at the AC mains power port for class B PCE measured on a test site.	25
Table 8 – Disturbance limits at the DC power port for class A PCE measured on a test site.	26
Table 9 – Disturbance limits at the DC power port for class B PCE measured on a test site.	
Table 10 – Limits of conducted common mode (asymmetric mode) disturbance at the wired port for class APPC Endards iteh ai/catalog/standards/sist/ba4e6a2d-74c6-42e6-b963-	27
Table 11 – Limits of conducted common mode (asymmetric mode) disturbance at the wired port for class B PCE	27
Table 12 – Electromagnetic radiation disturbance limits for class A PCE measured on a	27
Table 13 – Electromagnetic radiation disturbance limits for class B PCE measured on a test site	28

IEC 62920:2017 © IEC 2017

– 5 –

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PHOTOVOLTAIC POWER GENERATING SYSTEMS – EMC REQUIREMENTS AND TEST METHODS FOR POWER CONVERSION EQUIPMENT

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, EC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62920 has been prepared by IEC technical committee 82: Solar photovoltaic energy systems.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
82/1288/FDIS	82/1313/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

- 6 -

IEC 62920:2017 © IEC 2017

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>SIST EN 62920:2017</u> https://standards.iteh.ai/catalog/standards/sist/ba4e6a2d-74c6-42e6-b963-15022bf79dec/sist-en-62920-2017 IEC 62920:2017 © IEC 2017

INTRODUCTION

Background

Power conversion equipment (PCE) is indispensable for solar photovoltaic power energy systems in order to convert the DC electric power energy generated by solar photovoltaic panels into AC electric power, and to feed the AC power energy into the AC mains network or loads.

In recent years, standardization of EMC requirements for PCE has become more active. For example, CISPR/B has been considering the limits and measurement method for conducted disturbances at DC power ports of grid connected power converters since 2008. These proposed limits and measurement methods form the basis of the instructions for supplementing CISPR 11 in order to cover the set of EMC requirements for the PCE applying to the solar photovoltaic power energy systems. EMC requirements for PCE were added in CISPR 11 Ed.6.0 which was published in 2015. Some product committees, which consider products utilizing PCE, have their own product standards on EMC requirements. SC 22G has developed IEC 61800-3 to define the limits and test methods for power drive systems. SC 22H has IEC 62040-2 for uninterrupted power supplies, and TC 26 has IEC 60974-10 for arc welding. TC 9 sets the emission limits with IEC 62236 (all parts). Moreover, TC 69 will have IEC 61851-21-2¹ covering EMC requirements for conducted charging stations for electric vehicles.

Purpose of the development of a product EMC standard

IEC Guide 107 specifies that TC 77 and CISPR have responsibility for developing the basic and generic standards for EMC requirements of products. Therefore, product committees are not free to set their own emission limits. If product committees intend to require immunity to particular disturbances, they shall refer to these basic EMC immunity standards.

However, when the EMC standards which are developed by TC 77 and CISPR are not considered suitable for a particular product or electromagnetic environment, product committees shall seek their assistance and advice for any change in the emission limits and/or measurement requirements.

Product committees are responsible for selecting the appropriate immunity test items and levels for their products as well as for defining the relevant performance criteria for the evaluation of the immunity test results. Consequently, product committees, such as TC 22, TC 26, TC 9, and TC 69, have their own EMC standard to define EMC limits and test methods for their products.

On the other hand, TC 82 does not have its own product EMC standards. Therefore, TC 82 has to refer to the generic standards. Nevertheless, TC 82 has the responsibility to consider EMC requirements for PCE applying to the solar photovoltaic power energy systems, and TC 82 can take action as follows to develop its own product EMC standards:

- a) select the immunity test items in accordance with EMC environments for the solar photovoltaic power energy systems;
- b) supplement generic standards with a detailed description of test conditions and test set up;
- c) propose the conditional limits and alternative test methods in terms of installation environmental and operational conditions;
- d) develop appropriate requirements and test method for high power equipment.

This document presents the minimum EMC requirements for PCE applying to solar photovoltaic power energy systems.

¹ Under preparation. Stage at the time of publication: IEC AFDIS 61851-21-2:2017.

- 8 -

IEC 62920:2017 © IEC 2017

PHOTOVOLTAIC POWER GENERATING SYSTEMS -EMC REQUIREMENTS AND TEST METHODS FOR POWER CONVERSION EQUIPMENT

1 Scope

This document specifies electromagnetic compatibility (EMC) requirements for DC to AC power conversion equipment (PCE) for use in photovoltaic (PV) power systems.

The PCE covered by this document can be grid-interactive, which is termed as a grid connected power converter (GCPC), or stand-alone. It can be supplied by single or multiple photovoltaic modules grouped in various array configurations, and can be intended for use in conjunction with batteries or other forms of energy storage.

NOTE A micro inverter is an example of a GCPC supplied by a single photovoltaic module.

This document covers not only PCE connected to a public low voltage AC mains network or other low voltage AC mains installation, but also PCE connected to a medium or high voltage AC network with or without step-down power transformers. Requirements for the PCE connected to a medium or high voltage AC network are specified in this document. However, some requirements relevant to grid interconnection are addressed with other standards specifying power quality or their own grid codes in some countries.

NOTE DC/DC converters used for PV systems are not yet covered in this document. They can cause electromagnetic interference due to conducted disturbances at DC ports. SIST EN 62920:201

PCE is assessed with EMC requirements as a type test at a test site. This document provides test methods and test conditions for PCE as well as emission and immunity requirements, but not for photovoltaic modules and other balance of system components.

When compliance with EMC requirements at the test site cannot be shown due to technical reasons of the test site, PCE can be assessed in situ, such as at the manufacturer's premises or in the field where the PCE is assembled into a PV power system. However, only high frequency emission requirements for in situ assessment are specified in CISPR 11.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61000-3-2:2014, Electromagnetic compatibility (EMC) – Part 3-2: Limits – Limits for harmonic current emissions (equipment with input current \leq 16 A per phase)

IEC 61000-3-3:2013, Electromagnetic compatibility (EMC) - Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current \leq 16 A per phase and not subject to conditional connection

IEC TR 61000-3-6:2008, Electromagnetic compatibility (EMC) – Part 3-6: Limits – Assessment of emission limits for the connection of distorting installations to MV, HV and EHV power systems

IEC 62920:2017 © IEC 2017

IEC 61000-3-11:2000, Electromagnetic compatibility (EMC) – Part 3-11: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems – Equipment with rated current \leq 75 A and subject to conditional connection

IEC 61000-3-12:2011, Electromagnetic compatibility (EMC) – Part 3-12: Limits – Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current > 16 A and \leq 75 A per phase

IEC TR 61000-3-14:2011, Electromagnetic compatibility (EMC) – Part 3-14: Assessment of emission limits for harmonics, interharmonics, voltage fluctuations and unbalance for the connection of disturbing installations to LV power systems

IEC 61000-4-2:2008, Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test

IEC 61000-4-3:2006, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test* IEC 61000-4-3:2006/AMD1:2007 IEC 61000-4-3:2006/AMD2:2010

IEC 61000-4-4:2012, Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test

IEC 61000-4-5:2014, Electromagnetic compatibility (EMC) Rart 4-5: Testing and measurement techniques – Surge immunity test

standards.iteh.ai)

IEC 61000-4-6:2013, Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields

https://standards.iteh.ai/catalog/standards/sist/ba4e6a2d-74c6-42e6-b963-

IEC 61000-4-7:2002, *Electromagnetic (7 compatibility20 (EMC) – Part 4-7: Testing and measurement techniques – General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto IEC 61000-4-7:2002/AMD1:2008*

IEC 61000-4-11:2004, Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests

IEC 61000-4-34:2005, Electromagnetic compatibility (EMC) – Part 4-34: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests for equipment with input current more than 16 A per phase

CISPR 11:2015, Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement CISPR 11:2015/AMD1:2016

CISPR 16-1-2:2014, Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-2: Radio disturbance and immunity measuring apparatus – Coupling devices for conducted disturbance measurements

CISPR 32:2015, *Electromagnetic compatibility of multimedia equipment – Emission requirements*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.