# TECHNICAL REPORT

# ISO/TR 16822

First edition

# Building environment design — List of test procedures for heating, ventilating, air-conditioning and domestic hot water equipment related to energy efficiency

Conception de l'environnement des bâtiments - Liste des procédures d'essai liés à l'efficacité thermique pour les installations de chauffage, ventilation, air conditionné et eau chaude à usage domestique — Équipement de chauffage, de ventilation et de refroidissement — Exigences relatives au rendement d'énergie

PROOF/ÉPREUVE



Reference number ISO/TR 16822:2016(E)

Hitos: GARA ASTC. 931c. dodge Ridge Ridge Chiso. Ir. Joseph Red Ridge Ri



## COPYRIGHT PROTECTED DOCUMENT

#### © ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office Ch. de Blandonnet 8 • CP 401 CH-1214 Vernier, Geneva, Switzerland Tel. +41 22 749 01 11 Fax +41 22 749 09 47 copyright@iso.org www.iso.org

COI	ontents	Page
Fore	reword	iv
Intro	troduction	v
1	Scope	1
2	List of procedures by organization	1
3	Terms and definitions	5
Bibli	Mechanical equipment test procedures by equipment type 4.1 General 4.2 Air conditioner and condensing unit test procedures 4.3 Electrically operated unitary and applied heat pump test procedures 4.4 Water chilling package test procedures 4.5 Packaged terminal and room air conditioner and heat pump 4.6 Furnace, duct furnace, and unit heater test procedures 4.7 Boiler test procedures 4.8 Cooling tower and condenser test procedures 4.9 Water heaters, pool heaters, and unfired storage tank test procedures 4.10 Energy using auxiliary equipment	50cedures 5

# **Foreword**

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see <a href="www.iso.org/directives">www.iso.org/directives</a>).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see <a href="https://www.iso.org/patents">www.iso.org/patents</a>).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: <a href="https://www.iso.org/iso/foreword.html">www.iso.org/iso/foreword.html</a>.

The committee responsible for this document is 180/TC 205, Building environment design.

# Introduction

The world's energy resources are being consumed at a significant rate that will result in the depletion of known fossil fuel resources within the next century. Combustion of fossil fuels has contributed to the build-up of greenhouse gases in the atmosphere resulting in discernible climate change. The ill effects of climate change have been documented. It is imperative that energy be conserved. The building industry, through its use of energy, accounts for 30 % to 35 % of all fossil fuel usage. Conservation of energy in buildings can result in a slowing down of fossil fuel usage and consequently the build-up of greenhouse gases.

The energy efficiencies of components in HVAC systems are critical factors when determining building overall energy performance. Therefore, it is necessary to define common test methods that are to be used to determine efficiency for space heating, space cooling, and water heating equipment, in order to improve energy conservation. Space heating, space cooling, and water heating equipment are typically regulated by specifying both a measure of efficiency that the equipment must meet and a test method that must be used to determine that measure of efficiency. A technical report containing test procedures and globally relevant standards for the energy-efficiency of products is needed for the proper assessment of building energy performance. This Technical Report will be a useful reference for standards developed by ISO/TC 205 and ISO/TC 163-ISO/TC 205. The ultimate goal of this effort is to develop a set of globally adopted HVAC equipment testing and rating standards under the auspices of ISO.

This Technical Report lists existing HVAC equipment testing and rating procedures from around the world. Standards are listed in two ways, by the standards writing organization and by the type of equipment addressed in the standard. In Glause 2, procedures are listed by the organization that developed the procedure. In Clause 4, procedures are listed by the types of equipment that are covered by the procedure. Procedures are listed to aid in the development of new ISO procedures that may be globally adopted.

PROOF/ÉPREUVE

I CH ST A RIP A RELEASING A RESIDENCE OF THE STATE OF THE

# Building environment design — List of test procedures for heating, ventilating, air-conditioning and domestic hot water equipment related to energy efficiency

# 1 Scope

This Technical Report lists testing and rating procedures for determining energy efficiency of heating, ventilating, and air conditioning equipment. This Technical Report is applicable to space conditioning and water heating equipment. Testing and rating procedures are listed in two ways.

# 2 List of procedures by organization

The following documents contain provisions which, through reference in this text, constitute provisions of this Technical Report. For dated references, subsequent amendments to, or revisions of, any of these publications do not apply. However, parties to agreements based on this Technical Report are encouraged to investigate the possibility of applying the most recent editions of the documents indicated below. For undated references, the latest edition of the document referred to and any updates applies. Members of ISO and IEC maintain registers of currently valid International Standards.

#### **AHRI**

AHRI 400 with Addendum 2 Liquid-to-Liquid Heat Exchangers

AHRI 1230, Performance Rating of Variable Refrigerant Flow (VRF) Multi-split Air-Conditioning and Heat Pump Equipment

AHRI 1160, Performance Rating of Heat Pump Pool Heaters

#### **AMCA**

AMCA 500-D-07, Laboratory Methods of Testing Dampers for Rating

#### **ANSI**

ANSI Z21.47, Gas-Fired Central Furnaces

ANSI Z83.8, Gas Unit Heaters and Duct Furnaces

## **AHAM**

ANSI AHAM RAC-1, Room Air-Conditioners

## **ASHRAE**

ANSI ASHRAE 118.1, Method of Testing Commercial Gas, Electric and Oil Water Heaters

ANSI ASHRAE 118.2, Method of Testing Residential Gas, Electric, and Oil Water Heaters

ANSI ASHRAE 146, Method of Testing for Rating Pool Heaters

ASHRAE Standard 103, Method of Testing for Annual Fuel Utilization Efficiency of Residential Central Furnaces and Boilers

#### **AHRI**

AHRI 210/240, Unitary Air-conditioning and Air Source Heat Pump Equipment

# ISO/TR 16822:2016(E)

AHRI 310/380, Packaged Terminal Air-conditioners and Heat Pumps

AHRI 340/360, Commercial and Industrial Unitary Air-conditioning and Heat Pump Equipment

AHRI 365, Commercial and Industrial Unitary Air-conditioning Condensing Equipment

AHRI 390, Performance Rating of Single Packaged Vertical Air Conditioners and Heat Pumps

AHRI 460, Remote Mechanical-Draft Air-Cooled Refrigerant Condensers

AHRI 550/590 with Addenda through July 2002, Water Chilling Packages Using the Vapor Compression Cycle

AHRI 560, Absorption Water Chilling and Water Heating Packages

#### **CTI**

CTI ATC-105, Acceptance Test Code for Water Cooling Towers

CTI STD-201, Standard for Certification of Water Cooling Tower Thermal Performance

#### DOE

DOE 10 CFR Part 430, Appendix N, Uniform Test Method for Measuring the Energy Consumption of Furnaces

#### **EN**

EN 297, Atmospheric gas boiler without fan, < 70 kW

EN 303-1, Boilers with forced draught burners — General requirements

EN 303-2, Boilers with forced draught burners—Atomizing oil burners

EN 303-3, Gas boilers with forced draught burners — Assemblies

EN 303-4, Boilers with forced draught burners — Qil burners < 70 kW

EN 303-6, Boilers with forced draught burners oil fired combi-boilers

EN 416, Single-burner gas-fired overhead radiant tube heaters for non-domestic use — Part 2: Rational use of energy

EN 419, Non-domestic gas-fired overhead luminous radiant heaters — Part 2: Rational use of energy

EN 625, Gas-fired combi-boilers

EN 15035, Room-sealed (type C) oil-fired boilers

EN 15456, Electrical power consumption for heat generators

EN 267, Forced draught oil burners — Definitions, requirements, testing, marking

EN 304, Atomizing oil burners — Test code

EN 303-7, Boilers with forced draught burners — Gas fired boilers < 1000 kW

EN 656, *Gas boilers, type B, 70 - 300 kW* 

EN 13836, Gas boilers, type B, 300 - 1000 kW

EN 483, Gas boilers, type C < 70 kW

EN 677, Gas condensing boilers < 70 kW

EN 15034, Condensing oil boilers < 1000 kW

EN 13203-1, Gas-fired water heaters, performance assessment

EN 13203-2, Gas fired water heaters, energy use assessment

EN 12897, Water supply — Specification for indirectly heated unvented (closed) storage water heaters

EN 15332, Heating boilers — Energetic assessment of hot water storage tanks

EN 89, Gas-fired storage water heaters for the production of domestic hot water

EN 26, Gas-fired instantaneous water heaters for sanitary uses production, fitted with atmospheric burners

EN 12976-1, Thermal solar systems and components — Factory made systems — Part 1: General requirements

EN 12976-2, Thermal solar systems and components — Factory made systems — Part 2: test methods

EN 14511-1:2011, Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling — Part 1: Terms and definitions

EN 14511-2:2011, Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling — Part 2: Test conditions

EN 14511-3:2011, Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling — Part 3. Test methods

EN 14511-4:2011, Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling —Part 4: Requirements

EN 12102:2008, Air conditioners, liquid chilling packages, heat pumps and dehumidifiers with electrically driven compressors for space heating and cooling.—Measurement of airborne noise.— Determination of the sound power level

EN 15218:2006, Air conditioners and liquid chilling packages with evaporatively cooled condenser and with electrically driven compressors for space cooling — Terms, definitions, test conditions, test methods and requirements

EN 14825:2012, Air conditioners, liquid chilling packages and heat pumps, with electrically driven compressors, for space heating and cooling — Testing and rating at part load conditions and calculation of seasonal performance

EN 15240:2007, Ventilation for buildings — Energy performance of buildings — Guidelines for inspection of air-conditioning systems

EN 12599:2012, Ventilation for buildings — Test procedures and measurement methods to hand over air conditioning and ventilation systems

EN 15726:2011, Ventilation for buildings — Air diffusion — Measurements in the occupied zone of air-conditioned/ventilated rooms to evaluate thermal and acoustic conditions

### НІ

HI, Division of GAMA, BTS 2000, *Testing Standard Method to Determine Efficiency of Commercial Space Heating Boilers* 

#### ISO

ISO 13256-1, Water Source Heat Pumps — Testing and Rating for Performance — Part 1: Water-to-Air and Brine-to-Air Heat Pumps

ISO 13256-2, (1998), Water-Source Heat Pumps — Testing and Rating for Performance — Part 2: Water-to-Water and Brine-to-Water Heat Pumps