
**Guidelines for treated wastewater use
for irrigation projects —**

**Part 2:
Development of the project**

*Lignes directrices pour l'utilisation des eaux usées traitées en
irrigation —*

iTeh STANDARD PREVIEW
Partie 2: Développement du projet
(standards.iteh.ai)

ISO 16075-2:2015

<https://standards.iteh.ai/catalog/standards/sist/0a85e995-9f0d-4890-b9dd-14c2ddab2d50/iso-16075-2-2015>



iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 16075-2:2015

<https://standards.iteh.ai/catalog/standards/sist/0a85e995-9f0d-4890-b9dd-14c2ddab2d50/iso-16075-2-2015>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2015, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

	Page
Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms, definitions, and abbreviated terms	1
3.1 General.....	1
3.2 Use of treated wastewater (TWW).....	3
3.3 Wastewater quality.....	4
3.4 Irrigation systems.....	5
3.5 Wastewater system related components.....	7
3.6 Abbreviated terms.....	8
4 Public health and water quality parameters to take into consideration in TWW irrigation 9	
4.1 Suggested treated wastewater quality levels.....	9
4.2 TWW quality needed for irrigation use.....	13
4.2.1 Agricultural use.....	13
4.2.2 Urban use.....	13
4.3 Barriers concept.....	13
4.3.1 Types of barriers.....	14
4.3.2 Crops that can be irrigated without barriers.....	14
4.3.3 Barriers in the irrigation of public gardens.....	14
4.3.4 Barriers in the irrigation of fodder crops.....	14
4.3.5 Possible barriers.....	14
4.3.6 Barriers needed for irrigation with TWW according to their quality.....	16
4.3.7 Examples for calculating the numbers and types of barriers.....	16
5 Public health aspects of flood and furrow irrigation with TWW	17
6 Public health risks for surrounding residents	17
Annex A (informative) Adjustment of the TWW quality used for irrigation and the barriers that can be used to the types of crops that can be irrigated with the TWW	18
Bibliography	24

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 282, *Water reuse*, Subcommittee SC 1, *Treated wastewater use for irrigation*.

ISO 16075 consists of the following parts, under the general title *Guidelines for treated wastewater use for irrigation projects*:

- *Part 1: The basis of a reuse project for irrigation*
- *Part 2: Development of the project*
- *Part 3: Components of a reuse project for irrigation*

The following parts are under preparation:

- *Part 4: Monitoring*

Introduction

The increasing water scarcity and water pollution control efforts in many countries have made treated municipal and industrial wastewater a suitable economic means of augmenting the existing water supply especially when compared to expensive alternatives such as desalination or the development of new water sources involving dams and reservoirs. Water reuse makes it possible to close the water cycle at a point closer to cities by producing “new water” from municipal wastewater and reducing wastewater discharge to the environment.

An important new concept in water reuse is the “fit-to-purpose” approach, which entails the production of reclaimed water quality that meets the needs of the intended end-users. In the situation of reclaimed water for irrigation, the reclaimed water quality can induce an adaptation of the type of plant grown. Thus, the intended water reuse applications are to govern the degree of wastewater treatment required and inversely, the reliability of wastewater reclamation processes and operation.

Treated wastewater can be used for various non-potable purposes. The dominant applications for the use of treated wastewater (also referred to as reclaimed water or recycled water) include agricultural irrigation, landscape irrigation, industrial reuse, and groundwater recharge. More recent and rapidly growing applications are for various urban uses, recreational and environmental uses, and indirect and direct potable reuse.

Agricultural irrigation was, is, and will likely remain the largest reuse water consumer with recognized benefits and contribution to food security. Urban water recycling, landscape irrigation in particular, is characterized by fast development and will play a crucial role for the sustainability of cities in the future including energy footprint reduction, human well-being, and environmental restoration.

It is worth noting again that the suitability of treated wastewater for a given type of reuse depends on the compatibility between the wastewater availability (volume) and water irrigation demand throughout the year, as well as on the water quality and the specific use requirements. Water reuse for irrigation can convey some risks for health and environment, depending on the water quality, the irrigation water application method, the soil characteristics, the climate conditions, and the agronomic practices. Consequently, the public health and potential agronomic and environmental adverse impacts are to be considered as priority elements in the successful development of water reuse projects for irrigation. To prevent such potential adverse impacts, the development and application of international guidelines for the reuse of treated wastewater is essential.

The main water quality factors that determine the suitability of treated wastewater for irrigation are pathogen content, salinity, sodicity, specific ion toxicity, other chemical elements, and nutrients. Local health authorities are responsible for establishing water quality threshold values depending on authorized uses and they are also responsible for defining practices to ensure health and environmental protection taking into account local specificities.

From an agronomic point of view, the main limitation in using treated wastewater for irrigation arises from its quality. Treated wastewater, unlike water supplied for domestic and industrial purposes, contains higher concentrations of inorganic suspended and dissolved materials (total soluble salts, sodium, chloride, boron, and heavy metals), which can damage the soil and irrigated crops. Dissolved salts are not removed by conventional wastewater treatment technologies and appropriate good management, agronomic, and irrigation practices should be used to avoid or minimize potential negative impacts.

The presence of nutrients (nitrogen, phosphorus, and potassium) can become an advantage due to possible saving in fertilizers. However, the amount of nutrients provided by treated wastewater along the irrigation period is not necessarily synchronized with crop requirements and the availability of nutrients depends on the chemical forms.

This guideline provides guidance for healthy, hydrological, environmental and good operation, monitoring, and maintenance of water reuse projects for unrestricted and restricted irrigation of agricultural crops, gardens, and landscape areas using treated wastewater. The quality of supplied treated wastewater has to reflect the possible uses according to crop sensitivity (health-wise and

ISO 16075-2:2015(E)

agronomy-wise), water sources (the hydrologic sensitivity of the project area), the soil, and climate conditions.

This guideline refers to factors involved in water reuse projects for irrigation regardless of size, location, and complexity. It is applicable to intended uses of treated wastewater in a given project even if such uses will change during the project's lifetime as a result of the changes in the project itself or in the applicable legislation.

The key factors in assuring the health, environmental, and safety of water reuse projects in irrigation are the following:

- meticulous monitoring of treated wastewater quality to ensure the system functions as planned and designed;
- design and maintenance instructions of the irrigation systems to ensure their proper long-term operation;
- compatibility between the treated wastewater quality, the distribution method, and the intended soil and crops to ensure a viable use of the soil and undamaged crop growth;
- compatibility between the treated wastewater quality and its use to prevent or minimize possible contamination of groundwater or surface water sources.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[ISO 16075-2:2015](https://standards.iteh.ai/catalog/standards/sist/0a85e995-9f0d-4890-b9dd-14c2ddab2d50/iso-16075-2-2015)

<https://standards.iteh.ai/catalog/standards/sist/0a85e995-9f0d-4890-b9dd-14c2ddab2d50/iso-16075-2-2015>

Guidelines for treated wastewater use for irrigation projects —

Part 2: Development of the project

1 Scope

This part of ISO 16075 covers the following issues:

- criteria for the design of treated wastewater (hereinafter: TWW) irrigation projects intended to prevent public health risks within the population that has been in direct or indirect contact with the TWW or with any product that has come in contact with the TWW;
- specifications of the following:
 - i) the quality of the TWW that can be used for irrigation;
 - ii) the types of crops that can be irrigated with TWW;
 - iii) the combination of the qualities of the irrigated TWW and the types of crops that can be irrigated;
 - iv) the strategy of using barriers that can reduce the risks that arise from TWW irrigation;
 - v) the correlation between the quality of the TWW, the irrigated crops, and the types of barriers that can be used;
 - vi) the distance required between the TWW irrigation areas and residential areas.
 - vii) none of the parts of this part of ISO 16075 are intended to be used for certification purposes.

2 Normative references

There are no normative references.

3 Terms, definitions, and abbreviated terms

3.1 General

3.1.1 aquifer

underground layer of water-bearing permeable rock or unconsolidated materials (gravel, sand, or silt) from which groundwater can be extracted

3.1.2 background water

freshwater (3.1.10) supplied for domestic, institutional, commercial, and industrial use from which *wastewater* (3.1.22) is created

3.1.3

barrier

any means that reduces or prevents the risk of human infection by preventing contact between the TWW and the ingested produce or other means that, for example, reduces the concentration of microorganisms in the TWW or prevents their survival on the ingested produce

3.1.4

environment

surroundings in which an *organization* (3.1.13) operates including air, water, land, natural resources, flora, fauna, humans, and their interrelation

3.1.5

environmental aspect

element of an *organization's* (3.1.13) activities, projects, or products that can interact with the *environment* (3.1.4)

3.1.6

environmental impact

any change to environmental quality whether adverse or beneficial or wholly or partly resulting from an *organization's* (3.1.13) activities, projects, or *products* (3.1.15)

3.1.7

environmental parameter

quantifiable attribute of an *environmental aspect* (3.1.5)

3.1.8

fodder crops

crops not for human consumption such as pastures and forage, fiber, ornamental, seed, forest, and turf crops

3.1.9

food crops

crops which are intended for human consumption often further classified as to whether the food crop is to be cooked, processed, or consumed raw

3.1.10

freshwater

naturally occurring water on the Earth's surface (in ice, lakes, rivers, and streams) and underground as groundwater in *aquifers* (3.1.1)

Note 1 to entry: Freshwater includes desalinated seawater and desalinated brackish water, but excludes seawater and brackish water.

3.1.11

irrigation project

design, development, construction, selection of equipment, operation, and monitoring of works to provide suitable TWW irrigation

3.1.12

non-potable water

NPW

water that is not of drinking water quality

Note 1 to entry: It generally refers to *wastewater* (3.1.22) or TWW, but can also include other waters of non-drinking quality.

3.1.13

organization

group of people and facilities with an arrangement of responsibilities, authorities, and relationships

iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 16075-2:2015

[https://standards.iteh.ai/catalog/standards/sist/0a85e995-9f0d-4890-b9dd-](https://standards.iteh.ai/catalog/standards/sist/0a85e995-9f0d-4890-b9dd-14c2ddab2d50/iso-16075-2-2015)

[14c2ddab2d50/iso-16075-2-2015](https://standards.iteh.ai/catalog/standards/sist/0a85e995-9f0d-4890-b9dd-14c2ddab2d50/iso-16075-2-2015)

3.1.14
process

set of interrelated or interacting activities which transform inputs into outputs

Note 1 to entry: Inputs to a process are generally outputs of other processes.

Note 2 to entry: Processes in an *organization* (3.1.13) are generally planned and carried out under controlled conditions to add value.

3.1.15
product

any goods or services

Note 1 to entry: This includes interconnected and/or interrelated goods or services.

3.1.16
public health aspect

element of an *organization's* (3.1.13) activities, projects, or *products* (3.1.15) that can interact with the public health

3.1.17
public health impact

any change to public health, whether adverse or beneficial, wholly or partly resulting from an *organization's* (3.1.13) activities, projects, or *products* (3.1.15)

3.1.18
public health parameter

quantifiable attribute of a *public health aspect* (3.1.17)

3.1.19
soil

layer of unconsolidated material consisting of weathered material particles, dead and living organic matter, air space, and the *soil solution* (3.1.20)

3.1.20
soil solution

liquid phase of the *soil* (3.1.19) and its solutes

3.1.21
stakeholder

individual, group, or *organization* (3.1.13) that has an interest in an organization or activity

Note 1 to entry: Usually, a stakeholder can affect or is affected by the organization or the activity.

3.1.22
wastewater

wastewater collected principally by municipalities that can include spent or used water from domestic, institutional, commercial, or industrial sources and can include storm water

3.1.23
water reuse

use of treated wastewater for beneficial use

Note 1 to entry: Synonymous also to water reclamation and water recycling.

3.2 Use of treated wastewater (TWW)

3.2.1
agriculture

science or practice of farming including cultivation of the *soil* (3.1.19) for the growing of crops and the rearing of animals to provide food or other *products* (3.1.15)

3.2.2

landscape

all the visible features of an area of land often considered in terms of their aesthetic appeal such as public and private gardens, parks, and road vegetation including lawns and turfed recreational areas

3.2.3

restricted irrigation

use of TWW for non-potable applications in settings where public access is controlled or restricted by physical or institutional barriers

3.2.4

restricted urban irrigation

irrigation of areas in which public access during irrigation can be controlled such as some golf courses, cemeteries, and highway medians

3.2.5

unrestricted irrigation

use of TWW for non-potable applications in settings where public access is not restricted

3.2.6

unrestricted urban irrigation

irrigation of areas in which public access during irrigation is not restricted, such as some gardens and playgrounds

3.3 Wastewater quality

iTeh STANDARD PREVIEW

3.3.1

category A: very high quality TWW (standards.iteh.ai)

raw wastewater (3.3.6) which has undergone physical and biological treatment, *filtration* (3.5.3) and *disinfection* (3.5.2), and its quality is according to the description in row A of [Table 1](#)

<https://standards.iteh.ai/catalog/standards/sist/0a85e995-9f0d-4890-b9dd-14c2ddab2d50/iso-16075-2-2015>

3.3.2

category B: high quality TWW

raw wastewater (3.3.6) which has undergone physical and biological treatment, *filtration* (3.5.3) and *disinfection* (3.5.2), and its quality is according to the description in row B of [Table 1](#)

3.3.3

category C: good quality TWW

raw wastewater (3.3.6) which has undergone physical and biological treatment and its quality is according to the description in row C of [Table 1](#)

3.3.4

category D: medium quality TWW

raw wastewater (3.3.6) which has undergone physical and biological treatment and its quality is according to the description in row D of [Table 1](#)

3.3.5

category E: extensively TWW

raw wastewater (3.3.6) which has undergone natural biological treatment process with long (minimum 10 d to 15 d) retention time and its quality is accordingly to the description in row E of [Table 1](#)

3.3.6

raw wastewater

wastewater (3.1.22) which has not undergone any treatment

3.3.7**thermo-tolerant coliforms**

group of bacteria whose presence in the *environment* (3.1.4) usually indicates faecal contamination (previously called faecal coliforms)

Note 1 to entry: In order to determine the quality of TWW, one can test for *Escherichia coli* (*E. coli*) or for faecal coliforms since the difference in values is not significant.

3.4 Irrigation systems**3.4.1****boom sprinkler**

mobile sprinkling machine (3.4.11) composed by two symmetrical pipes (booms) with sprinkler nozzles distributed in one of the pipes and with the sprinkler action complemented by a gun sprinkler placed at each end of both pipes; the nozzles work through a reaction effect (similar to a hydraulic tourniquet) which drives the boom rotation at a desired speed

3.4.2**center-pivot and moving lateral irrigation machines**

automated irrigation machine consisting of a number of self-propelled towers supporting a pipeline rotating around a pivot point and through which water supplied at the pivot point flows radially outward for distribution by sprayers or *sprinklers* (3.4.24) located along the pipeline

3.4.3**emitter****emitting pipe****dripper**

device fitted to an irrigation lateral and intended to discharge water in the form of drops or continuous flow at flow rates not exceeding 15 l/h, except during flushing

[ISO 16075-2:2015](https://standards.iteh.ai/catalog/standards/sist/0a85e995-9f0d-4890-b9dd-14c2ddab2d50/iso-16075-2-2015)

3.4.4**gravity flow irrigation systems**

irrigation systems (3.4.8) where water is applied directly to the *soil* (3.1.19) surface and is not under pressure

3.4.5**in-line emitter**

emitter (3.4.3) intended for installation between two lengths of pipe in an irrigation lateral

3.4.6**irrigation gun**

large discharge device being either a part circle or full circle sprinkler

3.4.7**irrigation sprayer**

device which discharges water in the form of fine jets or in a fan shape without rotational movement of its parts

3.4.8**irrigation system**

assembly of pipes, components, and devices installed in the field for the purpose of irrigating a specific area

3.4.9**micro-irrigation system**

system capable of delivering water drops, tiny-streams, or minispray to the plants

Note 1 to entry: Surface and sub-surface drip irrigation and *micro-spray irrigation* (3.4.10) are the main types of this system.

3.4.10

micro-spray irrigation systems

this system is characterized by water point sources similar to *sprinkler's* (3.4.24) miniatures (micro-sprinklers) which are placed along the laterals with a flow rate between 30 l/h and 150 l/h at pressure heads of 15 m to 25 m and the corresponding wetted area between 2 m and 6 m

3.4.11

mobile sprinkling machine

sprinkling unit which is automatically moved across the *soil* (3.1.19) surface during the water application

3.4.12

on-line emitter

emitter (3.4.3) intended for installation in the wall of an irrigation lateral either directly or indirectly by means such as tubing

3.4.13

perforating pipe system

emitting pipe (emitter/emitting pipe), continuous pipe, hose or tubing including collapsible hose with perforations intended to discharge water in the form of drops or continuous flow at emission rates not exceeding 15 l/h for each emitting unit

3.4.14

permanent system

stationary fixed-grid irrigation system (*sprinklers*) (3.4.24) for which sprinkler set positions are rigidly fixed by semi-permanent or permanently installed irrigation laterals, for example, portable solid-set irrigation system, buried irrigation system

3.4.15

portable system

system for which all or part of the network elements can be removed

3.4.16

pressurized irrigation systems

pipelined network systems under pressure

3.4.17

rotating sprinkler

device which, by its rotating motion around its vertical axis, distributes water over a circular area or part of a circular area

3.4.18

self-moved system

unit where a lateral is mounted through the centre of a series of wheels and is moved as a whole

Note 1 to entry: *Rotating sprinklers* (3.4.17)/sprayers are placed on the lateral (also called wheel move).

3.4.19

self-propelled gun traveler

gun sprinkler on a cart or sled attached to the end of flexible pipe/hose

3.4.20

semi-permanent system

similar to the *semi-portable system* (3.4.21), but with portable laterals and permanent pumping plant, main lines, and sub-mains

3.4.21

semi-portable system

similar to the *portable system* (3.4.15) except that the water source and the pumping plant are fixed