

Ballasts électroniques alimentés en courant alternatif pour lampes tubulaires à fluorescence - Prescriptions de performances

A.C.-supplied electronic ballast for tubular fluorescent lamps- Performance requirements

C O R R I G E N D U M 1

Page 2

SOMMAIRE

Correction en anglais seulement.

Page 12

Paragraphe 4.3

Au lieu de: Un seul échantillon est soumis à tous les essais.

Lire: Un seul ballast est soumis à tous les essais.

Page 14

Paragraphe 5.1b)

Au lieu de: Le symbole Z qui indique....

Lire: Le symbole \bar{Z} qui indique....

Page 24

Paragraphe 12.1, troisième alinéa

Lire: Si ces composants n'ont pas été certifiés individuellement ou ne sont pas conformes, l'appareil d'éclairage lui-même sera essayé et devra être conforme.

Page 34

Figure 2.2

Dans le graphe, au lieu de:

Temps de la transition (t_s) ≥ 100 ms

Lire:

Temps de la transition (t_s) > 100 ms

Page 3

CONTENTS

Instead of: 7 Starting operations

Read: 7 Starting conditions

Page 13

Subclause 4.3

Instead of: One sample is submitted to all tests.

Read: One ballast is submitted to all tests.

Page 15

Subclause 5.1b)

Instead of: The symbol Z which indicates....

Read: The symbol \bar{Z} which indicates....

Page 25

Subclause 12.1, third paragraph

Read: Where these components have not been approved separately or do not comply, the luminaire itself is tested and shall comply.

Page 34

Figure 2.2

In the graph, instead of:

Transition time (t_s) ≥ 100 ms

Read:

Transition time (t_s) > 100 ms