



SLOVENSKI STANDARD
SIST EN 12845:2015/oprA1:2019
01-april-2019

Vgrajene naprave za gašenje - Avtomatski sprinklerski sistemi - Projektiranje, vgradnja in vzdrževanje

Fixed firefighting systems - Automatic sprinkler systems - Design, installation and maintenance

Ortsfeste Brandbekämpfungsanlagen - Automatische Sprinkleranlagen - Planung, Installation und Instandhaltung

Installations fixes de lutte contre l'incendie - Systèmes d'extinction automatique du type sprinkleur - Conception, installation et maintenance

Ta slovenski standard je istoveten z: EN 12845:2015/prA1:2019

ICS:

13.220.10 Gašenje požara Fire-fighting

SIST EN 12845:2015/oprA1:2019 en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Full standard:
<https://standards.iteh.ai/catalog/standard/sist/3ac388fb-7a0b-4c63-88b4-71b78b749dce/sist-en-12845-2015-01-pra1-2019>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

DRAFT
EN 12845:2015/prA1

January 2019

ICS 13.220.20

English Version

Fixed firefighting systems - Automatic sprinkler systems - Design, installation and maintenance

Installations fixes de lutte contre l'incendie - Systèmes
d'extinction automatique du type sprinkleur -
Conception, installation et maintenance

Ortsfeste Brandbekämpfungsanlagen - Automatische
Sprinkleranlagen - Planung, Installation und
Instandhaltung

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 191.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents		Page
European foreword		3
1	Modification to Clause 21, Third party inspection	4
2	Addition of Annex Q, Periodic system inspection	4

ITeh STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standard/sist/3ac388fb-7-a10-4c63-88b4-71b78b749dce/sist-en-12845-2015-14pral-2019>

European foreword

This document (EN 12845:2015/prA1:2019) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

This document is currently submitted to the CEN Enquiry.

ITeh STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standard/standard/sist/3ac388fb-7-a00-4c63-88b4-71b78b749dce/sist-en-12845-2015-14pral-2019>

prEN EN 12845:2015/AC:2016 (E)

1 Modification to Clause 21, Third party inspection

Replace Clause 21 with the following: “

21 Periodic system inspection

The sprinkler system shall be periodically inspected by an expert at least once a year (see Annex Q). The inspection report shall assess whether the system is in accordance with this standard, with regard to maintenance, operation and adequacy for the risk involved. A list of deviations shall be issued for action.”.

2 Addition of Annex Q, Periodic system inspection

Add the following new Annex Q: “

Annex Q (informative)

Periodic system inspection

When performing periodic inspection, it is recommended that the system inspections are undertaken by an independent body, e.g. not the system owner, building occupier, system installer (or competing installer) or service and maintenance provider (or competing service and maintenance provider).

The expert is a designated person, suitably trained, qualified by knowledge and practical experience and with the necessary instruction to enable the test and examinations to be carried out.”.

ITeh STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standard/sis/12845-2015-12845-2015-4663-8816-7-117817-491ee/sist-en-12845-2015-12845-2015-4663-8816-7-117817-491ee>