

SLOVENSKI STANDARD oSIST prEN 50549-1:2017

01-julij-2017

Nadomešča: SIST EN 50438:2014 SIST EN 50438:2014/IS1:2015 SIST-TS CLC/TS 50549-1:2015

Zahteve za vzporedno vezavo generatorskih postrojev z javnim razdelilnim omrežjem - 1-1. del: Vezava z nizkonapetostnim razdelilnim omrežjem -Generatorski postroji do vključno tipa A

Requirements for generating plants to be connected in parallel with distribution networks - Part 1-1: Connection to a LV distribution network – Generating plants up to and including Type A

Document Preview

SIST EN 50549-1:2019

https://standards.iteh.ai/catalog/standards/sist/3b821549-e569-4b57-bcba-509fb72e841f/sist-en-50549-1-2019

Ta slovenski standard je istoveten z: prEN 50549-1

ICS:

29.160.20	Generatorji	Generators
29.240.01	Omrežja za prenos in distribucijo električne energije	Power transmission and distribution networks in
	na splošno	general

oSIST prEN 50549-1:2017

en

oSIST prEN 50549-1:2017

iTeh Standards (https://standards.iteh.ai) Document Preview

<u>SIST EN 50549-1:2019</u> https://standards.iteh.ai/catalog/standards/sist/3b821549-e569-4b57-bcba-509fb72e841f/sist-en-50549-1-201



EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

DRAFT prEN 50549-1

May 2017

ICS 29.160.20

Will supersede CLC/TS 50549-1:2015, EN 50438:2013, EN 50438:2013/IS1:2015

English Version

Requirements for generating plants to be connected in parallel with distribution networks - Part 1-1: Connection to a LV distribution network - Generating plants up to and including Type A

To be completed

To be completed

This draft European Standard is submitted to CENELEC members for enquiry. Deadline for CENELEC: 2017-08-18.

It has been drawn up by CLC/TC 8X.

If this draft becomes a European Standard, CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CENELEC in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

© 2017 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

1 Contents

2				
3	Eu	ropear	n foreword	4
4	1	Scop	e	5
5	2	Norm	native references	6
6	3	Term	is and definitions	6
7		3.1	General	6
8		3.2	Plant, module and unit	7
9		3.3	Power	9
10		3.4	Voltage	9
11		3.5	Circuit theory	10
12		3.6	Protection	12
13		3.7	Control	16
14	4	Requ	lirements on generating plants	18
15		4.1	General	18
16		4.2	Connection scheme	18
1/		4.3	Choice of switchgear	19
18		4.4	Normal operating range	19
19 20		4.5 1.6	Active response to frequency deviation	21 24
20		4.0	Power response to voltage variations and voltage changes	24 20
22		4.8	FMC and power quality SIST EN 50549-1-2019	20
123:		4.9 s	Interface protection	<u>50534-1-</u>
24		4.10	Connection and starting to generate electrical power	39
25		4.11	Ceasing and reduction of active power on set point	40
26 27		4.12	Requirements regarding single fault tolerance of interface protection system and interface switch	40
28	An	nex A	(informative) Interconnection requirements	41
29	Α.	1 Gene	eral	41
30	A.2	2 Netw	ork integration	41
31	Α.3	3 Clust	ters of single-phase generating units	42
32	An	nex B	(informative) Parameter Table	43
33	An	nex C	(informative) List of national requirements applicable for Generating plants	46
34	An	nex D	(informative) Loss of Mains and overall power system security	47
35	An	nex F	(informative) Examples of protection strategies	48
36	F	1 Intro		48
37	с. с	1 1	General	
20	с. с.	1.1	Concratition	0+ ۸۵
20	с. г.	1.2 1.2	Detection of unwanted islands	40
39	E.'	1.3	Detection of unwanted islands	48
40	E.'	1.4	Problems with uncontrolled Islanding in MV networks	49
41	E.2	2 Exan	nple strategy 1	50
42	Е.3	3 Exan	nple strategy 2	53

43	Annex F (normative) Abbreviations	55
44 45	Annex G (informative) Relationship between this European standard and the COMISSION REGULATION (EU)2016/631	56
46	Bibliography	57
47		

- 48
- 49

iTeh Standards (https://standards.iteh.ai) Document Preview

SIST EN 50549-1:2019

https://standards.iteh.ai/catalog/standards/sist/3b821549-e569-4b57-bcba-509fb72e841f/sist-en-50549-1-2019

50 European foreword

- 51 This document (prEN 50549-1:2017) has been prepared by CLC/TC 8X "System aspects of electrical 52 energy supply".
- 53 This document is currently submitted to the Enquiry.
- 54 The following dates are proposed:

•	latest date by which the existence of this document has to be announced at national level	(doa)	dor + 6 months
•	latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement	(dop)	dor + 12 months
•	latest date by which the national standards conflicting with this document have to be withdrawn	(dow)	dor + 36 months (to be confirmed or modified when voting)

- 55 This document will supersede EN 50438:2013 and CLC/TS 50549-1:2015.
- 56 This document has been prepared under a mandate given to CENELEC by the European Commission
- 57 and the European Free Trade Association.
- 58 Please note: TC8X/Sec0155/RM the unconfirmed minutes of the 14th TC8X meeting held in Brussels

59 on 2016-11-23 it specified in decision 6 the requirement to prepare documents for enquiry according

to BT155/DG10265/DV. However during the drafting of this document it became apparent that the

61 difference between the planned <u>-1-1</u> and <u>-1-2</u> would be so small that it will be more practical for all

62 parties to combine the two documents into one EN 50549-1.

<u>SIST EN 50549-1:2019</u>

- 63 // This approach is proposed during the enquiry stage of EN 50549-1. NCs are invited to comment on 1-2019
 64 this approach. If NCs agree, WG03 proposes to publish EN 50549-1 as presented for comment in this
 65 document.
- 66 This European Standard relates to both European Network Codes and current technical market needs.
- 67 Its purpose is to give detailed description of functions to be implemented in products.

This European Standard is also intended to serve as a technical reference for the definition of national requirements where European Network Codes requirements allow flexible implementation. The

- specified requirements are solely technical requirements; economic issues for example. The bearing
 of cost are not in the scope of this document.
- 72 CLC/TC 8X plans future standardization work in order to ensure the compatibility of this European 73 Standard (EN) with the evolution of the legal framework.

74 **1 Scope**

This European Standard specifies the technical requirements for the protection functions and the operational capabilities for generating plants, intended to operate in parallel with LV distribution networks.

For practical reasons, this European Standard refers to the relevant distribution system operator where settings have to be defined and/or provided, even when these settings are to be defined and/or provided by another actor e.g. TSO, Member state, regulatory authorities, according to national and European legal framework.

- NOTE 1 This includes European network codes and their national implementation, as well as additional national
 regulations.
- 84 NOTE 2 Additional national requirements especially for the connection to the distribution network and the 85 operation of the generating plant may apply.
- The requirements of this European Standard apply to all generating plants, generating modules, electrical machinery and electronic equipment, irrespective of the kind of primary energy source and irrespective of the presence of loads in the producer's network that meet all of the following conditions:
- converting any primary energy source into AC electricity;
- 90 connected to a LV distribution network;
- generating modules capacity of Type B or smaller;
- 92 intended to operate in parallel with a distribution network.
- If generating modules of different type are combined in one plant, different requirements apply for the
 different modules based on the type of each module.
- 95 NOTE 3 Generating plants connected to a MV distribution network fall into the scope of EN 50549–2.
- 96 Unless specified otherwise by the DSO, generating plants connected to a medium voltage distribution
 97 / network with a maximum apparent power up to 100 kVA can comply with this European Standard as 1-2019
 98 alternative to the requirements of EN 50549-2. A different threshold may be defined by the DSO.
- 99 This European Standard defines connection requirements for generating plants to be connected in 100 parallel with distribution networks.
- 101 This European Standard recognizes the existence of National Standards, Network Codes, and specific 102 technical requirements of the DSOs and these should be complied with.
- 103 Excluded from the scope are:
- the selection and evaluation of the point of connection;
- 105 power system impact assessment;
- 106 connection assessment;
- island operation of generating plants, both intentional and unintentional, where no part of the distribution network is involved;
- four-quadrant rectifier of drives feeding breaking energy back into the distribution network for
 limited duration with no internal source of primary energy;
- uninterruptible power supply with duration of parallel operation limited to 100 ms;
- 112 NOTE 4 Parallel operation due to maintenance of uninterruptible power supply units is not considered.

requirements for the safety of personnel as they are already adequately covered by existing
 European Standards.

115 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

119 EN 60255-127, Measuring relays and protection equipment — Part 127: Functional requirements for 120 over/under voltage protection (IEC 60255-127)

121 EN 61000-4-30, Electromagnetic compatibility (EMC) — Part 4-30: Testing and measurement 122 techniques — Power quality measurement methods (IEC 61000-4-30)

HD 60364-1, Low-voltage electrical installations — Part 1: Fundamental principles, assessment of general characteristics, definitions (IEC 60364-1)

HD 60364-5-551, Low-voltage electrical installations — Part 5-55: Selection and erection of electrical
 equipment — Other equipment — Clause 551: Low-voltage generating sets (IEC 60364-5-551)

127 **3 Terms and definitions**

128 For the purposes of this document, the following terms and definitions apply.

129 3.1 General

130 **3.1.1**

131 distribution network

- 132 electrical network, including closed distribution networks, for the distribution of electrical power from
- 133 and to third parties connected to it, to and from a transmission or another distribution network, for
- 134 which a DSO is responsible

SIST EN 50549-1:2019

135 // **3.1.2** // **3.1**

- 137 system which distributes electricity within a geographically confined, industrial, commercial or shared
- 138 services site and does not (without prejudice to a small number of households located within the area
- served by the system and with employment or similar associations with the owner of the system)
- 140 supply households customers
- Note 1 to entry: This Closed Distribution Network will either have its operations or the production process of the users of the system integrated for specific or technical reasons or distribute electricity primarily to the owner or
- 143 operator of the Closed Distribution Network or their related undertakings.

144 **3.1.3**

145 distribution system operator - DSO

- 146 natural or legal person responsible for the distribution of electrical power to the public and for 147 operating, ensuring the maintenance of and, if necessary, developing the distribution network in a 148 given area
- 149 Note 1 to entry: In this document applicable to distribution grids DSO is used for relevant system operator 150 according Article 2 (13) of COMISSION REGULATION 2016/631.
- 151 Note 2 to entry: In some countries, the distribution network operator (DNO) fulfils the role of the DSO.

152 **3.1.4**

153 transmission system operator - TSO

natural or legal person responsible for operating, ensuring the maintenance of and, if necessary, developing the transmission system in a given area and, where applicable, its interconnections with

- 156 other power systems, and for ensuring the long-term ability of the power system to meet reasonable
- 157 demands for the transmission of electricity

158 3.1.5

low voltage (LV) distribution network 159

160 electric distribution network with a voltage whose nominal r.m.s. value is Un \leq 1 kV

161 3.1.6

162 power system stability

capability of a power system to regain a steady state, characterized by the synchronous operation of 163 164 the generating plants after a disturbance

[SOURCE: IEV 603-03-01] 165

166 3.1.7

- producer 167
- 168 natural or legal person who already has or is planning to connect an electricity generating plant to a 169 distribution network

3.1.8 170

producer's network 171

- electrical installations downstream from the point of connection owned/operated by the producer for 172
- internal distribution of electricity 173

174 3.1.9

downstream 175

- direction in which the active power would flow if no generating units, connected to the distribution 176
- 177 network, were running

178 3.1.10

- point of connection POC TOS://standards.iteh.ai 179
- 180 reference point on the electric power system where the user's electrical facility is connected
- 181 Note 1 to entry: For the purpose of this standard, the electric power system is the distribution network.

[SOURCE: IEV 617-04-01 modified] SIST EN 50549-1:2019 182

- 183 3.1.11

operating in parallel with the distribution network 184

situation where the generating plant is connected to a distribution network and operating 185

186 3.1.12

temporary operation in parallel with the distribution network 187

- conditions in which the generating plant is connected to a distribution network, during defined short 188
- 189 periods, to maintain the continuity of the supply voltage and to facilitate testing

190 3.2 Plant, module and unit

191 3.2.1

192 generating module

- either a generating unit of synchronous generating technology or the sum of all generating units of 193
- 194 non-synchronous generating technology connected to a common point of connection including all
- elements needed to feed electric power to the distribution grid 195



226 Note 1 to entry: Examples are: induction machines and converter based technologies.

227 3.2.8

228 cogeneration - combined heat and power (CHP)

229 combined generation of electricity and heat by an energy conversion system and the concurrent use of 230 the electric and thermal energy from the conversion system

231 3.3 Power

232 3.3.1

233 design active power - P_D

234 maximum AC active power output at an active factor of 0,9 or the active factor specified by the DSO 235 for a certain generating plant or generating technology

236 3.3.2

237 maximum active power - Pmax

- 238 maximum continuous active power which a power-generating plant can produce, less any demand associated solely with facilitating the operation of that power-generating plant and not fed into the 239 240 network as specified in the connection agreement or as agreed between the DSO and the power-
- 241 generating facility owner
- 242 Note 1 to entry: This maximum power is defined by a measurement with 10 min averaging.
- 243 3.3.3

244 rated current

maximum continuous AC output current which a generating unit or generating plant is designed to 245 246 achieve under normal operating conditions

247 [SOURCE: IEV 415-04-03, modified]

248 3.3.4

- 249 maximum apparent power - Smax provide Provide M
- maximum AC apparent power output that the generating unit or the sum of all the generating units in a 250
- 251 generating plant is designed to achieve under normal operating conditions

Note 1 to entry: This maximum power is defined by a measurement with 10 min averaging. 252

253 3.3.5

254 momentary active power - P_M

255 actual AC active power output at a certain instant

256 3.3.6

257 primary energy source

258 non-electric energy source supplying an electric generating unit

259 Note 1 to entry: Examples of primary energy sources include natural gas, wind and solar energy. These sources 260 can be utilized, e.g. by gas turbines, wind turbines and photovoltaic cells.

261 3.3.7

- 262 available active power - PA
- maximum AC active power available from the prime mover subject to the availability and magnitude of 263 264 the primary energy source at the relevant time
- 265 Note 1 to entry: The maximum active power considers all constraints regarding e.g. the primary energy source or 266 the availability of a heat sink for CHP.

267 3.4 Voltage

268 3.4.1

nominal voltage - Un 269

270 voltage by which a supply network is designated or identified and to which certain operating 271 characteristics are referred

272 273 274	3.4.2 nominal frequency - fn frequency used to designate and identify equipment or a power system
275	Note 1 to entry: For the purpose of this standard, the nominal frequency f_n is 50 Hz.
276	[SOURCE: IEV 151-16-09, modified]
277 278 279 280	3.4.3 reference voltage value specified as the base on which residual voltage, thresholds and other values are expressed in per unit or percentage terms
281 282	Note 1 to entry: For the purpose of this standard, the reference voltage is the nominal voltage or the declared voltage of the distribution network.
283	[SOURCE: EN 50160:2010, 3.18, modified]
284 285 286 287	3.4.4 voltage change variation of the r.m.s. value of a voltage between two consecutive levels sustained for definite but unspecified durations
288	[SOURCE: IEV 161-08-01, modified]
289 290 291	3.4.5 voltage variation increase or decrease of r.m.s. voltage normally due to load variations in load and/or generation
292	[SOURCE: EN 50160:2010, 3.34, modified]
293	3.5 Circuit theory
294 295 296 297	3.5.1 active factor for a two-terminal element or a two-terminal circuit under sinusoidal conditions, ratio of the active power to the apparent power
298	Note 1 to entry: In a three phase system, this is referring to the positive sequence component of the fundamental.
299	Note 2 to entry: The active factor is equal to the cosine of the displacement angle.
300	[SOURCE: IEV 131-11-49, modified]
301 302 303 304	3.5.2 displacement angle - ϕ under sinusoidal conditions, phase difference between the voltage applied to a linear two-terminal element or two-terminal circuit and the electric current in the element or circuit
305	Note 1 to entry: In a three phase system, this is referring to the positive sequence component of the fundamental.
306	Note 2 to entry: The cosine of the displacement angle is the active factor.
307	[SOURCE: IEV 131-11-48, modified]

- 308 **3.5.3**
- 309 power factor
- 310 under periodic conditions, ratio of the absolute value of the active power P to the apparent power S:

$$\lambda = \frac{|P|}{S}$$

- 312 Note 1 to entry: Under sinusoidal conditions, the power factor is the absolute value of the active factor.
- 313 [SOURCE: IEV 131-11-46]
- 314 **3.5.4**

311

315 fundamental components of a three-phase system

- 316 **3.5.4.1**
- 317 phasor
- representation of a sinusoidal integral quantity by a complex quantity whose argument is equal to the
- 319 initial phase and whose modulus is equal to the root-mean-square value
- 320 Note 1 to entry: For a quantity $a(t) = A \sqrt{2} \cos(\omega t + \Theta_0)$ the phasor is A exp j Θ_0 .
- 321 Note 2 to entry: The similar representation with the modulus equal to the amplitude is called "amplitude phasor".
- 322 Note 3 to entry: A phasor can also be represented graphically.
- 323 [SOURCE: IEV 131-11-26, modified] en Standards
- 324 **3.5.4.2**

325 positive sequence component of the fundamental

- 326 for a three-phase system with phases L1, L2 and L3, the symmetrical sinusoidal three-phase set of
- 327 voltages or currents having frequency equal to the fundamental frequency and which is defined by the
- 328 following complex mathematical expression:

https://stand $\underline{X}_{1} = \frac{1}{3} \left(\underline{X}_{L1} + \underline{a} \underline{X}_{L2} + \underline{a}^{2} \underline{X}_{L3} \right)$ st/3b821549-e569-4b57-bcba-509fb72e841f/sist-en-50549-1-2019

- 330 where
- 331 <u>a</u> = $e^{j2\pi/3}$ is the 120 degree operator,
- X_{L1} , X_{L2} and X_{L3} are the complex expressions of the fundamental frequency phase quantities concerned, that is, current or voltage phasors
- Note 1 to entry: In a balanced harmonic-free system, only positive sequence component of the fundamental exists. For example, if phase voltage phasors are symmetrical $\underline{U}_{L1} = Ue^{j\theta}$, $\underline{U}_{L2} = Ue^{j(\theta+4}\pi^{/3})$ and $\underline{U}_{L3} = Ue^{j(\theta+2}\pi^{/3})$ then $\underline{U}_1 = (Ue^{j\theta} + e^{j2}\pi^{/3} Ue^{j(\theta+4}\pi^{/3}) + e^{j4}\pi^{/3} Ue^{j(\theta+2}\pi^{/3}))/3 = (Ue^{j\theta} + Ue^{j\theta})/3 = Ue^{j\theta}$
- 337 [SOURCE: IEV 448-11-27]
- 338 **3.5.4.3**

339 negative sequence component of the fundamental

for a three-phase system with phases L1, L2 and L3, the symmetrical sinusoidal three-phase set of voltages or currents having frequency equal to the fundamental frequency and which is defined by the following complex mathematical expression:

$$\underline{X}_{2} = \frac{1}{3} \left(\underline{X}_{L1} + \underline{a}^{2} \underline{X}_{L2} + \underline{a} \underline{X}_{L3} \right)$$

343

344 where

345 <u>a</u> = $e^{j2\pi/3}$ is the 120 degree operator

 X_{L1} , X_{L2} and X_{L3} are the complex expressions of the fundamental frequency phase quantities concerned, that is, current or voltage phasors

Note 1 to entry: Negative sequence voltage or current components may be significant only when the voltages or currents, respectively, are unbalanced. For example, if phase voltage phasors are symmetrical $\underline{U}_{L1} = Ue^{j\theta}$, $\underline{U}_{L2} = Ue^{j(\theta+4}\pi^{/3})$ and $\underline{U}_{L3} = Ue^{j(\theta+2}\pi^{/3})$ then the negative sequence component $\underline{U}_2 = (Ue^{j\theta} + e^{j4}\pi^{/3} Ue^{j(\theta+4}\pi^{/3}) + e^{j2}\pi^{/3})$ $Ue^{j(\theta+2}\pi^{/3})/3 = Ue^{j\theta} (1 + e^{j2}\pi^{/3} + e^{j4}\pi^{/3})/3 = 0$.

352 [SOURCE: IEV 448-11-28]

353 **3.5.4.4**

354 zero sequence component of the fundamental

for a three-phase system with phases L1, L2 and L3, the in-phase sinusoidal voltage or current component having the fundamental frequency and equal amplitude in each of the phases and which is defined by the following complex mathematical expression:

$$\underline{X}_{0} = \frac{1}{3} \left(\underline{X}_{L1} + \underline{X}_{L2} + \underline{X}_{L3} \right)$$

359 where

358

- 360 X_{L1}, X_{L2} and X_{L3} are the complex expressions of the fundamental frequency phase quantities 361 concerned, that is, current or voltage phasors **C to make and C**
- 362 [SOURCE: IEV 448-11-29] (https://standards.iteh.ai)
- 363 **3.6 Protection**

364 **3.6.1**

365 protection system

arrangement of one or more protection equipments, and other devices intended to perform one or
 more specified protection functions

368 Note 1 to entry: A protection system includes one or more protection equipments, instrument transformer(s),

wiring, tripping circuit(s), auxiliary supply(s) and, where provided, communication system(s). Depending upon the
 principle(s) of the protection system, it may include one end or all ends of the protected section and, possibly,
 automatic reclosing equipment.

- 372 Note 2 to entry: The circuit-breaker(s) are excluded.
- 373 [SOURCE: IEV 448-11-03]