

SLOVENSKI STANDARD
oSIST prEN 50491-12-1:2017
01-november-2017

Splošne zahteve za stanovanjske in stavbne elektronske sisteme (HBES) in sisteme za nadzor in avtomatizacijo stavb (BACS) - Pametna omrežja - Aplikacijske specifikacije - Vmesnik in okvir za odjemalca - 12-1. del: Vmesnik med CEM in upravljalcem stanovanjskih in stavbnih virov - Splošne zahteve in arhitektura

General requirements for Home and Building Electronic Systems (HBES) and Building Automation and Control Systems (BACS) - Smart grid - Application specification - Interface and framework for customer - Part 12-1: Interface between the CEM and Home/Building Resource manager - General Requirements and Architecture

<https://standards.iteh.ai>
Document Preview

Exigences générales relatives aux systèmes électroniques pour les foyers domestiques et les bâtiments (HBES) et aux systèmes de gestion technique du bâtiment (SGTB) □ Réseau intelligent □ Spécification d'application □ Interface et cadre pour le client - Partie 12-1 : Interface entre le gestionnaire d'énergie pour le client (CEM, Customer Energy Manager) et le gestionnaire de ressources pour foyers domestiques/ bâtiments. Exigences et Architecture générales

Ta slovenski standard je istoveten z: prEN 50491-12-1

ICS:

35.240.67	Uporabniške rešitve IT v gradbeništvu	IT applications in building and construction industry
97.120	Avtomatske krmilne naprave za dom	Automatic controls for household use

oSIST prEN 50491-12-1:2017

en,fr

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

DRAFT
prEN 50491-12-1

September 2017

ICS 97.120

English Version

**General requirements for Home and Building Electronic Systems (HBES)
and Building Automation and Control Systems (BACS) - Smart grid -
Application specification - Interface and framework for customer - Part 12-1:
Interface between the CEM and Home/Building Resource manager -
General Requirements and Architecture**

Exigences générales relatives aux systèmes électroniques pour les foyers domestiques et les bâtiments (HBES) et aux systèmes de gestion technique du bâtiment (SGTB) - Réseau intelligent - Spécification d'application - Interface et cadre pour le client - Partie 12-1 : Interface entre le gestionnaire d'énergie pour le client (CEM, Customer Energy Manager) et le gestionnaire de ressources pour foyers domestiques/ bâtiments. Exigences et Architecture générales

This draft European Standard is submitted to CENELEC members for enquiry.
Deadline for CENELEC: 2017-11-24.

It has been drawn up by CLC/TC 205.

If this draft becomes a European Standard, CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CENELEC in three official versions (English, French, German).
A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

1		
2	European foreword	3
3	Introduction	4
4	1 Scope.....	5
5	2 Normative references	5
6	3 Terms, definitions and abbreviations.....	5
7	3.1 Terms and definitions	5
8	3.2 Abbreviations	7
9	4 Design considerations	8
10	4.1 General	8
11	4.2 Data security /privacy	8
12	4.3 Device type agnostic energy management	8
13	4.4 Clock alignment	8
14	5 Background.....	9
15	6 Smart Grid premises side Architecture.....	12
16	6.1 General	12
17	6.2 Smart Grid Connection Point (SGCP)	14
18	6.3 Energy Management Gateway (EMG)	14
19	6.4 Interface S1.....	14
20	6.5 Customer Energy Manager (CEM)	15
21	6.6 Interface S2.....	16
22	6.7 Resource manager	16
23	6.8 HBES	17
24	7 User Stories and Use Cases	17
25	7.1 Requirements for interoperability.....	17
26	7.2 Determining the requirements for Interface S2.....	17
27	7.3 Extensibility of S2 Requirements	18
28	Annex A (informative) Use Case example.....	19
29	Bibliography	22
30		

31 European foreword

32 This document (prEN 50491-12-1:2017) has been prepared by the Technical Committee CLC/TC 205, "Home
33 and Building Electronic Systems (HBES)".

34 This document is currently submitted to the Enquiry.

35 The following dates are proposed:

- latest date by which the existence of this document has to be announced at national level (doa) dor + 6 months
- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) dor + 12 months
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) dor + 36 months (to be confirmed or modified when voting)

36 EN 50491-12 is part of the EN 50491 series of European Standards - General requirements for Home and
37 Building Electronic Systems (HBES) and Building Automation and Control Systems (BACS) - which will
38 comprise the following parts:

- 39 — Part 1: General requirements;
- 40 — Part 2: Environmental Conditions;
- 41 — Part 3: Electrical Safety Requirements;
- 42 — Part 4-1: General functional safety requirements for products intended to be integrated in Building
43 Electronic Systems (HBES) and Building Automation and Control Systems (BACS);
- 44 — Part 5-1: EMC requirements, conditions and test set-up;
- 45 — Part 5-2: EMC requirements for HBES/BACS used in residential, commercial and light industry
46 environment;
- 47 — Part 5-3: EMC requirements for HBES/BACS used in industry environment
- 48 — Part 6-1: HBES installations - Installation and planning;
- 49 — Part 6-3: HBES installations - Assessment and definition of levels;
- 50 — Part 11: Smart Metering – Application Specification – Simple External Consumer Display;
- 51 — Part 12: Smart grid - Application specification - Interface and framework for customer;
- 52 — Part 12-1: Interface between the CEM and Home/Building Resource manager– General Requirements and
53 Architecture
- 54 — Future Part 12-2: Interface between the Home/Building CEM and Resource manager(s)– Data model and
55 messaging
- 56 — Future Part 12-3: Home/Building Customer Energy Manager (CEM)
- 57 — Future Part 12-4: Resource manager

58 Introduction

59 Traditional electricity networks make use of a primarily one-way flow of energy and communication from the
60 generator to the consumer via the transmission and distribution systems.

61 Although there is some monitoring and control of equipment in the transmission and distribution systems, there
62 is no communication with, or control of, consumer equipment. In particular, there is no means of requesting
63 short-term control of consumer equipment according to generation and/or transmission/distribution grid
64 conditions. Generation equipment is controlled according to the open-ended (uncontrolled) demand of the
65 consumer.

66 Today we are faced with an increase of power consumption, this is directly connected to an increase of CO²
67 production. The increased CO² density in the atmosphere supports the climate warming of the earth.

68 One significant way to cope with the increased energy consumption without increasing the CO² production is to
69 use more renewable energy resources.

70 Unfortunately, the available renewable energy supply is not aligned with the energy demand. To increase the
71 efficiency, the energy demand should be aligned as much as possible with the available energy supply. To
72 reach this goal communication between the various equipment and systems of the stakeholders within the
73 energy field is necessary. This grid, exchanging information and energy between producers, consumers,
74 distributors and metering is known as the "Smart Grid".

75 The EN 50491-12 series describes aspects of this smart grid that relate specifically to the premises
76 (home/building) part of the smart grid, including the common interface between equipment in the premises and
77 the smart grid is described.

iTeh Standards (<https://standards.iteh.ai>) Document Preview

[SIST EN 50491-12-1:2018](https://standards.iteh.ai/catalog/standards/sist/ecefb887-c294-4b73-b602-79331891a1f5/sist-en-50491-12-1-2018)

<https://standards.iteh.ai/catalog/standards/sist/ecefb887-c294-4b73-b602-79331891a1f5/sist-en-50491-12-1-2018>

78 1 Scope

79 This European Standard specifies General Requirements and Architecture of an application layer interface
80 between the Customer Energy Manager (CEM) and Smart Devices (SD) operating within the smart grid
81 premises side system (i.e. home or building but not industrial premises).

82 This standard does not include:

- 83 – Safety;
- 84 – EMC;
- 85 – Data Security; it is assumed that the underlying protocols will take the Data Security aspect into account;
- 86 – Special equipment (e.g. legacy heat pumps) with a direct physical connection to the grid, as such equipment
87 bypasses the CEM and is not HBES/BACS enabled (covered by other standards than the
88 EN 50491 series).

89 2 Normative references

90 The following documents are referred to in the text in such a way that some or all of their content constitutes
91 requirements of this document. For dated references, only the edition cited applies. For undated references, the
92 latest edition of the referenced document (including any amendments) applies.

93 EN 50491-12 (all parts), *General requirements for Home and Building Electronic Systems (HBES) and Building
94 Automation and Control Systems*

95 3 Terms, definitions and abbreviations

96 3.1 Terms and definitions

97 For the purposes of this document, the following terms and definitions apply:

98 3.1.1

99 **Customer Energy Manager**

100 **CEM**

101 internal automation function for optimizing the energy consumption and/or production within the premises
102 according to the preferences of the customer using internal flexibilities and typically based on external
103 information received through the Smart Grid Connection Point and possibly other data sources

104 3.1.2

105 **Customer Energy Manager System**

106 CEM system which allows to manage the energy consumption and or production within the premises, consists
107 of a CEM and attached Resource Manager which connects the HBES / BACS and / or Smart Appliances to the
108 CEM

109 3.1.3

110 **Energy Management Gateway**

111 **EMG**

112 access point (functional entity) sending and receiving smart grid related information and commands between
113 an actor in the Grid and the CEM, letting the CEM decide how to process the events

114 Note 1 to entry: The communication is often ensured through an internet connection.

115 3.1.4

116 **Head End System**

117 **HES**

118 system that receives metering data in the advanced metering infrastructure

prEN 50491-12-1:2017 (E)

119 **3.1.5**
 120 **Home and Building Electronic Systems / Building Automation Control System**
 121 **HBES / BACS**
 122 logical group of devices which uses a multi-application communication system where the functions are
 123 distributed and linked through a common communication process

124 Note 1 to entry: HBES/BACS is used in homes and buildings plus their surroundings. Functions of the system are e.g.:
 125 switching, open loop controlling, closed loop controlling, monitoring and supervising.

126 Note 2 to entry: In literature, HBES/BACS may be referred also as “home control system/network“, „home electronic
 127 systems“ “home automation systems” etc.

128 Note 3 to entry: Examples of HBES/BACS applications are the management, of lighting, heating, energy water, fire alarms,
 129 blinds, different forms of security, etc.”. See introduction in EN 50491–4-1.

130 **3.1.6**
 131 **Schema**
 132 abstract model that documents and organizes the data required in a defined way, so it can be used for different
 133 purposes such as exchanging and or storing information

134 **3.1.7**
 135 **Local Network Access Point**
 136 **LNAP**
 137 specific Network Interface controller between the Local Network (within the premises) and a system acting as
 138 back-end for the metering communication, which controls and monitors the communication to the Tx meter
 139 (Instrument for measuring, memorizing data related to the consumption of commodity)

140 **3.1.8**
 141 **Meter Data management**
 142 **MDM**
 143 software system that performs long-term data storage and management for the vast quantities of data delivered
 144 by smart metering systems

145 **3.1.9**
 146 **Resource Manager**
 147 software component that exclusively represents a logical group of devices or a single smart device, and is
 148 responsible for sending unambiguous instruction to the logical group of devices or to single device, typically
 149 using a device-specific protocol

150 Note 1 to entry: In the context of this document the Resource Manager manages the energy flexibility of a logical group of
 151 devices or a single smart device.

152 Note 2 to entry: The Resource Manager may be implemented in a special device, in the smart device itself or outside of
 153 the device

154 **3.1.10**
 155 **Neighborhood Network Access Point**
 156 **NNAP**
 157 specialized Network Interface Controller between the Neighbourhoods Network and Wide Area Network (WAN)

158 **3.1.11**
 159 **premises**
 160 can be a public or private building/home where energy is used and/or produced

161 **3.1.12**
 162 **Smart Appliances**
 163 device that consumes energy that can be controlled by a Resource Manager. Smart Appliance can be a washing
 164 machine, a freezer

165 **3.1.13**
 166 **Smart Device**
 167 **SD**
 168 device that can consume, produce or store energy (or a combination thereof) and that can be controlled by a
 169 Resource Manager for the purpose of energy management. Smart Devices can be Electrical Vehicles, Smart
 170 Appliances, renewable Power sources

171 **3.1.14**
 172 **Smart Grid Connection Point**
 173 **SGCP**
 174 physical and logical borderline / interface from the customer to the network/market or from the network/market
 175 to the customer, considering generation, storage or demand

176 Note 1 to entry: The SGCP can be implemented by one or more separate interfaces.

177 **3.1.15**
 178 **Smart meter gateway**
 179 **SMG**
 180 interface between the premises and the metering network

181 Note 1 to entry: The SMG may have three interfaces, one to the HAN (Home Area Network), one to the LMN (Local
 182 Metrological Network) which is the interface to the different meter and one interface to the WAN (Wide Area Network).

183 Note 2 to entry: The smart meter gateway can be a part of the meter.

184 **3.2 Abbreviations**

BACS	Building Automation Control Systems
CEM	Customer Energy Manager
CHP	Combined Heat and Power
DER	Distributed Energy Resources
EMG	Energy Management Gateway
H1	Local connection to simple external consumer display
H2	Connection between the SMG and EMG)
HES	Head End System
HBES	Home and Building Electronic System
LNAP	Local Network Access Point
MDM	Meter Data Management
MCF	Meter Communication Function
NNAP	Neighbourhood Network Access Point
SD	Smart Device
SGCG	Smart Grid Co-ordination Group, reporting to CEN-CENELEC-ETSI and in charge of answering the M/490 mandate
SGCP	Smart Grid Connection Point
SMG	Smart Meter Gateway
S1	Interface between Energy management gateway and CEM
S2	Interface between CEM and Resource Manager

185 4 Design considerations

186 4.1 General

187 For designing a system like the Smart Grid, some general design considerations have to be taken into account.
188 One important requirement for the Smart Grid is the data security and data privacy.

189 4.2 Data security /privacy

190 4.2.1 General

191 Data security and privacy should protect the system and keep the data as much as possible private.

192 The data security / privacy shall be distinguished between the data security / privacy related to the smart Grid
193 and the Data security / privacy within the Smart grid premises side.

194 4.2.2 Data security / privacy on the smart grid side

195 It should be not possible to attack and impair the data. The data privacy can be reached by exchanging only
196 aggregated, energy management related data and / or data where the customer has given the permission to
197 use the data by a second person

198 4.2.3 Data security / privacy on premises side

199 Data security / privacy on the premises side shall guarantee that the data can only read by authorized persons
200 and cannot be manipulated. Depending on the implementation of the system this can be reached with different
201 methods:

- 202 – Data encryption and decryption;
- 203 – Constructive design (avoid that anyone except authorized persons can get access to the devices and
204 communication channel).

205 4.2.4 Customer Energy Management System security

206 The security of the Customer Energy Manager System (CEMS) is linked to the number of connections between
207 the CEMS and the Neighbourhood Network. Every connection between the CEMS and the Neighbourhood
208 Network shall contain a Firewall to avoid non authorized access to the CEMS. The more connections are
209 between the two networks the more effort shall be spent for configuring of the different Firewalls and the higher
210 is the risk of security holes. Therefore, it is recommended to limit the connection points between the CEMS and
211 the Neighbourhood Network as much as possible. Ideally there is only one connection between the CEMS and
212 the Neighbourhood Network.

213 4.3 Device type agnostic energy management

214 While today there is a set of common devices and appliances (e.g. freezers, TV sets, electric bikes, ...), the
215 data structures of the CEM interface S2 should be designed in such a way that even future device types, which
216 currently are unknown (e.g. micro power-to-methanol reactors, fridge-freezer- air conditioners, ...), can be
217 correctly managed without the need to update the communication standard.

218 4.4 Clock alignment

219 The main task for a CEM is to manage energy, which basically are variations of (average) power over time. One
220 of the key CEM data structures is therefore a power profile and it makes "time" a central and very important
221 aspect.

222 "Time" seems like a trivial concept. Humans tend to think of "absolute" time in the form of a "date" plus a "24-
223 hour clock" information. But on a technical level it is not that trivial at all, because there are aspects like time
224 zones, different calendars, daylight saving time, leap seconds, hardware clock drift and the overall question of
225 how to actually synchronize multiple clocks to a desired type and precision of alignment.