



SLOVENSKI STANDARD SIST EN IEC 62932-1:2021

01-februar-2021

Energijski sistemi pretočnih baterij za vgrajeno opremo - 1. del: Terminologija in splošni vidiki

Flow battery energy systems for stationary applications - Part 1: Terminology and general aspects

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Ta slovenski standard je istoveten z: EN IEC 62932-1:2020
<https://standards.iteh.ai/catalog/standards/sist/c65e58fb-f8d1-422f-a4e2-ae22de156b8e/sist-en-iec-62932-1-2021>

ICS:

29.220.99

Drugi členi in baterije

Other cells and batteries

SIST EN IEC 62932-1:2021

en

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

SIST EN IEC 62932-1:2021

<https://standards.iteh.ai/catalog/standards/sist/c65e58fb-f8d1-422f-a4e2-ac22de156b8e/sist-en-iec-62932-1-2021>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN IEC 62932-1

April 2020

ICS 29.220.99

English Version

**Flow battery energy systems for stationary applications - Part 1:
Terminology and general aspects
(IEC 62932-1:2020)**

Systèmes de production d'énergie de batteries
d'accumulateurs à circulation d'électrolyte pour applications
stationnaires - Partie 1: Terminologie et aspects généraux
(IEC 62932-1:2020)

Flussbatterie-Energiesysteme für stationäre Anwendungen
- Teil 1: Terminologie und allgemeine Aspekte
(IEC 62932-1:2020)

This European Standard was approved by CENELEC on 2020-03-24. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

SIST EN IEC 62932-1:2021

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN IEC 62932-1:2020 (E)**European foreword**

The text of document 21/1027/FDIS, future edition 1 of IEC 62932-1, prepared by IEC/TC 21 "Secondary cells and batteries" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62932-1:2020.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2020-12-24
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2023-03-24

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

iTeh STANDARD PREVIEW
Endorsement notice
(standards.iteh.ai)

The text of the International Standard IEC 62932-1:2020 was approved by CENELEC as a European Standard without any modification.



IEC 62932-1

Edition 1.0 2020-02

INTERNATIONAL STANDARD



**Flow battery energy systems for stationary applications –
Part 1: Terminology and general aspects**

ITeH STANDARD PREVIEW
(standards.iteh.ai)
SIST EN IEC 62932-1:2021
<https://standards.iteh.ai/catalog/standards/sist/c65e58fb-f8d1-422f-a4e2-ae22de156b8e/sist-en-iec-62932-1-2021>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.220.99

ISBN 978-2-8322-7852-9

Warning! Make sure that you obtained this publication from an authorized distributor.

IEC 62932-1:2020 © IEC 2020

INTERNATIONAL ELECTROTECHNICAL COMMISSION

FLOW BATTERY ENERGY SYSTEMS FOR STATIONARY APPLICATIONS –**Part 1: Terminology and general aspects****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62932-1 has been prepared by IEC technical committee 21: Secondary cells and batteries, in collaboration with IEC technical committee 105: Fuel cell technologies.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
21/1027/FDIS	21/1037/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62932 series, published under the general title *Flow battery energy systems for stationary applications*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN IEC 62932-1:2021](https://standards.iteh.ai/catalog/standards/sist/c65e58fb-f8d1-422f-a4e2-ae22de156b8e/sist-en-iec-62932-1-2021)

<https://standards.iteh.ai/catalog/standards/sist/c65e58fb-f8d1-422f-a4e2-ae22de156b8e/sist-en-iec-62932-1-2021>

FLOW BATTERY ENERGY SYSTEMS FOR STATIONARY APPLICATIONS –

Part 1: Terminology and general aspects

1 Scope

This part of IEC 62932 relates to flow battery energy systems (FBES) used in electrical energy storage (EES) applications and provides the main terminology and general aspects of this technology, including terms necessary for the definition of unit parameters, test methods, safety and environmental issues.

2 Normative references

There are no normative references in this document.

3 Terms, definitions and abbreviated terms

3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1.1

ambient temperature

environmental temperature around a flow battery energy system

3.1.2

auxiliary energy

energy consumed by all the auxiliary equipment and components of a flow battery and of a flow battery energy system

Note 1 to entry: The equipment and components include, but are not limited to, battery management system, battery support system, fluid circulation system.

3.1.3

battery management system

BMS

electronic system associated with a flow battery energy system which monitors and/or manages its state, calculates secondary data, reports that data and/or controls its environment to influence the flow battery energy system's performance and/or service life

Note 1 to entry: The function of the battery management system can be fully or partially assigned to the battery pack and/or to equipment that uses flow battery energy store systems.

[SOURCE: IEC 61427-2:2015, 3.8, modified – admitted terms "battery management unit" and "BMU" omitted, "battery" replaced by "flow battery energy system", Notes 2 to 4 deleted.]

3.1.4**battery support system****BSS**

auxiliary units, such as heat exchanger, ventilation system, safety system, and inert gas system, used in an FBES, and which are not stacks, or part of the fluid circulation system, power conversion system, or battery management system

Note 1 to entry: The battery support system is controlled by the battery management system.

3.1.5**charge****charging**

<of a battery> operation during which a secondary cell or battery is supplied with electric energy from an external circuit which results in chemical changes within the cell and thus the storage of energy as chemical energy

Note 1 to entry: A charge operation is defined by its maximum voltage, current, duration and other conditions as specified by the manufacturer.

[SOURCE: IEC 60050-482:2004, 482-05-27, modified – term "charging of a battery" separated into "charge" and "charging" with "of a battery" as the domain, and addition of the note.]

3.1.6**cold standby**

standby state requiring warm up before a demand to operate can be met

Note 1 to entry: A cold standby state may apply to redundant or stand-alone items.

Note 2 to entry: In this context "warm up" includes meeting any conditions required to operate as required (e.g. achieving the required temperature, speed, pressure).

[SOURCE: IEC 60050-192:2015, 192-02-11, modified – "state" omitted from the term, and the domain, "of an item", deleted.]

3.1.7**discharge****discharging**

<of a battery> operation during which a secondary battery supplies electric energy to an external circuit which results in chemical changes within the cell and the release of energy as electrical energy

Note 1 to entry: A discharge operation is defined by its maximum voltage, current, duration and other conditions as specified by the manufacturer.

3.1.8**emergency shutdown**

rapid regulated shutdown of the flow battery energy system triggered by a protection system or by manual intervention

[SOURCE: IEC 60050-415:1999, 415-01-11, modified – the word "regulated" added, and "wind turbine" replaced by "flow battery energy system".]

3.1.9**emergency stop**

function which is intended to avert arising or reduce existing hazards to persons, damage to machinery or to work in progress and be initiated by a single action

[SOURCE: ISO 13850:2015, 3.1, modified – "(E-Stop)" omitted from the term, second preferred term "emergency stop function" omitted, layout modified.]

3.1.10**energy efficiency**

useful energy output at primary POC divided by the required energy input by the FBES/FBS including all parasitic and auxiliary energy needed to run the system and evaluated during FBES/FBS operation with the same final state of charge as the initial state of charge

Note 1 to entry: The energy efficiency for FBES includes necessary conversion loss of power conversion system (PCS), auxiliary energy required for fluid circulation system, BMS and BSS.

Note 2 to entry: Efficiency is generally expressed in percentage.

[SOURCE: IEC 62933-1:2018, 4.12, modified – "EES" replaced by "FBES/FBS", Note 1 to entry replaced.]

3.1.11**energy storage fluid**

fluid that contains active materials and flows through the battery cell, consisting of liquid, suspension or gas

3.1.12**end of charge**

limit conditions specified by the manufacturer at which a charge is (to be) terminated

3.1.13**end of discharge**

limit conditions specified by the manufacturer at which a discharge is (to be) terminated

3.1.14**flow cell**

secondary cell characterized by the spatial separation of the electrodes and the movement of the energy storage fluids

Note 1 to entry: Flow battery cell includes the hybrid flow cell.

3.1.15**flow battery energy system
FBES**

system to store energy consisting of FBS(s) and power conversion system(s)

3.1.16**flow battery system
FBS**

two or more flow cells electrically connected including all components for use in an electrochemical energy storage system such as battery management system, battery support system and fluid circulation system

3.1.17**fluid system**

components and equipment destined to store and circulate energy storage fluids, such as tanks, pipes, manual valves, electrical valves, pumps and sensors

3.1.18**forced ventilation**

movement of air and its replacement with fresh air by mechanical means

[SOURCE: IEC 62282-3-300:2012, 3.9]