
Lifts (elevators) — Requirements for lifts used to assist in building evacuation

*Ascenseurs — Exigences pour les ascenseurs utilisés en cas
d'évacuation de bâtiments*

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

ISO/TS 18870:2014

<https://standards.iteh.ai/catalog/standards/iso/9e77bd0a-374f-4dd7-99fd-98d1e71d8d01/iso-ts-18870-2014>



iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

ISO/TS 18870:2014

<https://standards.iteh.ai/catalog/standards/iso/9e77bd0a-374f-4dd7-99fd-98d1e71d8d01/iso-ts-18870-2014>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2014

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Automatic evacuation lift specification	3
4.1 Determining the number and size of lifts	3
4.2 Protection of lift equipment	3
4.3 Waiting and travelling environment for users.....	4
4.4 Removal or suspension of lifts from evacuation service.....	4
4.5 Lift system reliability.....	4
4.6 Automatic recovery system.....	4
4.7 Remote lift car surveillance	5
4.8 Communication system requirements	5
4.9 Lift signs and passenger announcements.....	6
4.10 Prevention and detection of car overloading	6
4.11 Initiation of evacuation service	6
4.12 Description of evacuation service	6
4.13 Removal of lifts cars from service.....	8
4.14 Change of main evacuation exit floor (MEEF).....	9
4.15 Cancellation of evacuation service.....	9
5 Information to be provided to the building owner	9
6 Other information to be provided	10
Annex A (informative) Building design considerations for automatic lift evacuation specification	11
Annex B (informative) Information to be provided	19
Bibliography	21

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: Foreword - Supplementary information

The committee responsible for this document is ISO/TC 178, *Lifts, escalators, and moving walks*.

Document Preview

[ISO/TS 18870:2014](https://standards.iteh.ai)

<https://standards.iteh.ai/catalog/standards/iso/9e77bd0a-374f-4dd7-99fd-98d1e71d8d01/iso-ts-18870-2014>

Introduction

This Technical Specification has been prepared in response to ISO/TC 178 Resolution 273/2007 in which the Technical Committee requested that WG 6 undertake to write a specification for lift features that if incorporated into an appropriate lift would enable it to be used in safety to evacuate persons from a building that was suitably designed.

This work results from a detailed study undertaken by TC 178/WG6 into the feasibility of using lifts for evacuation of persons. The study ISO/TR 25743 indicated that it was feasible to use lifts, provided that certain features were incorporated in the lift and also in the building.

Lift engineers and other specialists have been involved in the production of this specification.

It has been recognized that lift engineers are not experts in building design or fire engineering. The writing of this Technical Specification does not indicate if it is acceptable or permitted to use lifts for building evacuations. It only indicates the features required should those persons responsible wish to make such a decision. This Technical Specification does not define, in any detail, building features that will have to be provided in conjunction with a lift intended to be used for evacuation. Its aim is to make clear to those persons involved in building design and fire engineering the issues that they shall address to enable the lift to be used safely.

There are many reasons why a building might need to be evacuated, such as a fire, explosion, chemical or biological attack, flooding, storm damage, earthquake, etc. Not all of these are relevant to every building and other hazardous situations, while existing, are so unlikely to occur that they can be disregarded. Designers of buildings have to determine if a particular hazard is sufficiently great as to require addressing.

If, for example, a small office block is being designed that will be located in a mid-town area, it is within the realm of possibility that it could be subjected to an explosion or chemical attack (terrorism). It is not, however, very likely to be the case unless it has some particular reason to make it vulnerable. In most cases, the risk of these events is probably so low as to make it unnecessary for them to be addressed.

If the building is to be the headquarters of National Security, this will increase the likelihood of it being subjected to some form of attack. It might be necessary to consider the effects of an explosion in or close to the building or a chemical agent being introduced into the building.

Clearly, a building constructed in an area where earthquakes do not normally occur need not have provisions made for such an event.

If a building is to be built in the centre of a major city to form a prestigious landmark, it might be essential to consider all likely events that could occur.

The designer of the building has to determine, by risk assessment or other methods, what hazardous events need to be reasonably addressed. Once this is completed, ISO/TR 25743 can be used to understand the lift and building features that might be required for each evacuation scenario envisaged.

A lift or lifts can enable disabled persons to evacuate a building in relative ease, but if it is thought, lifts could play a role in general evacuation, they might or might not make a significant contribution to reducing the general evacuation time. It will depend on the building size, number of lifts, etc.

This Technical Specification defines lift requirements to address common hazards that all users could be exposed to if lifts are used for evacuation.

Even if it is thought that lifts could play a part in a general evacuation, it might prove to be uneconomical. It is not suggested for lifts to replace or change the requirements for escape stairs, and that using lifts instead of stairs can increase evacuation times in many building designs. The intention is to allow lifts to play a positive role in assisting and improving the efficiency of the building evacuation strategy.

This Technical Specification is divided into sections covering the key items that have to be addressed. There is no priority intended from the order in which the items are listed.

Lifts (elevators) — Requirements for lifts used to assist in building evacuation

1 Scope

This Technical Specification details requirements for passenger carrying lifts, which are installed in buildings having a suitable comprehensive building evacuation strategy. It does not define building requirements that will have to be provided as part of the overall evacuation strategy for the building.

Excluded from this Technical Specification are the following:

- details of a building evacuation strategy;
- details of building features to reduce risks or eliminate hazards;
- national building requirements which might demand special features.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 4190-5, *Lift (Elevator) installation — Part 5: Control devices, signals and additional fittings*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

Alternative Evacuation Exit Floor

AEEF

level defined by the building designer to be used for evacuation when systems or management determine it should be used

3.2

Building Management System

BMS

system capable of making appropriate decisions based on information sent to it

3.3

chemical incident

introduction of a gas, chemical, bacterial agent, or substance into the building

3.4

building management

persons or organization responsible for ensuring the day-to-day safe efficient running of the building and for ensuring the building is safely evacuated in line with the evacuation strategy

3.5

ETA

estimated time of arrival of the lift

3.6

fire

combustion of material producing, heat, sometimes smoke, and/or flame

3.7

Fire Command Centre

FCC

room or area provided in the building where information is displayed showing the status of a fire detection system and lifts, etc. and where management can receive audible and visual information to determine what actions to take if lifts are to be used

3.8

fire compartment

fire separated area

area within a building bounded by walls, floor, and ceiling constructed from fire resisting material so as to provide resistance to fire for a defined period

3.9

fire warden

person appointed by the building management to assist in managing the evacuation of a floor or area of building during an emergency

3.10

hazardous area

area where due to heat, smoke, gas, etc. the environment is considered dangerous to persons

3.11

hazard detection system

system of sensors capable of automatically detecting fire, smoke, gas, etc

3.12

impaired mobility

difficulty in using stairs because of a physical impairment

3.13

lift evacuation time

time a person spends using a lift to evacuate

Note 1 to entry: It is expressed in s.

Note 2 to entry: This is measured from initiation of evacuation service for a given floor plus the time spent travelling to the floor plus the time to open doors, load the car return nonstop to main exit for evacuation, open doors, and empty lift car.

3.14

Main Evacuation Exit Floor

MEEF

floor designated by the building designer where persons should exit lifts to leave the building

Note 1 to entry: This might or might not be the normal exit floor or ground floor of the building.

3.15

required lift evacuation handling capacity

number of persons who can be moved to the main evacuation exit floor in a five-minute period, expressed as a percentage of the total number of persons to be evacuated by lifts

Note 1 to entry: This is not to be confused with normal lift handling capacity.

3.16

required lift evacuation time

time measured from start of the lift evacuation service to completion of the evacuation of a floor or number of floors

3.17**safe area****safe floor**

area of the building, where it is known that heat, smoke, etc. are not present and where it will be safe for people to wait, travel in, or leave the lift

3.18**total lift evacuation time**

time required to move all persons requiring evacuation by lifts to the *Main Evacuation Exit Floor* ([3.14](#))

Note 1 to entry: This time is measured from start of evacuation service with lift(s) at MEEF to evacuation of all persons and return of lifts to the MEEF.

3.19**building sign**

information display provided by the building, not the lift, informing building users of the location of evacuation lifts available for use

4 Automatic evacuation lift specification

4.1 Determining the number and size of lifts

To calculate the number and size of lifts required to provide an adequate evacuation service, the handling capacity of a given lift or group of lifts shall be determined. To calculate lift handling capacity, the lift designer will require certain information as detailed in [Annex B](#).

Any other building specific information that might affect the handling capacity or assist the lift designer in understanding the issues related to the evacuation strategy should also be provided.

It shall be recognized that there is always a reasonable possibility that a lift or lifts might not be available for some reason. This might occur due to planned maintenance, repairs, etc. An allowance should be made in the handling capacity calculations to take account of this. This shall be done by assuming that in a building with multiple lifts, at least one lift will not be available at any given time and should therefore be removed from any calculation.

In determining the size of the lift, it should be assumed that if a lift car arrives at a floor and there is not enough space for people to enter, there is a risk of panic and/or overloading. This might occur where a wheelchair is in the lift consuming a relatively large amount of floor area in relation to its load. To avoid this situation, the size of lift car chosen should be suitable to accept a wheel chair while still providing room for a number of additional occupant(s).

A lift contractor will be able to calculate the number of lifts and their speed provided that the information contained in [Annex B](#) is provided.

4.2 Protection of lift equipment

Lift shafts and machine rooms or machinery spaces located outside the shaft should be fully enclosed. The temperature in the enclosures should be maintained to acceptable levels for the equipment, as determined by the lift supplier in consultation with the building management.

Water can come from a number of sources including fire hoses although it is not anticipated that hoses will be deliberately directed at the lift or its equipment.

To avoid unnecessary failures from the ingress of water, a number of provisions shall be made. Sensors in the lift pit shall monitor for the presence of water. For example,

- a) if water is detected below the level of pit equipment, sheave, etc. so as not to affect operation; for this condition, a warning shall be sent to the FCC and any BMS, but lifts shall continue to operate, and/or
- b) if the water reaches sheaves or other equipment, the lift shall be removed from service (see [4.5](#)).

4.3 Waiting and travelling environment for users

To ensure the safety of users, lift machine spaces, lift shaft, and landing areas outside the lift should be monitored for the presence of smoke or high temperatures likely to harm persons or cause failures of the lift equipment.

The lifts shall not monitor these conditions but respond appropriately to information sent to them by those providing the monitoring equipment.

When an unsafe condition is detected at a floor, the lift shall be prevented from stopping at the relevant floor or floors.

If an unsafe condition is detected in the well or machinery space, the lift shall be removed from service at the first available safe area.

The lift shall inform the FCC and any BMS that it is no longer available for service.

4.4 Removal or suspension of lifts from evacuation service

Where a lift receives a command from a BMS or manual signal to stop or suspend service to a floor or area of the building, any stop shall be a controlled stop at a safe area. A controlled stop means allowing the lift to slow down and stop at a floor in the normal manner.

Where a lift or lifts are instructed to suspend service, the lift(s) shall inform the FCC and any BMS once it is no longer available for service.

4.5 Lift system reliability

Lift reliability is an important issue but it should be noted that this specification already calls for many features that will increase reliability, such as water protection. The lift will also have an automatic recovery system that minimizes the risk to passengers if a stoppage occurs. For this reason, no further additional provisions are required.

Loss of a bank of lifts is much more serious but is only likely to occur due to loss of the power supply. For this reason, it is vital that secondary (emergency supplies) are provided (see [Annex A](#)).

4.6 Automatic recovery system

Whenever a lift containing passengers has stopped for some reason, it needs to be, if possible, automatically recovered to a safe floor. If it is not close enough to a safe floor to open its doors, it should be provided with a means to enable it to attempt an automatic recovery and during this process both car and landing doors should be locked closed and passengers should be informed that a recovery is taking place.

Whenever a car stops, it is a natural reaction for passengers to try and pull the car door open. For this reason, car doors should be locked shut during automatic recovery operation. The doors should remain locked shut until it is determined that the car has recovered to a floor.

During any recovery or attempted recovery, passengers shall be kept informed of what is going on. This information shall be both audible and visual.

A recovery attempt might fail for some reasons, therefore, passengers should be informed of any recovery or failure to recover. If it is not possible to recover the lift and passengers are trapped, they should be provided with visual and audible information that the alarm has been automatically raised and they will be rescued shortly. They shall also be able to communicate with those in charge of evacuation.

If a lift fails for some reason, it shall

- a) determine if the lift contains passengers and is outside a door zone,
- b) automatically lock the car doors if outside the door zone,