

---

---

**Information and documentation —  
Document storage requirements for  
archive and library materials**

*Information et documentation — Prescriptions pour le stockage des  
documents d'archives et de bibliothèques*

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST ISO 11799:2018](https://standards.iteh.ai/catalog/standards/sist/c905b187-132b-4a58-9edf-4a039082fb81/sist-iso-11799-2018)

<https://standards.iteh.ai/catalog/standards/sist/c905b187-132b-4a58-9edf-4a039082fb81/sist-iso-11799-2018>



**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST ISO 11799:2018

<https://standards.iteh.ai/catalog/standards/sist/c905b187-132b-4a58-9edf-4a039082fb81/sist-iso-11799-2018>



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2015, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Ch. de Blandonnet 8 • CP 401  
CH-1214 Vernier, Geneva, Switzerland  
Tel. +41 22 749 01 11  
Fax +41 22 749 09 47  
[copyright@iso.org](mailto:copyright@iso.org)  
[www.iso.org](http://www.iso.org)

# Contents

	Page
<b>Foreword</b> .....	<b>iv</b>
<b>Introduction</b> .....	<b>v</b>
<b>1 Scope</b> .....	<b>1</b>
<b>2 Terms and definitions</b> .....	<b>1</b>
<b>3 Risk management</b> .....	<b>2</b>
<b>4 Construction of the building</b> .....	<b>2</b>
4.1 Security.....	2
4.2 Indoor climate stability.....	3
4.3 Inner structure and load requirements.....	3
<b>5 Installation and equipment</b> .....	<b>3</b>
5.1 Services.....	3
5.2 Fire prevention.....	4
5.3 Fire detection.....	4
5.4 Fire extinguishing.....	4
5.5 Storage environment.....	4
5.5.1 Illumination.....	4
5.5.2 Humidity and temperature.....	5
5.5.3 Ventilation and air quality.....	5
5.6 Furniture and equipment.....	6
<b>6 Maintenance</b> .....	<b>6</b>
<b>Annex A (informative) Fire prevention systems</b> .....	<b>7</b>
<b>Annex B (informative) Fire fighting systems</b> .....	<b>8</b>
<b>Annex C (informative) Recommended climatic conditions for the long-term storage of archive and library materials</b> .....	<b>9</b>
<b>Annex D (informative) Guidance for air pollutants</b> .....	<b>10</b>
<b>Bibliography</b> .....	<b>11</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 46, *Information and documentation*, Subcommittee SC 10, *Requirements for document storage and conditions for preservation*.

This second edition cancels and replaces the first edition (ISO 11799:2003), which has been technically revised.

## Introduction

Archives and libraries are institutions established to collect, preserve and make available materials intended for consultation.

Archive and library collections wherever they are stored normally contain a wide variety of material and formats. These are mainly documents on paper, parchment, palm leaves, papyrus and may also include photographic, audio-visual documents and digital formats on diverse types of carriers (mechanical, photo, magnetic, optical). All these materials ideally require specific storage conditions to ensure their long-term preservation and access.

NOTE See the Bibliography for ISO standards on storage of specific materials.

Figures and quantities given in this International Standard are intended for general international guidance. This International Standard presents some facts and general rules to be considered when a purpose built repository is designed, when an old building originally designed for another use is converted, or when a building already in use as repository is renovated, with respect to energy efficiency and sustainable development.

This International Standard applies to the long-term storage of archive and library materials for their lifetime. It takes into account that the materials are stored and allow current usage as well.

Depending on the climate and economic situation of individual countries, it may be difficult to create and maintain ideal conditions for the long-term storage of archive and library materials.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST ISO 11799:2018

<https://standards.iteh.ai/catalog/standards/sist/c905b187-132b-4a58-9edf-4a039082fb81/sist-iso-11799-2018>

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST ISO 11799:2018

<https://standards.iteh.ai/catalog/standards/sist/c905b187-132b-4a58-9edf-4a039082fb81/sist-iso-11799-2018>

# Information and documentation — Document storage requirements for archive and library materials

## 1 Scope

This International Standard specifies the characteristics of repositories used for the long-term storage of archive and library materials. It covers the siting and construction and renovation of the building and the installation and equipment to be used both within and around the building.

It applies to all archive and library materials held in repositories, where mixed media may be stored together with paper-based materials. It does not preclude the establishment of separate areas or compartments within individual repositories, where the environment can be controlled to create conditions suitable for the needs of specific archive materials.

In a number of fields, national or local building regulations may encompass such matters as construction, safety and security for public buildings and buildings in which valuable objects are stored (fire precautions, emergency exits, security against earthquakes, theft, burglary, terrorist acts, etc.), as well as services and equipment in professional use. This International Standard therefore avoids detailed rules and regulations in these fields, except when recommending what may be additions to these requirements.

iTeh STANDARD PREVIEW

## 2 Terms and definitions (standards.iteh.ai)

For the purposes of this document, the following terms and definitions apply.

**2.1** **archive and library materials** <https://standards.iteh.ai/catalog/standards/sist/c905b187-132b-4a58-9edf-4a039082fb81/sist-iso-11799-2018>

all types of documents kept in archives and libraries regardless of their physical format, mainly books, manuscripts, files, maps, graphic collections and other documents consisting of paper, but also parchment, papyrus, films, photographic materials, audiovisual recordings, magnetic and optical media, as well as bindings and protective material

**2.2** **document**

recorded information or material object which can be treated as a unit in a documentation process

**2.3** **long-term storage**

storage, for a period of undefined length, of material kept for permanent retention

**2.4** **maintenance**

actions of prevention or correction to support long-term functionality of repositories and the systems that support them.

[SOURCE: EN 13306:2010]

**2.5** **repository**

building or room designed or arranged and used specifically and exclusively for long-term storage of archive and library materials

### 3 Risk management

An overall assessment including an evaluation of the need and the risks should take place especially considering possible hazards.

The site for an archive and/or library repository building should consider the following risks:

- flooding;
- subsidence or landslides;
- tsunamis, frequent volcanic activity, or earthquakes;
- fire or explosions from adjacent site activities;
- accidents on nearby air runways or train tracks;
- proximity to strategic installations which would be a target in an armed conflict, terrorist attack or civil unrest;
- proximity to a plant, installation or natural source that emits harmful gases, smoke, dust, etc.;
- proximity to a place or a building which attracts rodents, insects and other pests.

The building shall be designed to protect the holdings by mitigating for hazards including the following:

- intentional harm;
- fire;
- water;
- pests;
- contaminants;
- light, UV, IR;
- temperature extremes or harmful fluctuations;
- humidity extremes or harmful fluctuations.

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST ISO 11799:2018  
https://standards.iteh.ai/catalog/standards/sist/c905b187-132b-4a58-9edf-4a039082fb81/sist-iso-11799-2018](https://standards.iteh.ai/catalog/standards/sist/c905b187-132b-4a58-9edf-4a039082fb81/sist-iso-11799-2018)

In order to minimize the harmful effects of external climatic variations, careful attention should be given to the building's orientation, landscaping, the overall climate of the site and the construction of the building.

The building shall be designed to facilitate the safe movement of holdings and assist the recovery from significant threats i.e. consideration of smoke hatches, floor drains and ramps.

A post-occupancy evaluation will ensure that the objectives have been met and the desired effects have been achieved.

### 4 Construction of the building

#### 4.1 Security

The repository shall be secured against theft, burglary, vandalism and terrorism. Precautions should be taken against arson. The repository shall be either a purpose-built detached building or a self-contained unit within a building. Precautions shall be taken against entrances being used by unauthorized people. The building design should facilitate monitoring.

NOTE 1 For more information on precautions against arson, see Reference [8].



NOTE 2 For more information on security in archives and libraries see Reference [14].

Emergency exits shall be constructed in such a way that they can easily be opened from the inside and that they cannot be opened from the outside, with the exceptions for fire response.

In the interests of security, it is recommended that storage areas should have no windows or skylight or they shall be fitted to provide adequate security (see also 5.5).

## 4.2 Indoor climate stability

Temperature and relative humidity have an impact on the holdings. Therefore storage areas should be designed to provide a stable internal environment appropriate to the preservation of the materials (see Annex C).

This can be partially achieved by constructing the external walls, roof and floor of the building from materials that, as far as possible, insulate the interior from external climatic changes without comprising air supply and circulation required for both collection storage and human occupancy. Walls, floors and ceilings inside the repository should be made of materials that have a high thermal inertia and moisture buffering.

Positive or at least neutral air pressure in repositories is recommended to maintain appropriate, conditioned environment and keep dust, pollutants and unconditioned air from entering the room.

NOTE For more information, see the Reference [15].

## 4.3 Inner structure and load requirements

For reasons of efficient climate control, fire safety and to limit loss of holdings in the event of fire, the repository should be compartmentalized.

The walls (including doors), floors and ceilings between single rooms and compartments, and between storage and other areas of the building shall be constructed so as to prevent fire (and water) from spreading into a neighbouring unit.

The floor load shall be calculated to include the specific volume and type(s) of archival records, the containers, and the static or movable shelving, cabinets and/or cases.

Structural support overall, or in specific higher load areas should be provided.

It is recommended that shelving configuration be considered during design to ensure shelving structural support, aisle width, and movement of materials are appropriate for materials types and containers to be stored.

Drains are recommended if water is used for fire protection, with protection against the entry of pests and water. Drainage shall be configured to carry water completely away from the building.

Provide space for safe and efficient movement of holdings. Inner structural supports and doorways will need to be designed to enable safe, unimpeded movement of collections of material by all available means of transport.

All inner structural systems should be engineered with bracing to resist movement or tipping that could result in a collapse or other damage to the holdings.

## 5 Installation and equipment

### 5.1 Services

Supply systems for electricity, gas and liquids, and drains shall not be located in, above or adjacent a room in the repository, unless needed in that room for a specific function directly connected with the repositories.

A building management system control should be in a different fire compartment than the repository.

## 5.2 Fire prevention

The aim is to avoid a fire within the repository and make the repository impregnable for fire from the outside.

NOTE For further information, see [Annex A](#).

## 5.3 Fire detection

All parts of the building shall be provided with a fire detection system connected to a central monitoring panel. Such a system shall respond automatically to the presence of fire by detecting smoke or other products of combustion. Heat detection devices shall only be installed as the sole method of detection in areas where other types of detectors may be inappropriate or unsuitable.

All parts of the building shall, in addition, be provided with manually operated fire-alarm call points which can be used by occupants to indicate the presence of a fire.

The central fire-alarm control panel should provide the ability to monitor all components of the system and should visually display the status of the system.

Panels should be located in a convenient, central location which is continuously monitored while the repository is occupied or open. Where the panel is not located at or near the probable fire-brigade entry point, a supplementary or repeater panel should be provided for the use of the fire brigade.

## 5.4 Fire extinguishing

The repository shall be equipped with fire extinguishers. Consideration should be given to the benefits offered by an automatic fire fighting system. Gas- or water-based fire fighting systems with no additives are recommended in repositories.

Fire extinguishing measures should be designed complying with the material stored, the design of the building, considering the size of the fire compartments, higher density structure, type of shelving, etc.

NOTE For further information, see [Annex B](#).

## 5.5 Storage environment

### 5.5.1 Illumination

The damage caused by light is cumulative. Intensity, duration and spectral distribution of any illumination in a repository should be controlled to minimize damage. Different materials react differently to light. Some are more prone to be affected than others. Light in general is damaging and should be kept at a minimum. Direct daylight shall be excluded.

In a building not primarily designed as a repository, but adapted for that purpose, windows should be blocked or as a minimum be screened by curtains or blinds, and/or by solar filtering on the window glass (IR, UV, visible radiation).

Similar screening provisions are recommended for offices, public reading rooms and any other room in which documents are exhibited. At an easily accessible place outside the repository, there should be a central switch indicating whether all lights and other electrical circuits in the repository are turned off. It should be ensured that illumination is powered off, through time controls, motion detection, or other means.

A repository room shall not be illuminated more than is necessary for retrieval and replacement of documents, room inspection and cleaning.

For the two latter purposes, an illumination of about 100 lux on the floor level is sufficient. The distance between the lamp and the nearest unprotected material should be considered with regards to the heat the lamp generates.

## 5.5.2 Humidity and temperature

Repositories for archive and library materials shall be kept at a relative humidity below the point where microbiological activity occurs.

Repositories for archive and library materials should be kept at a cool temperature, ideally controlled in a building with high thermal and hydric inertia (see 4.2).

NOTE According to the present state of knowledge, there is an increasing risk of microbiological activity above 60 % relative humidity, and increased brittleness at low relative humidity. The lowest acceptable humidity for long-term storage of archive and library materials is under discussion. For different kinds of materials, different limits are recommended, but there is no general agreement, either upon temperature or upon humidity. In general materials last longer at lower temperatures and at lower relative humidity. As guidance, the data in [Annex C](#) may be used.

## 5.5.3 Ventilation and air quality

### 5.5.3.1 General

The purpose of air ventilation is to ensure an appropriate air quality in archival storage in order to keep the records clean and dry and to discourage microorganisms, safeguard health by avoiding mold outbreaks, and to avoid damage to records.

### 5.5.3.2 Ventilation

Ventilation includes both air exchanges and air circulation in the archival storage area. Air circulation is necessary in all locations and all levels to minimize the risk of developing microclimates that may cause a mold growth. Air exchange is necessary to prevent the build-up of off-gassing from the holdings, i.e. acetic and formic acids.

### 5.5.3.3 Particulates

Accumulations of particulates can encourage growth of microorganisms. Some particulates contain burned hydrocarbons, sulfur and other compounds that harm collections. A particulate filtration system, if necessary, should be designed for both air supply and return air ducting.

To avoid an internal source of particulates, it is recommended that all concrete block walls be primed and painted, and concrete floors hardened with sealant to prevent particulate accumulations inside the storage area.

### 5.5.3.4 Gaseous contaminants

Gaseous contaminants can cause irreversible damage to holdings (i.e. discoloration of silver-based photographic holdings, and distortion of plastic films due to increased acidity, etc.). Gaseous pollution-related damage is cumulative, is influenced by other environmental factors (i.e. relative humidity and temperature), (See [Annex D](#) for further information).

NOTE 1 The most common contaminants from external sources, found in archival storage areas are forms of NO(x) and SO(x) from the combustion of hydrocarbons. Ozone from external sources; in higher concentrations in urban areas; is readily converted to an inactive form and is not found in high concentrations in most archival storage facilities.