

---

**Visokonapetostne stikalne in krmilne naprave - 214. del: Razvrščanje notranjih oblokov pri krmilnih napravah, nameščenih na drogovih, za napetosti nad 1 kV do vključno 52 kV (IEC 62271-214:2019)**

High-voltage switchgear and controlgear - Part 214: Internal arc classification for pole-mounted switchgear for rated voltages above 1 kV and up to and including 52 kV (IEC 62271-214:2019)

Hochspannungs-Schaltgeräte und -Schaltanlagen – Teil 214: Störlichtbogenklassifikation für metallgekapselte, mastmontierte Schaltanlagen für Bemessungsspannungen über 1 kV bis einschließlich 52 kV (IEC 62271-214:2019)

Appareillage à haute tension - Partie 214: Classification arc interne des appareillages sous enveloppe métallique de tensions assignées supérieures à 1 kV et inférieures ou égales à 52 kV montés sur poteau (IEC 62271-214:2019)

**Ta slovenski standard je istoveten z: EN IEC 62271-214:2019**

**ICS:**

29.130.10	Visokonapetostne stikalne in krmilne naprave	High voltage switchgear and controlgear
-----------	--	---

**SIST EN IEC 62271-214:2019** en

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN IEC 62271-214:2019](https://standards.iteh.ai/catalog/standards/sist/2f72bab7-9a75-4998-8c2d-9821cb439e51/sist-en-iec-62271-214-2019)

<https://standards.iteh.ai/catalog/standards/sist/2f72bab7-9a75-4998-8c2d-9821cb439e51/sist-en-iec-62271-214-2019>

EUROPEAN STANDARD

EN IEC 62271-214

NORME EUROPÉENNE

EUROPÄISCHE NORM

September 2019

ICS 29.130.10

English Version

High-voltage switchgear and controlgear - Part 214: Internal arc classification for metal-enclosed pole-mounted switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV  
(IEC 62271-214:2019)

Appareillage à haute tension - Partie 214: Classification arc interne des appareillages sous enveloppe métallique de tensions assignées supérieures à 1 kV et inférieures ou égales à 52 kV montés sur poteau  
(IEC 62271-214:2019)

Hochspannungs-Schaltgeräte und -Schaltanlagen - Teil 214: Störlichtbogenklassifikation für metallgekapselte, mastmontierte Schaltanlagen für Bemessungsspannungen über 1 kV bis einschließlich 52 kV  
(IEC 62271-214:2019)

This European Standard was approved by CENELEC on 2019-07-25. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

(standards.iteh.ai)

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

SIST EN IEC 62271-214:2019

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

**EN IEC 62271-214:2019 (E)****European foreword**

The text of document 17C/706/FDIS, future edition 1 of IEC 62271-214, prepared by SC 17C "Assemblies" of IEC/TC 17 "High-voltage switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62271-214:2019.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2020-04-25
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2022-07-25

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

**iTeh STANDARD PREVIEW**  
**Endorsement notice**  
**(standards.iteh.ai)**

The text of the International Standard IEC 62271-214:2019 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60060-1:2010	NOTE	Harmonized as EN 60060-1:2010 (not modified)
IEC 60529:1989	NOTE	Harmonized as EN 60529:1991 (not modified)
IEC 60909-0:2016	NOTE	Harmonized as EN 60909-0:2016 (not modified)
IEC 60243-1:2013	NOTE	Harmonized as EN 60243-1:2013 (not modified)
IEC 62271-100	NOTE	Harmonized as EN 62271-100
IEC 62271-102	NOTE	Harmonized as EN IEC 62271-102
IEC 62271-103	NOTE	Harmonized as EN 62271-103
IEC 62271-203:2013	NOTE	Harmonized as EN 62271-203:2013 (not modified)
IEC/TR 62271-307	NOTE	Harmonized as CLC IEC/TR 62271-307
IEC 60038:2009	NOTE	Harmonized as EN 60038:2011
IEC 60059:1999	NOTE	Harmonized as EN 60059:1999 (not modified)

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: [www.cenelec.eu](http://www.cenelec.eu).

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-151	2001	International Electrotechnical Vocabulary - Part 151: Electrical and magnetic devices	-	-
IEC 60050-441	1984	International Electrotechnical Vocabulary. Switchgear, controlgear and fuses	-	-
IEC 62271-1	2017	High-voltage switchgear and controlgear - Part 1: Common specifications for alternating current switchgear and controlgear	EN 62271-1	2017

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN IEC 62271-214:2019](https://standards.iteh.ai/catalog/standards/sist/2f72bab7-9a75-4998-8c2d-9821cb439e51/sist-en-iec-62271-214-2019)

<https://standards.iteh.ai/catalog/standards/sist/2f72bab7-9a75-4998-8c2d-9821cb439e51/sist-en-iec-62271-214-2019>



IEC 62271-214

Edition 1.0 2019-06

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

**High-voltage switchgear and controlgear –  
Part 214: Internal arc classification for metal-enclosed pole-mounted switchgear  
and controlgear for rated voltages above 1 kV and up to and including 52 kV**

**Appareillage à haute tension –  
Partie 214: Classification arc interne des appareillages sous enveloppe  
métallique de tensions assignées supérieures à 1 kV et inférieures ou égales à  
52 kV montés sur poteau**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

ICS 29.130.10

ISBN 978-2-8322-6996-1

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references .....	7
3 Terms and definitions .....	7
3.1 General terms and definitions .....	8
4 Normal and special service conditions .....	10
4.1 General.....	10
5 Ratings.....	10
5.1 General.....	10
5.2 Rated voltage ( $U_r$ ) .....	10
5.2.1 General .....	10
5.3 Rated insulation level ( $U_d$ , $U_p$ , $U_s$ ) .....	10
5.4 Rated frequency ( $f_r$ ).....	10
5.101 Ratings of the internal arc classification (IAC).....	10
5.101.1 General .....	10
5.101.2 Rated approach distance ( $D_{AP}$ ).....	10
5.101.3 Rated arc fault currents ( $I_A$ , $I_{Ae}$ ).....	11
5.101.4 Rated arc fault duration ( $t_A$ , $t_{Ae}$ ) .....	11
6 Design and construction .....	11
6.11 Nameplate .....	11
6.11.1 General .....	11
6.101 Internal arc fault.....	12
6.102 Enclosure .....	12
7 Type tests .....	13
7.1 General.....	13
7.1.1 Basics .....	13
7.1.2 Information for identification of test object .....	13
7.1.3 Information to be included in type-test reports .....	14
7.101 Internal arc type test.....	14
7.101.1 General .....	14
7.101.2 Test conditions .....	15
7.101.3 Arrangement of the equipment.....	15
7.101.4 Indicators (for assessing the thermal effects of the gases).....	17
7.101.5 Arrangement of indicators.....	17
7.101.6 Test parameters .....	17
7.101.7 Test procedure .....	19
7.101.8 Criteria to pass the test .....	23
7.101.9 Transferability of the test results.....	23
8 Routine tests .....	24
9 Guide to the selection of switchgear and controlgear.....	24
9.1 General.....	24
9.101 Internal arc fault.....	24
9.101.1 General .....	24
9.101.2 Causes and preventive measures .....	24
9.101.3 Supplementary protective measures .....	25



9.101.4	Considerations for the selection and installation .....	26
9.101.5	Internal arc test .....	26
9.101.6	IAC designation .....	26
10	Information to be given with enquiries, tenders and orders (informative).....	27
10.1	General.....	27
11	Transport, storage, installation, operation instruction and maintenance .....	27
11.1	General.....	27
11.2	Conditions during transport, storage and installation .....	27
11.3	Installation .....	28
11.3.1	General .....	28
11.101	Maintenance .....	28
11.101.1	General .....	28
12	Safety.....	28
12.1	General.....	28
13	Influence of the product on the environment .....	28
Annex A	(normative) Identification of the test objects.....	29
A.1	General.....	29
A.2	Data.....	29
A.3	Drawings.....	29
Bibliography	.....	30
Figure 1	– Examples of enclosures and compartment(s) in different arrangements .....	13
Figure 2	– Test arrangement for pole-mounted switchgear and controlgear.....	16
Figure 3	– Horizontal indicator.....	17
Figure 4	– Flow-chart for the choice of arc initiation depending on the construction .....	21
Table 1	– Nameplate information .....	12
Table 2	– Parameters for internal fault test according to enclosure and compartment construction.....	20
Table 3	– Locations, causes and examples of measures to decrease the probability of internal arc faults.....	25
Table 4	– Single phase-to-earth arc fault current depending on the network neutral earthing .....	27

**ITeH STANDARD PREVIEW**  
(standards.iteh.ai)

SIST EN IEC 62271-214:2019

standards.iteh.ai/catalog/standards/sist/2f72bab7-9a75-4998-8c2d-

9821cb439e51/sist/en-iec-62271-214-2019

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

**Part 214: Internal arc classification for metal-enclosed pole-mounted switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62271-214 has been prepared by subcommittee 17C Assemblies, of IEC technical committee 17: Switchgear and controlgear.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
17C/706/FDIS	17C/710/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

This standard shall be read in conjunction with IEC 62271-1, second edition, published in 2017, to which it refers and which is applicable unless otherwise specified in this standard. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 62271-1. Amendments to these clauses and subclauses are given under the same references whilst additional subclauses are numbered from 101. Any clause with the term “Not Applicable” relates to the clause not being relevant to IEC 62271-214 and does not infer the clause is or is not relevant for its applicable switchgear standard.

A list of all parts of the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN IEC 62271-214:2019](https://standards.iteh.ai/catalog/standards/sist/2f72bab7-9a75-4998-8c2d-9821cb439e51/sist-en-iec-62271-214-2019)

<https://standards.iteh.ai/catalog/standards/sist/2f72bab7-9a75-4998-8c2d-9821cb439e51/sist-en-iec-62271-214-2019>

## INTRODUCTION

IEC 62271-214 has been developed due to the requirement to remove IAC Type C designated pole mounted switchgear from IEC 62271-200. Only enclosed terminal equipment is to be considered within IEC 62271-200. For this reason, IEC 62271-214 is to be considered independent of IEC 62271-200, however it is still related to other product standards of the IEC 62271 series.

Only open terminal pole mounted switchgear has been considered within this document.

This equipment relates to operation in three-phase, two-phase and single-phase systems.

## **iTeh STANDARD PREVIEW** **(standards.iteh.ai)**

[SIST EN IEC 62271-214:2019](https://standards.iteh.ai/catalog/standards/sist/2f72bab7-9a75-4998-8c2d-9821cb439e51/sist-en-iec-62271-214-2019)

<https://standards.iteh.ai/catalog/standards/sist/2f72bab7-9a75-4998-8c2d-9821cb439e51/sist-en-iec-62271-214-2019>