
**Fire protection — Automatic nozzle
systems —**

**Part 14:
Requirements and test methods for
water spray nozzles**

iTeh Standards
(<https://standards.itih.ai>)
Document Preview

[ISO 6182-14:2019](https://standards.itih.ai/catalog/standards/iso/00518873-83d5-4b82-b911-d7ed5949ffbf/iso-6182-14-2019)

<https://standards.itih.ai/catalog/standards/iso/00518873-83d5-4b82-b911-d7ed5949ffbf/iso-6182-14-2019>



iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 6182-14:2019](https://standards.iteh.ai/catalog/standards/iso/00518873-83d5-4b82-b911-d7ed5949ffbf/iso-6182-14-2019)

<https://standards.iteh.ai/catalog/standards/iso/00518873-83d5-4b82-b911-d7ed5949ffbf/iso-6182-14-2019>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2019

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Product consistency	2
5 Product assembly	2
5.1 Design features.....	2
5.2 Materials of construction.....	2
6 Requirements	2
6.1 Dimensions.....	2
6.1.1 Orifice size.....	2
6.1.2 Nominal thread sizes.....	2
6.2 Flow constant (see 7.2).....	2
6.3 Spray angle (see 7.3).....	3
6.4 Stress corrosion (see 7.4).....	3
6.4.1 Stress corrosion for copper alloy parts (see 7.4.1).....	3
6.4.2 Stress corrosion for stainless steel parts (see 7.4.2).....	3
6.5 Coated nozzles (see 7.5).....	3
6.5.1 Evaporation of wax and bitumen (see 7.5.1).....	3
6.5.2 Resistance to low temperatures (see 7.5.2).....	3
6.5.3 Resistance to high temperature (see 7.5.3).....	3
6.6 Resistance to heat (see 7.6).....	3
6.7 Vibration (see 7.7).....	4
6.8 Impact (see 7.8).....	4
6.9 Strength of water dispersing components (see 7.9).....	4
7 Methods of test	4
7.1 Preliminary examination.....	4
7.1.1 Visual examination.....	4
7.2 Water flow constant (see 6.2).....	4
7.3 Spray angle tests (see 6.3).....	5
7.4 Stress corrosion tests (see 6.4).....	7
7.4.1 Stress corrosion test with aqueous ammonia solution (see 6.4.1).....	7
7.4.2 Stress corrosion test with a boiling magnesium chloride solution (see 6.4.2).....	8
7.5 Tests for nozzle coatings (see 6.5).....	8
7.5.1 Evaporation test (see 6.5.1).....	8
7.5.2 Low-temperature test (see 6.5.2).....	8
7.5.3 High-temperature test (see 6.5.3).....	8
7.6 Resistance to heat test (see 6.6).....	8
7.7 Vibration test (see 6.7).....	9
7.8 Impact test (see 6.8).....	9
7.9 Strength of water dispersing components test (see 6.9).....	10
8 Marking	10
8.1 Nozzles.....	10
9 Manufacturer's installation instructions	11
Annex A (normative) Tolerances	12

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 5, *Fixed firefighting systems using water*.

A list of all parts in the ISO 6182 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

These nozzles are intended for application of hazards involving: exposure protection; the extinguishment or control of fires including flammable liquids hazards; conveyor openings; oil cooled transformers; dryers; and other hazards.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 6182-14:2019](#)

<https://standards.iteh.ai/catalog/standards/iso/00518873-83d5-4b82-b911-d7ed5949ffbf/iso-6182-14-2019>

Fire protection — Automatic nozzle systems —

Part 14: Requirements and test methods for water spray nozzles

1 Scope

This document specifies performance requirements, methods of test, and marking requirements for open water spray nozzles. This document is not applicable to open sprinklers or open water mist nozzles.

Factors of installation, such as nozzle spacing, design densities, wind and hot gas velocities, are not intended to be addressed by this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 7-1, *Pipe threads where pressure-tight joints are made on the threads — Part 1: Dimensions, tolerances and designation*

ISO 49, *Malleable cast iron fittings threaded to ISO 7-1*

ISO 65, *Carbon steel tubes suitable for screwing in accordance with ISO 7-1*

ASTM G36, *Standard Practice for Evaluating Stress-Corrosion-Cracking Resistance of Metals and Alloys in a Boiling Magnesium Chloride Solution*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

water spray nozzle

water discharge device that, when discharging water under pressure, will distribute the water in a specific directional pattern

Note 1 to entry: Some devices utilize deflector plates or swirl chambers.

3.2

open water spray nozzle

water spray nozzle (3.1) that has no heat responsive element and discharges water after the water spray system is actuated

3.3

coated nozzle

water spray nozzle (3.1) that has a factory-applied coating for corrosion protection

Note 1 to entry: For the purposes of this document, the term 'coated nozzle' does not include coatings intended for aesthetic purposes.

4 Product consistency

It shall be the responsibility of the manufacturer to implement a quality control programme to ensure that production continuously meets the requirements of this document.

5 Product assembly

5.1 Design features

All nozzles shall be designed and manufactured in such a way that they cannot be readily adjusted, dismantled or reassembled.

5.2 Materials of construction

Nozzles shall be constructed of corrosion resistant metallic materials. Nozzles made of brass, bronze or stainless steel are deemed to satisfy this requirement.

6 Requirements

6.1 Dimensions

6.1.1 Orifice size

6.1.1.1 Except as permitted in 6.1.1.2, all nozzles shall be constructed so that a sphere of diameter 5 mm can pass through each water passage in the nozzle.

6.1.1.2 Nozzles having orifices smaller than a nominal 5 mm diameter are permitted if the orifices are protected with a strainer in the system or in each nozzle. The maximum dimension of an opening in the strainer shall not exceed 80 % of the smallest water passageway being protected and the total open area of the strainer shall not be less than 150 % of the total nozzle orifice area.

NOTE If there is no risk of corrosion or water deposits, then an orifice less than 5 mm can be used without a strainer. See the manufacturer's installation instruction requirements in [Clause 9](#).

6.1.2 Nominal thread sizes

Nominal thread sizes shall be suitable for fittings threaded in accordance with ISO 7-1. The dimensions of all threaded connections should conform to International Standards where applied or shall conform to national standards where International Standards are not applicable.

6.2 Flow constant (see 7.2)

The flow constant, K , for nozzles is given by the formula:

$$K = \frac{q}{\sqrt{10p}}$$

where

p is the pressure, expressed in megapascals;

q is the flow rate, expressed in litres per minute;

K-factor for nozzles shall be in accordance with the manufacturer's design and installation instructions when determined by the test method given in 7.2. Each flow constant K (calculated), shall be within $\pm 5\%$ of the manufacturer's value, for nozzles having a nominal k-factor of 40 or larger, and $\pm 10\%$ of the manufacturer's value for nozzles having a nominal k-factor less than 40.

6.3 Spray angle (see 7.3)

When tested as described in 7.3.1 through 7.3.3, a spray nozzle shall produce a spray angle within $\pm 10^\circ$ of the manufacturer's published water discharge angles. Other methods of determining nozzle spray angle shall be permitted to be used provided the same level of accuracy is maintained.

6.4 Stress corrosion (see 7.4)

6.4.1 Stress corrosion for copper alloy parts (see 7.4.1)

When tested in accordance with 7.4.1, each nozzle shall show no cracks, delamination or degradation which could affect its ability to satisfy other requirements of this document.

6.4.2 Stress corrosion for stainless steel parts (see 7.4.2)

When tested in accordance with 7.4.2, each nozzle shall show no cracks, delamination or degradation which could affect its ability to satisfy other requirements of this document.

NOTE In some countries, this test is not mandatory.

6.5 Coated nozzles (see 7.5)

6.5.1 Evaporation of wax and bitumen (see 7.5.1)

Waxes and bitumens used for coating nozzles shall not contain volatile matter in sufficient quantities to cause shrinkage, hardening, cracking or flaking of the applied coating. The loss in mass shall not exceed 5 % of that of the original sample when tested by the method in 7.5.1.

6.5.2 Resistance to low temperatures (see 7.5.2)

All coatings used for nozzles shall not crack or flake when subjected to low temperatures by the method in 7.5.2.

6.5.3 Resistance to high temperature (see 7.5.3)

Coated nozzles shall withstand exposure to increased ambient temperatures without evidence of cracking, flaking, delamination, deformation or melting of the coating, when tested by the method specified in 7.5.3.

6.6 Resistance to heat (see 7.6)

Nozzles shall be resistant to high temperatures when tested in accordance with 7.6. After exposure, the nozzle shall not fracture or break. If visual deformation is observed in the water discharge path, it shall meet the requirements of 6.2. If the nozzle is deformed, spray angle testing shall be conducted in accordance with 6.3.

6.7 Vibration (see 7.7)

Nozzles having multiple components shall be able to withstand the effects of vibration without deterioration when tested in accordance with 7.7. After the vibration test of 7.7, nozzles shall show no visible deterioration or loosening of components.

6.8 Impact (see 7.8)

Nozzles shall have adequate strength to withstand impacts associated with handling, transport and installation without deterioration of performance. After the impact test of 7.8.1; these nozzles shall show no fracture. If the nozzle is deformed, spray angle and strength testing shall be conducted in accordance with 6.3 and 6.9.

6.9 Strength of water dispersing components (see 7.9)

The nozzle shall not show any signs of visible deterioration or loosening of components after the test specified in 7.9. If damage is noted, spray angle testing shall be conducted in accordance with 6.3.

7 Methods of test

The following tests shall be carried out for each type of nozzle. Before testing, precise drawings of parts and the assembly shall be submitted together with the appropriate specifications. Tests shall be conducted at a room temperature of $20\text{ °C} \pm 10\text{ °C}$, unless other temperatures are indicated. Nozzles shall be tested with all the components required by their design and installation instructions. Unless otherwise stated, the tolerances given in Annex A shall apply.

7.1 Preliminary examination

The construction shall be examined to ensure that it complies with the requirements of Clause 5.

7.1.1 Visual examination

Before testing, nozzles shall be examined visually with respect to the following points:

- a) marking,
- b) conformity of the nozzles with the manufacturer's drawings and specification,
- c) obvious defects.

7.2 Water flow constant (see 6.2)

The nozzle shall be mounted with a pressure gauge on a supply pipe as shown in Figure 1.

Four nozzles shall be tested. The frame arms and deflector of nozzles may be removed to facilitate testing provided this does not impact the flow constant.

The water flow shall be measured by use of a flowmeter or by collection and measurement of the water discharge by weight or volume at pressures from minimum discharge pressure to the maximum discharge pressure referenced in the manufacturer's installation instructions. In one series of tests, the pressure shall be increased at intervals of 0,1 MPa (1 bar), and, in the other series, the pressure shall be decreased from the maximum discharge pressure at intervals of 0,1 MPa (1 bar) to the minimum discharge pressure.

The K-factor shall be calculated for each flowing pressure and the K-factor shall be averaged for each series of readings. Each calculated K-factor shall be within the limits specified in 6.2. During the test, pressures shall be corrected for differences in height between the gauge and the outlet orifice of the nozzle.