



SLOVENSKI STANDARD
SIST EN 1366-10:2011+A1:2017
01-julij-2017

Nadomešča:
SIST EN 1366-10:2011

Preskusi požarne odpornosti servisnih inštalacij - 10. del: Dimne lopute

Fire resistance tests for service installations - Part 10: Smoke control dampers

Feuerwiderstandsprüfungen für Installationen - Teil 10: Entrauchungsklappen

Essais de résistance au feu des installations techniques - Partie 10: Volets de désenfumage

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Ta slovenski standard je istoveten z: EN 1366-10:2011+A1:2017

SIST EN 1366-10:2011+A1:2017
https://standards.iteh.ai/catalog/standards/sist/9112ae520711/sist-en-1366-10-2011a1-2017

ICS:

13.220.50	Požarna odpornost gradbenih materialov in elementov	Fire-resistance of building materials and elements
-----------	---	--

SIST EN 1366-10:2011+A1:2017 **en,fr,de**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 1366-10:2011+A1:2017](https://standards.iteh.ai/catalog/standards/sist/0a3263a0-5164-4373-b8d2-9112ae520711/sist-en-1366-10-2011a1-2017)

<https://standards.iteh.ai/catalog/standards/sist/0a3263a0-5164-4373-b8d2-9112ae520711/sist-en-1366-10-2011a1-2017>

EUROPEAN STANDARD

EN 1366-10:2011+A1

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2017

ICS 13.220.50; 91.140.30

Supersedes EN 1366-10:2011

English Version

Fire resistance tests for service installations - Part 10: Smoke control dampers

Essais de résistance au feu des installations techniques
- Partie 10: Volets de désenfumage

Feuerwiderstandsprüfungen für Installationen - Teil
10: Entrauchungsklappen

This European Standard was approved by CEN on 6 February 2011 and includes Amendment 1 approved by CEN on 6 February 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents	Page
European foreword.....	5
Introduction	7
1 Scope	8
2 Normative references	8
3 Terms and definitions	8
4 Test equipment	13
4.1 General.....	13
4.2 Connecting duct for multi compartment fire resisting smoke control damper: maintenance of opening test and EN 1366-2 test.....	13
4.3 Volume flow measuring station for multi compartment fire resisting smoke control damper: maintenance of opening test and EN 1366-2 test.....	13
4.4 Plenum for High Operating Temperature (HOT) test.....	13
4.5 Cycling equipment	13
4.6 Condensing unit.....	14
4.7 Gas temperature measuring devices.....	14
4.8 Exhaust fan system	14
4.9 Perforated plate.....	14
4.10 Flow measurement nozzles (fire test).....	15
4.11 Ambient leakage measuring device.....	15
4.12 Pressure sensors for differential pressure control	15
4.13 Welded connecting tube.....	15
4.14 Extract fan connecting duct.....	15
4.15 Extraction fan	16
4.16 Thermocouples	16
4.17 Oxygen measuring equipment.....	16
4.18 Observation windows.....	16
5 Test specimen	16
5.1 Cross-section.....	16
5.2 Design.....	16
5.2.1 General.....	16
5.2.2 Supporting constructions.....	16
5.2.3 Inclusion of grilles.....	17
6 Test methods	17
6.1 General.....	17
6.2 Initiation regimes for elevated temperature and fire tests.....	17
6.2.1 Smoke control damper for systems with automatic activation.....	17
6.2.2 Smoke control damper for systems with manual intervention:	18
6.3 Cycling test requirements (to form part of the sequences of testing defined below).....	18
6.3.1 General.....	18
6.3.2 Smoke control damper to be used in dedicated Smoke control systems, operated only in the case of emergency.....	18
6.3.3 Differential pressure conditions	19

6.4	Single compartment smoke control dampers mounted on the surface of a duct.....	19
6.4.1	Sequence.....	19
6.4.2	Ambient leakage.....	19
6.4.3	Cycling test.....	19
6.4.4	Elevated temperature test.....	19
6.5	Multi compartment fire resisting smoke control dampers.....	20
6.5.1	Fire resistance test according to EN 1366-2 (for units mounted within or on the face of a compartment structure).....	20
6.5.2	Maintenance of opening test (for units mounted within a compartment structure).....	21
6.5.3	Horizontal duct test for surface mounted smoke control dampers on a horizontal duct.....	21
6.5.4	Vertical duct test for surface mounted smoke control dampers.....	22
6.6	Multi compartment fire resisting smoke control dampers (HOT Classification).....	24
6.6.1	Fire resistance test (for units mounted within or on the face of a compartment structure).....	24
6.6.2	High operating test (HOT 400/30 - cycling and maintenance of opening test).....	25
7	Test procedure.....	25
7.1	Pre-test calibration.....	25
7.1.1	Oxygen-measuring instrument.....	25
7.1.2	Perforated plate.....	25
7.1.3	Leakage measurement at ambient temperature.....	26
7.2	Fire test.....	26
7.2.1	Extraction fan.....	26
7.2.2	Ignition of furnace.....	26
7.2.3	Furnace conditions.....	26
7.2.4	Temperatures and pressures.....	27
7.2.5	Oxygen measurements.....	27
7.2.6	General observations.....	27
7.2.7	Reduction of cross-section/ maintenance of opening.....	27
7.2.8	Leakage calculations.....	27
7.3	Termination of test.....	27
8	Test report.....	28
9	Direct field of application of test results.....	28
9.1	General.....	28
9.2	Smoke control damper sizes.....	28
9.3	Pressure difference.....	29
9.4	Elevated temperatures.....	29
9.5	Cycling tests.....	29
9.5.1	Smoke control dampers meeting the cycling requirements for modulating applications.....	29
9.5.2	Smoke control dampers meeting the cycling requirements for use with combined smoke control and general HVAC applications and for smoke control systems that are cycle checked every day.....	29
9.5.3	Smoke control dampers meeting the cycling requirements for smoke control dampers that are operated only in the case of emergency.....	29
9.6	Initiation method.....	29
9.7	Application to duct constructions other than that tested.....	30
9.7.1	Single compartment smoke control dampers.....	30

EN 1366-10:2011+A1:2017 (E)

9.7.2	Multi compartment smoke control dampers	30
	Annex A (normative) Cycling test.....	51
A.1	General.....	51
A.2	Purpose of the test.....	51
A.3	Method of Application	51
A.3.1	General.....	51
A.3.2	Smoke Control Damper with single blade.....	51
A.3.3	Smoke control damper with multi blades of smaller area.....	52
A.3.4	Report.....	53
A.4	Background for the torque value (informative)	53
A.4.1	Threshold rates of the working condition of the system.....	53
A.4.2	Previous experience.....	53
	Annex B (normative) Leakage calculation from oxygen measurement	55
B.1	General.....	55
	Annex C (normative) Maintenance of opening calculation.....	56
C.1	Calculation of the theoretical total mass M_{max} of hot gases during the fire test	56
C.1.1	Basis	56
C.1.2	Method	56
C.1.3	Summary	57
C.2	Calculation of the actual total mass M_{actual} of hot gases during the fire test.....	58
C.2.1	Basis	58
C.2.2	Method	59
C.2.3	Summary	59
C.3	Graphical representation of typical integral calculation from data.....	61
	Bibliography.....	62

European foreword

This document (EN 1366-10:2011+A1:2017) has been prepared by Technical Committee CEN/TC 127 "Fire safety in buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2017, and conflicting national standards shall be withdrawn at the latest by October 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document includes Amendment 1 approved by CEN on 2017-02-06.

This document supersedes EN 1366-10:2011.

The start and finish of text introduced or altered by amendment is indicated in the text by tags **A1** and **A1**.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

EN 1366 'Fire resistance tests for service installations' consists of the following

Part 1: Ducts

Part 2: Fire dampers

Part 3: Penetration seals

Part 4: Linear joint seals

Part 5: Service ducts and shafts

Part 6: Raised access and hollow core floors

Part 7: Conveyor systems and their closures

Part 8: Smoke extraction ducts

Part 9: Single compartment smoke extraction ducts

Part 10: Smoke control dampers

Part 11: Fire protective systems for cable systems and associated components (in course of preparation)

A1 Part 12: Non-mechanical fire barrier for ventilation ductwork **A1**

Part 13: Fire resistance tests for service installations - Part 13: 1-, -2, 3- sided ducts (in course of preparation)

EN 1366-10:2011+A1:2017 (E)

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 1366-10:2011+A1:2017](https://standards.iteh.ai/catalog/standards/sist/0a3263a0-5164-4373-b8d2-9112ae520711/sist-en-1366-10-2011a1-2017)

<https://standards.iteh.ai/catalog/standards/sist/0a3263a0-5164-4373-b8d2-9112ae520711/sist-en-1366-10-2011a1-2017>

Introduction

When smoke and heat exhaust ventilation are being considered, it becomes apparent that a clear path needs to be made between the area where heat and smoke is being generated (the fire) and the outside of the building.

To create this path there need to be ducts and the smoke extract path needs to remain uninterrupted. This means that smoke control dampers at the fire and along the path have to be open and remain open. Smoke control dampers at branches, or on the surface of the duct, along the path need to be closed and remain closed. In fact, if the duct crosses a compartment boundary it becomes part of the fire compartment in which the fire started.

The purpose of this European Standard is to define test methods to evaluate the abilities of smoke control dampers to

- 1) be applicable to single compartment and/or multi compartment fire resisting applications;
- 2) be applicable to automatic systems or systems with manual intervention;
- 3) change state from closed to open at elevated temperatures, and vice versa;
- 4) once opened maintain a defined cross sectional area at elevated temperature;
- 5) maintain a satisfactory leakage performance when subjected to negative pressure at elevated temperatures.

The units need to be mounted for the tests in a manner representative of practice.

Temperature and integrity measurements need to be carried out on various parts of the test construction during the test. Leakage measurements required need to be measured by direct flow measurement at the prescribed pressure differentials. Ambient leakage of the units needs also to be recorded.

Performance of these tests need to allow products to comply with EN 12101-8 and be classified to EN 13501-4. The required temperatures, pressure differentials etc. are stated in EN 12101-8.

Completing the tests within this European Standard does not ensure full compliance with EN 12101-8, as other, additional, requirements are defined in EN 12101-8. Some of these may be required to meet the classification requirements of EN 13501-4 as well.

Caution

The attention of all persons concerned with managing and carrying out this furnace testing is drawn to the fact that fire testing can be hazardous and that there is a possibility that toxic and/or harmful smoke and gases can be evolved during the test. Mechanical and operational hazards can also arise during the construction of the test elements or structures, their testing and disposal of test residues.

An assessment of all potential hazards and risks to health shall be made and safety precautions need to be identified and provided. Written safety instructions need to be issued. Appropriate training needs to be given to relevant personnel. Laboratory personnel need to ensure that they follow written safety instructions at all times.

EN 1366-10:2011+A1:2017 (E)**1 Scope**

This European Standard specifies test methods for smoke control dampers to assess their performance under elevated temperature or fire conditions.

It needs to be noted that the smoke control damper to be tested may require testing to EN 1366-2 and that this needs to be considered before carrying out these tests.

Smoke control damper tests are required to confirm that the furnace testing requirements of EN 12101-8 are met and EN 12101-8 needs to be considered before carrying out these tests.

Smoke control dampers tested to this European Standard should be classified using EN 13501-4 and this European Standard needs to be considered before carrying out these tests.

To this end this European Standard needs to be read in conjunction with EN 12101-8, EN 13501-4, EN 1366-2 and EN 1363-1, the latter giving further details for fire resistance testing.

For installation details the requirements for smoke extraction ducts need to be considered and these are defined in EN 1366-8 and EN 1366-9.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1, *Fire resistance tests — Part 1: General Requirements*

EN 1366-2, *Fire resistance tests for service installations — Part 2: Fire dampers*

EN 1366-8, *Fire resistance tests for service installations — Part 8: Smoke extraction ducts*

EN 1366-9, *Fire resistance tests for service installations — Part 9: Single compartment smoke extraction ducts*

EN 1507, *Ventilation for buildings — Sheet metal air ducts with rectangular section — Requirements for strength and leakage*

EN 1751, *Ventilation for buildings — Air terminal devices — Aerodynamic testing of damper and valves*

EN 13501-4, *Fire classification of construction products and building elements — Part 4: Classification using data from fire resistance tests on components of smoke control systems*

EN ISO 5167-1, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full — Part 1: General principles and requirements (ISO 5167-1:2003)*

EN ISO 13943:2010, *Fire safety — Vocabulary (ISO 13943:2008)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN ISO 13943:2010 and the following apply.

3.1**air inlet**

device connected to outside air to allow the inlet of air from outside the construction works

3.2**attended control room**

room with people, who have the duty to control the smoke exhaust system, permanently (24 h, seven days per week) monitor the incoming signals from the smoke control system and put the smoke control system into operation in case of smoke alarm

NOTE This ensures that the smoke control system is running and items such as the smoke control dampers are in position within the system response time.

3.3**back-up power supply**

power supply to operate the system when the normal power supply has failed

3.4**commissioning**

act of ensuring that all components and the system are installed and operating in accordance with this European Standard

3.5**elevated temperature**

temperature in excess of normal ambient air, below those necessary for fire resistance testing, to which smoke and heat exhaust ducts for single compartments are tested

3.6**fire compartment**

enclosed space, comprising one or more separate spaces, bounded by elements of construction having a specified fire resistance and intended to prevent the spread of fire (in either direction) for a given period of time

NOTE Fire compartment often has regulatory connotations. The term should not be confused with "room of origin" or "fire cell".

3.7**HVAC**

heating, ventilating and air conditioning (usually used in association with the word system)

3.8**interface control unit**

device which controls the operation of the actuator located at the smoke control damper or within the same fire zone as the smoke control damper – usually associated with a smoke control/fire alarm system

3.9**largest size**

this refers to the largest size of damper individual unit (as opposed to an assembly of units) proposed for sale/manufacture

EN 1366-10:2011+A1:2017 (E)**3.10****modulating actuators**

smoke control damper or fire damper control mechanism which can control the smoke control damper or fire damper to be in a position or number of positions between fully open and fully closed

3.11**multi compartment fire resisting smoke control dampers**

smoke control dampers for use in multi compartment areas, which may be associated with smoke control duct tested according to EN 1366-8 and/or may be installed within or on the face of a fire compartment structure

3.12**multi compartment fire resisting smoke control system ducts**

fire resisting ducts for use in multi compartment application and that have been tested and met the requirements of EN 1366-8

3.13**natural smoke and heat control system**

smoke and heat ventilation system which uses natural ventilation

NOTE Natural ventilation is caused by buoyancy forces due to differences in density of the gases because of temperature differences.

3.14**penetration seal**

product used between the smoke control system duct/damper and the fire compartment structure to maintain the fire resistance, when tested and having met the requirements of EN 1366-8, at the position where a smoke control system duct passes through the element, or a smoke control damper or fire damper is mounted in the element

3.15**powered smoke and heat exhaust system**

smoke and heat ventilation system which utilises a number of smoke control fans having met the requirements of EN 12101-3 for a defined period of time which causes the positive displacement of gases

3.16**pressure differential systems**

system of fans, ducts, vents, and other features provided for the purposes of creating a lower pressure in the fire zone than in the protected space (see prEN 12101-13)

3.17**remote signalling device**

device located away from the smoke control damper or fire damper which indicates the damper position, open or closed

3.18**safety position**

position (open or closed) into which specific projects may require certain dampers to move, depending upon the fire location within the building

NOTE Specific projects can require certain smoke control dampers to move to an open or closed position, depending upon the fire location within the building.

3.19**single compartment smoke control dampers**

smoke control dampers for use in single compartment areas, which may be associated with smoke control ducts tested to EN 1366-9, and/or may be installed in an external wall, floor or roof

3.20**single compartment smoke control system ducts**

ducts for use within single fire compartment application and that have been tested and met the requirements of EN 1366-9

3.21**smallest size**

this refers to the smallest size of damper individual unit including the minimum width and length proposed for sale/manufacture

3.22**smoke and heat exhaust ventilation system (SHEVS)**

system consisting of components jointly selected to exhaust smoke and heat

NOTE The components form a system which complies with the requirements of CEN/TR 12101-4 in order to establish a buoyant layer of warm gases above cooler cleaner air.

3.23**smoke and heat exhaust ventilator (SHEV)**

device specially designed to move smoke and hot gases out of construction works under conditions of fire

3.24**smoke barrier**

barrier to restrict the spread of smoke and hot gases from a fire, forming part of the boundary of a smoke reservoir or used as a channelling screen, or used as a void edge boundary

3.25**smoke control damper for systems with automatic activation**

smoke control damper that is applicable to the systems defined in 3.29

3.26**smoke control damper for systems with manual intervention**

smoke control damper that is applicable to the systems defined in 3.30 and 3.31

3.27**smoke control damper**

device automatically or manually activated, which can be open or closed in its operational position, to control the flow of smoke and hot gases into, from or within a duct

3.28**smoke control duct**

duct used in a system to control the movement and /or containment of smoke and heat

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 1366-10:2011+A1:2017](https://standards.iteh.ai/catalog/standards/sist/0a3263a0-5164-4373-b8d2-9112ae520711/sist-en-1366-10-2011a1-2017)

<https://standards.iteh.ai/catalog/standards/sist/0a3263a0-5164-4373-b8d2-9112ae520711/sist-en-1366-10-2011a1-2017>

EN 1366-10:2011+A1:2017 (E)**3.29****smoke control system with automatic activation**

smoke control system (smoke and heat exhaust ventilation type or pressure differential type), that operates automatically on receipt of a smoke or fire alarm without any manual action/intervention

NOTE A system with an attended control room can also be accepted as an automatic system. Once initiated, the system does not cause the smoke control damper position to be changed.

3.30**smoke control system with automatic activation and with manual override**

smoke control system (smoke and heat exhaust ventilation type or pressure differential type), that can be put into operation as 3.29 on receipt of a smoke or fire alarm, but once initiated the system allows the smoke control damper position to be changed by external input/firemen's override

3.31**smoke control system with manual intervention**

smoke control system (smoke and heat exhaust ventilation type or pressurization type), that will be put into operation, on detection smoke or fire, by human intervention (e.g. by pressing a button or pulling a handle) leading to a sequence of automatic actions in the operation of the smoke control system

NOTE Once initiated, the system allows the smoke control damper position to be changed by external input/firemen's override.

3.32**smoke layer**

layer of smoke that stabilises underneath the ceiling due to the affect of temperature gradient

3.33**smoke logging**

condition within a building when the hot gases from a fire descend to a level whereby the safe escape of the occupants is hampered and the ingress of firefighters is prevented

3.34**smoke reservoir**

region within a building limited or bordered by smoke barriers or structural elements and which in the event of a fire retains a thermally buoyant smoke layer

3.35**smoke zone (zones)**

areas into which construction works are divided for the extraction of smoke and hot gases

NOTE Each zone is served by a SHEV (or sub system of a SHEV), which is initiated by a signal from a single or group of initiation devices associated with the zone.

3.36**structural supports**

means of retaining the smoke control system duct to the building structure

3.37**system response time**

time from the initiation of the smoke control system to it being fully operational

3.38**thermal operating device**

temperature sensitive device which responds to initiate a subsequent action

3.39**triggering device**

device such as a fire detector system, smoke detector or pushbutton which sends an activating signal to the initiation device(s)

4 Test equipment**4.1 General**

In addition to the test equipment specified in EN 1363-1, the following is required (examples of test arrangements are given in Figures 3, 5, 8 and 9):

4.2 Connecting duct for multi compartment fire resisting smoke control damper: maintenance of opening test and EN 1366-2 test

The connecting duct shall be of all welded construction fabricated from $(1,5 \pm 0,1)$ mm thick steel with a width and height appropriate to the size of smoke control damper or fire damper being tested. The duct shall have a length of two times the diagonal dimension of the smoke control damper or fire damper up to a maximum of 2 m (See Figure 6). The connecting duct shall be provided with a gas tight observation window. The general test arrangement showing flow measuring equipment is shown in Figure 6.

4.3 Volume flow measuring station for multi compartment fire resisting smoke control damper: maintenance of opening test and EN 1366-2 test

This shall consist of a Venturi, orifice plate, or other suitable device and (where necessary) an air flow straightener, installed in straight lengths of pipe, all sized in accordance with EN ISO 5167-1. It shall be installed between the connecting duct and the exhaust fan to determine the volume flow rate of gases passing through the smoke control damper or fire damper under test. This shall be done at elevated temperature, unless a condenser is used. The volume flow results shall be expressed at 20 °C. The measuring device shall be capable of measuring to an accuracy of ± 5 %. Regardless of whether vertical or horizontal smoke control damper or fire dampers are being tested, the volume flow measuring station shall always be used in a horizontal direction.

4.4 Plenum for High Operating Temperature (HOT) test

A steel plenum box shall be mounted on the non fire side of the smoke control damper over the whole face area. This is shown in Figure 18. It shall extend out from the standard supporting construction (wall) by 50 mm or past the edge of any blades that will pass beyond the supporting construction when opening by 50 mm. The box shall have an observation hole in the face opposite the damper blades of 50 mm diameter.

4.5 Cycling equipment

Full information on the equipment needed to perform the cycling tests is shown in Annex A. In addition the following shall be considered.

Equipment shall be required to control a supply to allow the smoke control damper actuator to be cycled. This equipment shall be able to provide the nominal operating power/supply less 10