



# SLOVENSKI STANDARD SIST EN IEC 60255-1:2023

01-maj-2023

---

## Merilni releji in zaščitna oprema - 1. del: Skupne zahteve

Measuring relays and protection equipment - Part 1: Common requirements

Messrelais und Schutzeinrichtungen - Teil 1: Allgemeine Anforderungen

Relais de mesure et dispositifs de protection - Partie 1: Prescriptions communes

Ta slovenski standard je istoveten z: **EN IEC 60255-1:2023**

<https://standards.iteh.ai/catalog/standards/sist/d5d51a70-32a7-485a-831e-7fd8329500e1/sist-en-iec-60255-1-2023>

### ICS:

29.120.70      Releji                                      Relays

**SIST EN IEC 60255-1:2023**                                      **en**



EUROPEAN STANDARD

EN IEC 60255-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

January 2023

ICS 29.120.70

Supersedes EN 60255-1:2010

English Version

## Measuring relays and protection equipment - Part 1: Common requirements (IEC 60255-1:2022)

Relais de mesure et dispositifs de protection - Partie 1:  
Exigences communes  
(IEC 60255-1:2022)

Messrelais und Schutzeinrichtungen - Teil 1: Allgemeine  
Anforderungen  
(IEC 60255-1:2022)

This European Standard was approved by CENELEC on 2023-01-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

**EN IEC 60255-1:2023 (E)****European foreword**

The text of document 95/513/FDIS, future edition 2 of IEC 60255-1, prepared by IEC/TC 95 "Measuring relays and protection equipment" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60255-1:2023.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2023-10-19 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2026-01-19 document have to be withdrawn

This document supersedes EN 60255-1:2010 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

**Endorsement notice**

The text of the International Standard IEC 60255-1:2022 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 60664-1	NOTE Harmonized as EN IEC 60664-1
IEC 60068-2-5	NOTE Harmonized as EN IEC 60068-2-5
IEC 60068-2-10	NOTE Harmonized as EN 60068-2-10
IEC 60068-2-42	NOTE Harmonized as EN 60068-2-42
IEC 60068-2-43	NOTE Harmonized as EN 60068-2-43
IEC 60068-2-52	NOTE Harmonized as EN IEC 60068-2-52
IEC 60068-2-60	NOTE Harmonized as EN 60068-2-60
IEC 60068-2-68	NOTE Harmonized as EN 60068-2-68
IEC 60529	NOTE Harmonized as EN 60529
IEC 61869-6:2016	NOTE Harmonized as EN 61869-6:2016 (not modified)
IEC 62443-4-2	NOTE Harmonized as EN IEC 62443-4-2
IEC 62351 (series)	NOTE Harmonized as EN 62351 (series)
ISO/IEC 27019	NOTE Harmonized as EN ISO/IEC 27019
IEC 61869-9	NOTE Harmonized as EN IEC 61869-9

## Annex A (normative)

### Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: [www.cenelec.eu](http://www.cenelec.eu).

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60068-2-1	-	Environmental testing - Part 2-1: Tests - Test A: Cold	EN 60068-2-1	-
IEC 60068-2-2	-	Environmental testing - Part 2-2: Tests - Test B: Dry heat	EN 60068-2-2	-
IEC 60068-2-14	-	Environmental testing - Part 2-14: Tests - Test N: Change of temperature	EN 60068-2-14	-
IEC 60068-2-30	-	Environmental testing - Part 2-30: Tests - Test Db: Damp heat, cyclic (12 h + 12 h cycle)	EN 60068-2-30	-
IEC 60068-2-78	-	Environmental testing - Part 2-78: Tests - Test Cab: Damp heat, steady state	EN 60068-2-78	-
IEC 60255-21-1	-	Electrical relays - Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment - Section One: Vibration tests (sinusoidal)	EN 60255-21-1	-
IEC 60255-21-2	-	Electrical relays - Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment - Section Two: Shock and bump tests	EN 60255-21-2	-
IEC 60255-21-3	-	Electrical relays - Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment - Section 3: Seismic tests	EN 60255-21-3	-
IEC 60255-26	-	Measuring relays and protection equipment - Part 26: Electromagnetic compatibility requirements	EN 60255-26	-
IEC 60255-27	-	Measuring relays and protection equipment - Part 27: Product safety requirements	EN 60255-27	-
IEC 60255-1XX	series	Measuring relays and protection equipment - Part 1XX: Functional requirements	EN 60255-1XX	series

**EN IEC 60255-1:2023 (E)**

IEC 60688	-	Electrical measuring transducers for converting AC and DC electrical quantities to analogue or digital signals	-
IEC 61810-1	-	Electromechanical elementary relays - Part 1: General and safety requirements	-
IEC 61869-2	-	Instrument transformers - Part 2: Additional requirements for current transformers	-
IEC 61869-3	-	Instrument transformers - Part 3: Additional requirements for inductive voltage transformers	-
IEC 61869-5	-	Instrument transformers - Part 5: Additional requirements for capacitor voltage transformers	-
IEC 61869-10	-	Instrument transformers - Part 10: Additional requirements for low-power passive current transformers	EN IEC 61869-10 -
IEC 61869-11	-	Instrument transformers - Part 11: Additional requirements for low-power passive voltage transformers	EN IEC 61869-11 -

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN IEC 60255-1:2023](https://standards.iteh.ai/catalog/standards/sist/d5d51a70-32a7-485a-831e-7fd8329500e1/sist-en-iec-60255-1-2023)

<https://standards.iteh.ai/catalog/standards/sist/d5d51a70-32a7-485a-831e-7fd8329500e1/sist-en-iec-60255-1-2023>



IEC 60255-1

Edition 2.0 2022-12

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

**Measuring relays and protection equipment –  
Part 1: Common requirements**

**Relais de mesure et dispositifs de protection –  
Partie 1: Exigences communes**

EN IEC 60255-1:2023  
<https://standards.iteh.ai/catalog/standards/sist/d5d51a70-32a7-485a-831e-7fd8329500c1/sist-en-iec-60255-1-2023>

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

ICS 29.120.70

ISBN 978-2-8322-6120-0

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references .....	8
3 Terms, definitions and abbreviated terms .....	9
3.1 Terms and definitions.....	9
3.2 Abbreviated terms.....	15
4 Environmental conditions.....	15
4.1 General.....	15
4.2 Normal environmental conditions .....	16
4.3 Special environmental conditions .....	16
4.4 Environmental storage conditions .....	16
4.5 Transport conditions .....	16
5 Ratings.....	16
5.1 General.....	16
5.2 Rated voltage .....	17
5.2.1 Input energizing voltage.....	17
5.2.2 Auxiliary power supply port energizing voltage.....	17
5.2.3 Rated insulation voltage .....	17
5.3 Rated current – Input energizing current .....	17
5.3.1 Primary relay .....	17
5.3.2 Secondary relay.....	17
5.4 Binary input and output port.....	18
5.4.1 Binary input port.....	18
5.4.2 Binary output port.....	18
5.5 Transducer analogue input and output port.....	19
5.5.1 Transducer analogue input port .....	19
5.5.2 Transducer analogue output port .....	19
5.6 Frequency.....	19
5.6.1 Rated frequency .....	19
5.6.2 Frequency operating range .....	19
5.7 Rated burden .....	19
5.8 Rated ambient temperature range.....	20
6 Design and construction .....	20
6.1 Marking.....	20
6.2 Dimensions.....	20
6.3 Enclosure protection .....	20
6.4 Product safety requirements .....	20
6.5 Functional performance requirements .....	20
6.5.1 General .....	20
6.5.2 Intrinsic accuracy.....	21
6.5.3 Operating accuracy.....	22
6.5.4 Performance under system conditions .....	22
6.5.5 Performance of multifunctional protection equipment .....	22
6.5.6 Internal user programmable logic.....	22
6.6 Communication protocols.....	22



6.7	Cybersecurity.....	22
6.8	Binary input and output port.....	23
6.8.1	Binary input port.....	23
6.8.2	Binary output port.....	23
6.9	Transducer analogue input and output port.....	23
6.9.1	Transducer analogue input port.....	23
6.9.2	Transducer analogue output port.....	23
6.10	Input circuit for measurement quantities.....	23
6.10.1	Analogue voltage port.....	23
6.10.2	Analogue current port.....	23
6.10.3	Communication port.....	24
6.11	Binary output performance (mechanical and static).....	24
6.12	Climatic performance.....	24
6.12.1	General.....	24
6.12.2	Verification procedure.....	24
6.12.3	Climatic environmental tests.....	25
6.13	Mechanical requirements.....	29
6.13.1	Vibration response and endurance (sinusoidal).....	29
6.13.2	Shock response, shock withstand and bump.....	29
6.13.3	Seismic risk.....	29
6.14	Pollution.....	29
6.15	Electromagnetic compatibility (EMC).....	29
7	Tests.....	29
7.1	Test reference conditions.....	29
7.2	Test overview.....	30
7.3	Burden measurements.....	32
7.3.1	Burden for analogue voltage inputs.....	32
7.3.2	Burden for analogue current inputs.....	32
7.3.3	Burden for AC power supply.....	32
7.3.4	Burden for DC power supply.....	32
7.3.5	Burden for binary input.....	33
7.4	Type test report content.....	33
8	Marking, labelling and packaging.....	34
9	Product documentation and technical data.....	34
Annex A	(normative) Type testing guidelines.....	35
A.1	General.....	35
A.2	Protection setting.....	35
A.2.1	Introductory remark.....	35
A.2.2	Test philosophy.....	35
A.2.3	Overcurrent and undercurrent.....	36
A.2.4	Overvoltage and undervoltage.....	37
A.2.5	Over frequency and under frequency.....	38
A.2.6	Functions set around current, voltage and frequency.....	38
A.2.7	Other functions.....	39
Annex B	(informative) Environmental operating locations.....	40
B.1	Operating environment.....	40
B.2	Operating conditions.....	40
	Bibliography.....	44

Figure 1 – Ports for measuring relays and protection equipment .....	13
Figure 2 – Binary output parameters .....	19
Figure A.1 – Settings selection criteria .....	36
Table 1 – Normal environmental conditions .....	16
Table 2 – Contact performance requirements .....	18
Table 3 – Hot and cold temperatures .....	20
Table 4 – Dry heat test – Operational .....	25
Table 5 – Cold test – Operational .....	26
Table 6 – Dry heat test, storage temperature .....	26
Table 7 – Cold test, storage temperature .....	27
Table 8 – Change of temperature test .....	27
Table 9 – Damp heat steady state test .....	28
Table 10 – Cyclic temperature with humidity test .....	28
Table 11 – Test reference conditions .....	30
Table 12 – Test overview .....	31
Table B.1 – Operating locations .....	40
Table B.2 – Climatic conditions .....	41
Table B.3 – Mechanical conditions .....	41
Table B.4 – EMC conditions .....	42
Table B.5 – Chemically active substance conditions .....	42
Table B.6 – Mechanically active substance conditions .....	42
Table B.7 – Biological conditions .....	43

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**MEASURING RELAYS AND PROTECTION EQUIPMENT –****Part 1: Common requirements**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60255-1 has been prepared by IEC technical committee 95: Measuring relays and protection equipment. It is an International Standard.

This second edition cancels and replaces the first edition published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) scope of document clarified;
- b) merging units and communications as an integral part of the protection added;
- c) binary output clarification expanded;
- d) environmental operating conditions added (Annex B);
- e) test reference conditions added;
- f) multiple changes to improve understanding across most clauses;
- g) derating by manufacturer added;

- h) safety and EMC tests removed from document and referenced only;
- i) relay setting and type test guidelines modified (Annex A)
- j) battery monitor port and low power instrument transformers added.

The text of this International Standard is based on the following documents:

Draft	Report on voting
95/513/FDIS	95/521/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/publications](http://www.iec.ch/publications).

A list of all parts in the IEC 60255 series, published under the general title *Measuring relays and protection equipment*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## INTRODUCTION

The following explains the numbering of documents falling under the responsibility of TC 95:

The numbering of documents follows the following principle:

- common standards start with IEC 60255–XX;
- protection functional standards fall into IEC the 60255-1XX series.

The IEC 60255 series consists of the following parts:

a) Common standards:

Part 1: Common requirements

Part 21: Vibration, shock, bump and seismic tests

Part 24: Common format for transient data exchange (COMTRADE) for power systems

Part 26: Electromagnetic compatibility requirements

Part 27: Product safety requirements

b) Protection functional standards:

Part 1XX: Functional requirements

NOTE The last two digits of the part of the proposed functional standard new numbering correspond to function numbers as established in IEEE Std C37.2™-2008 [3]<sup>1</sup>.

(standards.iteh.ai)

[SIST EN IEC 60255-1:2023](https://standards.iteh.ai/catalog/standards/sist/d5d51a70-32a7-485a-831e-7fd8329500e1/sist-en-iec-60255-1-2023)

<https://standards.iteh.ai/catalog/standards/sist/d5d51a70-32a7-485a-831e-7fd8329500e1/sist-en-iec-60255-1-2023>

---

<sup>1</sup> Numbers in square brackets refer to the Bibliography.

# MEASURING RELAYS AND PROTECTION EQUIPMENT –

## Part 1: Common requirements

### 1 Scope

This part of IEC 60255 specifies common rules and requirements applicable to measuring relays and protection equipment, including any combination of equipment to form a distributed protection scheme for power system protection such as control, monitoring and process interface equipment, to obtain uniformity of requirements and tests. This document covers the main technologies in use today; other emerging technologies present specific EMC and safety issues but the philosophy in this document will be applied.

All measuring relays and protection equipment used for protection within the power system environment are covered by this document. Other documents in this series can define their own requirements which in such cases take precedence. The typical locations for measuring relays and protection equipment are where protection of electrical equipment is required: generally power stations, substations and industrial locations.

Measuring relays and protection equipment installed in special applications (marine, railways, aerospace, explosive atmospheres, computer centres, etc.) could be enhanced by additional requirements required by that application.

### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-1, *Environmental testing – Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-14, *Environmental testing – Part 2-14: Tests – Test N: Change of temperature*

IEC 60068-2-30, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60068-2-78, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state*

IEC 60255-21-1, *Electrical relays – Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment – Section One: Vibration tests (sinusoidal)*

IEC 60255-21-2, *Electrical relays – Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment – Section Two: Shock and bump tests*

IEC 60255-21-3, *Electrical relays – Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment – Section 3: Seismic tests*

IEC 60255-26, *Measuring relays and protection equipment – Part 26: Electromagnetic compatibility requirements*

IEC 60255-27, *Measuring relays and protection equipment – Part 27: Product safety requirements*

IEC 60255-1XX (all parts), *Measuring relays and protection equipment – Part 1XX: Functional requirements*

IEC 60688, *Electrical measuring transducers for converting AC and DC electrical quantities to analogue or digital signals*

IEC 61810-1, *Electromechanical elementary relays – Part 1: General and safety requirements*

IEC 61869-2, *Instrument transformers – Part 2: Additional requirements for current transformers*

IEC 61869-3, *Instrument transformers – Part 3: Additional requirements for inductive voltage transformers*

IEC 61869-5, *Instrument transformers – Part 5: Additional requirements for capacitor voltage transformers*

IEC 61869-10, *Instrument transformers – Part 10: Additional requirements for low-power passive current transformers*

IEC 61869-11, *Instrument transformers – Part 11: Additional requirements for low-power passive voltage transformers*

### 3 Terms, definitions and abbreviated terms

#### 3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

##### 3.1.1

##### **absolute error**

difference between a measured value and its declared value

[SOURCE: IEC 60050-447:2020 [5], 447-08-01]

##### 3.1.2

##### **analogue input port**

port intended for current or voltage input whose values are directly proportional to physical measured quantities, i.e. transducer input (measuring temperature, light, etc.)

##### 3.1.3

##### **analogue output port**

port that generates an analogue output signal to drive actuators, analogue panel meters, etc.

Note 1 to entry: Typically a current or voltage less than or equal to 20 mA or 10 V DC respectively.