



SLOVENSKI STANDARD

SIST EN 13480-5:2018

01-januar-2018

Nadomešča:

SIST EN 13480-5:2012

SIST EN 13480-5:2012/A1:2013

SIST EN 13480-5:2012/A2:2017

SIST EN 13480-5:2012/A3:2017

Kovinski industrijski cevovodi - 5. del: Pregled in preskušanje

Metallic industrial piping - Part 5: Inspection and testing

Metallische industrielle Rohrleitungen - Teil 5: Prüfung

Tuyauteries industrielles métalliques - Partie 5: Inspection et contrôle

Ta slovenski standard je istoveten z: **EN 13480-5:2017**

ICS:

23.040.10	Železne in jeklene cevi	Iron and steel pipes
77.140.75	Jeklene cevi in cevni profili za posebne namene	Steel pipes and tubes for specific use

SIST EN 13480-5:2018

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 13480-5:2018

<https://standards.iteh.ai/catalog/standards/sist/8425d844-5437-432c-af8b-1ee219c1ab46/sist-en-13480-5-2018>

EUROPEAN STANDARD

EN 13480-5

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2017

ICS 23.040.01

Supersedes EN 13480-5:2012

English Version

Metallic industrial piping - Part 5: Inspection and testing

Tuyauteries industrielles métalliques - Partie 5 :
Inspection et contrôle

Metallische industrielle Rohrleitungen - Teil 5: Prüfung

This European Standard was approved by CEN on 21 June 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

[SIST EN 13480-5:2018](https://standards.iteh.ai/catalog/standards/sist/8425d844-5437-432c-af8b-1ee219c1ab46/sist-en-13480-5-2018)

<https://standards.iteh.ai/catalog/standards/sist/8425d844-5437-432c-af8b-1ee219c1ab46/sist-en-13480-5-2018>



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

	Page
European foreword.....	4
1 Scope.....	6
2 Normative references.....	6
3 Terms and definitions.....	7
4 Symbols and abbreviations.....	7
5 Determination of inspection and testing requirements.....	7
5.1 General.....	7
5.2 Classification of piping.....	7
6 Design review.....	7
7 In-process inspection and testing.....	8
7.1 General.....	8
7.2 Materials and formed pressure retaining parts.....	8
7.2.1 General.....	8
7.2.2 Verification of material.....	8
7.2.3 Verification of formed pressure retaining parts.....	8
7.2.4 Non-destructive testing of formed parts.....	8
7.2.5 Destructive testing of formed parts.....	12
7.3 Welding.....	12
7.3.1 Review of welding documents.....	12
7.3.2 Inspection before welding.....	12
7.3.3 Testing and inspection during welding.....	13
7.3.4 Inspection after welding.....	13
7.3.5 Inspection of built up pipe ends.....	13
7.4 Heat treatment.....	13
8 Non-destructive testing of welds.....	13
8.1 Application of NDT.....	13
8.1.1 General.....	13
8.1.2 Examination of weld quality by sample inspection.....	14
8.1.3 Imperfections revealed by sample inspection.....	14
8.2 Circumferential butt, branch, fillet and seal welds.....	15
8.2.1 Extent of testing.....	15
8.2.2 Dissimilar metal joints.....	17
8.2.3 Transverse cracks.....	17
8.3 Longitudinal welds.....	17
8.4 Testing methods.....	17
8.4.1 General.....	17
8.4.2 Quality level.....	17
8.4.3 Personnel qualification.....	18
8.4.4 Selection of NDT methods and testing techniques.....	18
8.4.5 Testing techniques and acceptance levels.....	19
8.5 Reports.....	19

8.6	Weld repairs	19
9	Final assessment and documentation	19
9.1	General	19
9.2	Final inspection	19
9.2.1	General	19
9.2.2	Visual inspection before the proof test.....	19
9.2.3	Visual inspection after the proof test.....	20
9.2.4	Review of the manufacturing documents	20
9.3	Proof test.....	20
9.3.1	General	20
9.3.2	Hydrostatic pressure test	20
9.3.3	Pneumatic pressure test	23
9.3.4	Other tests	25
9.3.5	Documentation of the proof test	25
9.4	Documentation	25
9.4.1	Final documentation package	25
9.4.2	Design and manufacturing documentation package	27
9.4.3	Operating instructions.....	27
9.4.4	Documentation for the purchaser	27
10	Declaration.....	27
Annex A (informative)	Declaration of compliance with EN 13480.....	28
A.1	Declaration for design.....	28
A.2	Declaration for fabrication, installation and testing	29
A.3	Declaration for compliance for piping with EN 13480.....	30
Annex Y (informative)	History of EN 13480-5.....	31
Y.1	Differences between EN 13480-5:2012 and EN 13480-5:2017.....	31
Annex ZA (informative)	Relationship between this European Standard and the Essential Requirements of EU Directive 2014/68/EU aimed to be covered	33
Bibliography	34

European foreword

This document (EN 13480-5:2017) has been prepared by Technical Committee CEN/TC 267 “Industrial piping and pipelines”, the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by December 2017, and conflicting national standards shall be withdrawn at the latest by December 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this document.

This European Standard EN 13480 for metallic industrial piping consists of eight interdependent and not dissociable Parts which are:

— *Part 1: General;*

— *Part 2: Materials;* <https://standards.iteh.ai/catalog/standards/sist/8425d844-5437-432c-af8b-1ee219c1ab46/sist-en-13480-5-2018>

— *Part 3: Design and calculation;*

— *Part 4: Fabrication and installation;*

— *Part 5: Inspection and testing;*

— *Part 6: Additional requirements for buried piping;*

— *CEN/TR 13480-7, Guidance on the use of conformity assessment procedures;*

— *Part 8: Additional requirements for aluminium and aluminium alloy piping.*

Although these Parts may be obtained separately, it should be recognised that the Parts are inter-dependant. As such the manufacture of metallic industrial piping requires the application of all the relevant Parts in order for the requirements of the Standard to be satisfactorily fulfilled.

This European Standard will be maintained by a Maintenance MHD working group whose scope of working is limited to corrections and interpretations related to EN 13480.

The contact to submit queries can be found at <http://www.unm.fr> (en13480@unm.fr). A form for submitting questions can be downloaded from the link to the MHD website. After subject experts have agreed an answer, the answer will be communicated to the questioner. Corrected pages will be given specific issue number and issued by CEN according to CEN Rules. Interpretation sheets will be posted on the website of the MHD.

This document supersedes EN 13480-5:2012. This new edition incorporates the Amendments which have been approved previously by CEN members, and the corrected pages up to Issue 5 without any further technical change. Annex Y provides details of significant technical changes between this European Standard and the previous edition.

Amendments to this new edition may be issued from time to time and then used immediately as alternatives to rules contained herein.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

[SIST EN 13480-5:2018](#)

<https://standards.iteh.ai/catalog/standards/sist/8425d844-5437-432c-af8b-1ee219c1ab46/sist-en-13480-5-2018>

EN 13480-5:2017 (E) Issue 1 (2017-06)

1 Scope

This Part of this European Standard specifies the requirements for inspection and testing of industrial piping as defined in EN 13480-1:2017 to be performed on individual spools or piping systems, including supports, designed in accordance with EN 13480-3:2017 and EN 13480-6:2017 (if applicable), and fabricated and installed in accordance with EN 13480-4:2017.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 13480-1:2017, *Metallic industrial piping — Part 1: General*

EN 13480-2:2017, *Metallic industrial piping — Part 2: Materials*

EN 13480-3:2017, *Metallic industrial piping — Part 3: Design and calculation*

EN 13480-4:2017, *Metallic industrial piping — Part 4: Fabrication and installation*

EN 13480-6:2017, *Metallic industrial piping — Part 6: Additional requirements for buried piping*

EN 14917:2009+A1:2012, *Metal bellows expansion joints for pressure applications*

EN ISO 5817:2014, *Welding — Fusion-welded joints in steel, nickel, titanium and their alloys (beam welding excluded) — Quality levels for imperfections (ISO 5817:2014)*

EN ISO 9712:2012, *Non-destructive testing — Qualification and certification of NDT personnel (ISO 9712:2012)*

EN ISO 10893-5:2011, *Non-destructive testing of steel tubes — Part 5: Magnetic particle inspection of seamless and welded ferromagnetic steel tubes for the detection of surface imperfections (ISO 10893-5:2011)*

EN ISO 17635:2016, *Non-destructive testing of welds — General rules for metallic materials (ISO 17635:2016)*

EN ISO 17640:2010, *Non-destructive testing of welds — Ultrasonic testing — Techniques, testing levels, and assessment (ISO 17640:2010)*

ISO 3057:1998, *Non-destructive testing — Metallographic replica techniques of surface examination*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 13480-1 shall apply.

4 Symbols and abbreviations

For the purposes of this Part of this European Standard, the symbols given in EN 13480-1 apply together with the following abbreviations:

- NDT Non-destructive testing
- MT Magnetic particle testing
- PT Penetrant testing
- RT Radiographic testing
- UT Ultrasonic testing
- VT Visual testing
- PWHT Post-weld heat treatment
- PED Pressure Equipment Directive.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

5 Determination of inspection and testing requirements

[SIST EN 13480-5:2018](https://standards.iteh.ai/catalog/standards/sist/8425d844-5437-432c-af8b-1ee219c1ab46/sist-en-13480-5-2018)

5.1 General <https://standards.iteh.ai/catalog/standards/sist/8425d844-5437-432c-af8b-1ee219c1ab46/sist-en-13480-5-2018>

The manufacturer shall be responsible for the fabrication and the installation, even if this work will be sub-contracted to other fabricators and/or installers.

The fabricator and/or installer shall be responsible for carrying out the inspection and testing including subcontracted NDT (if any) specified in this European Standard, for all piping.

NOTE For guidance on the use of conformity assessment procedures see CEN/TR 13480-7.

5.2 Classification of piping

Industrial piping shall be classified in accordance with EN 13480-1:2017, Table 5.1-1.

NOTE Categories I to III are identical to categories I to III of the Pressure Equipment Directive.

6 Design review

Before fabrication/installation commences, a review of the piping design and its supports shall be performed.

Where design and fabrication are carried out by separate organisations, the piping designer shall prepare a confirmation for the manufacturer that the design is in compliance with the requirements of this European Standard.

EN 13480-5:2017 (E)
Issue 1 (2017-06)

A list of the relevant drawings shall be attached to the confirmation.

Where the design of parts has already been reviewed in accordance with this European Standard, and where an appropriate confirmation is available, a further design review shall not be required.

NOTE For guidance on the use of conformity assessment procedures see CEN/TR 13480-7.

7 In-process inspection and testing

7.1 General

Testing and inspection shall be carried out by personnel qualified for the method used. European Standards, specifications or written procedures (if necessary) shall be available to all testing personnel and inspectors prior to the testing/inspection.

Reports on NDT specified in 7.2.4 and Clause 8 and reports on destructive testing specified in 7.2.5 shall be prepared to demonstrate that all required testing has been carried out and that the results are acceptable.

7.2 Materials and formed pressure retaining parts

7.2.1 General

The testing and inspection specified below shall be restricted to parts formed during the fabrication process, especially induction bending. Formed bought out standardized parts and components shall not be a part of this requirement.

Formed parts shall be subject to appropriate testing in accordance with the fabricators/installers test programme.

7.2.2 Verification of material

A verification shall be performed that materials are in accordance with the specified material standard or purchase order.

7.2.3 Verification of formed pressure retaining parts

It shall be verified that all formed pressure retaining parts comply with the specified shape and dimensional requirements, and have received the specified finish or heat treatment.

7.2.4 Non-destructive testing of formed parts

7.2.4.1 General

All formed parts shall be subject to non-destructive testing. Depending on material, dimensions and type of forming process testing may include:

- a) visual testing;
- b) wall thickness measurements;

- c) dimensional checks (ovality, angle of bend etc.) and tolerances (see EN 13480-4);
- d) hardness tests;
- e) testing for surface imperfections (magnetic particle or penetrant testing);

on formed parts of each component or batch of identical components.

Material, heat treatment conditions, heat treatment lot, degree of deformation shall be considered in the definition of the batch.

Replicas of the surface structure in the tension zone may be required in case of lifetime monitoring for creep range application.

Ultrasonic testing may be performed if specified. Specification shall include area, extent, method and acceptance criteria.

NOTE A customary interpretation of a heat treatment lot is the entire content of a furnace of a single heat treatment.

7.2.4.2 Induction bending

Material surfaces shall be suitable for induction bending. EN ISO 10893-5 specifies surface qualities and acceptance levels. The acceptance levels shall be agreed, considering material, dimensions and service (creep, fatigue).

Induction bends shall be tested according to Table 7.2.4.2-1.

Heat treatment shall be done if required by EN 13480-4. Subsequent hardness testing shall be performed on the straight length and within bending zone to verify the homogeneity of annealing.

If no heat treatment is required after forming, hardness testing is required in the bending zone only if specified for service reasons.

Dimensional checks shall include ovality, angle of bend, wall thickness and tolerances (see EN 13480-4).

MT/PT testing shall be performed to verify that the outside surface in the bended zone is free of cracks.

If specified for the component or by Table 7.2.4.2-1, replicas of the surface structure in the tension zone shall be taken on each component or batch of identical components. Replicas shall be made in accordance with ISO 3057.

The material grade, the heat treatment conditions of the material, the heat treatment lot after bending and the forming conditions shall be considered in the definition of the batch.

Table 7.2.4.2-1 — NDT for induction bends

Material Group (see EN 13480-2)	VT	Dimensional check	Hardness testing	MT/PT	Replicas
1.1, 1.2, 1.3, 8, 9	c	c	—	b5e	—
1.4, 3, 5.3, 5.4, 6	c	c	c	cf	—
2	c	c	c	b5e	—
4	c	c	c	ce	—
5.1, 5.2	c	c	b10e	b10e	—
10	c	c	—	cf	yes
NOTE b5e – 5 % of batch on extrados c – testing per component cf – component forming area b10e – 10 % of batch on extrados ce – testing per component extrados					

7.2.4.3 Cold formed pipes

Cold formed pipes shall be tested according to Table 7.2.4.3-1.

Heat treatment shall be done if required by EN 13480-4. Subsequent hardness testing shall be performed on the straight length and within bending zone to verify the homogeneity of annealing.

If no heat treatment is required after forming, hardness testing is required in the bending zone only if specified by the purchaser for service reasons.

<https://standards.iteh.ai/catalog/standards/sist/8425d844-5437-432c-af8b->

Dimensional checks shall be performed after tooling of the bending machine and start of production to the same extent as specified for MT/PT (see Table 7.2.4.2-1) and shall include ovality, angle of bend and tolerances (see EN 13480-4).

Wall thickness measurement at the extrados is required for all cold formed pipes with $r_m \leq 1,3 d_0$.

MT/PT testing shall be performed to verify that the outside surface in the bended zone is free of cracks.