



SLOVENSKI STANDARD
SIST EN 16475-3:2016/oprA1:2018
01-januar-2018

Dimovodne naprave - Oprema - 3. del: Regulatorji vleka, lopute z motornim pogonom in kombinirane lopute za sekundarni zrak - Zahteve in preskusne metode

Chimneys - Accessories - Part 3: Draught regulators, standstill opening devices and combined secondary air devices - Requirements and test methods

Abgasanlagen - Zubehörteile - Teil 3: Selbsttätig arbeitende, zwangsgesteuerte und kombinierte Nebenluftvorrichtungen - Anforderungen und Prüfverfahren

Conduits de fumée - Accessoires - Partie 3: Régulateurs de tirage, dispositifs d'ouverture pour période d'arrêt et dispositifs combinés d'air secondaire - Exigences et méthodes d'essai

Ta slovenski standard je istoveten z: EN 16475-3:2016/prA1

ICS:

91.060.40 Dimniki, jaški, kanali Chimneys, shafts, ducts

SIST EN 16475-3:2016/oprA1:2018 en,fr,de

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

DRAFT
EN 16475-3:2016
prA1

November 2017

ICS 91.060.40

English Version

Chimneys - Accessories - Part 3: Draught regulators, standstill opening devices and combined secondary air devices - Requirements and test methods

Conduits de fumée - Accessoires - Partie 3: Régulateurs
de tirage, dispositifs d'ouverture pour période d'arrêt
et dispositifs combinés d'air secondaire - Exigences et
méthodes d'essai

Abgasanlagen - Zubehörteile - Teil 3: Selbsttätig
arbeitende, zwangsgesteuerte und kombinierte
Nebenluftvorrichtungen - Anforderungen und
Prüfverfahren

This draft amendment is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 166.

This draft amendment A1, if approved, will modify the European Standard EN 16475-3:2016. If this draft becomes an amendment, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for inclusion of this amendment into the relevant national standard without any alteration.

This draft amendment was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

European foreword.....	3
1 Modification to 4.4.1 (Reaction to fire)	4
2 Modification to 4.4.2.2	4
3 Modification to 4.4.2.3	4

European foreword

This document (EN 16475-3:2016/prA1:2017) has been prepared by Technical Committee CEN/TC 166 "Chimneys", the secretariat of which is held by ASI.

This document is currently submitted to the CEN Enquiry.

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of EN 16475-3:2016.

EN 16475-3:2016/prA1:2017 (E)**1 Modification to 4.4.1 (Reaction to fire)**

Replace the whole text of the subclause with the following text:

“The reaction to fire for draught regulators, standstill opening devices and combined secondary air devices should be declared:

- after testing in accordance with EN 13501-1; or
- by classification without further testing for materials which are by default classified A1.

NOTE Classified without further testing or materials which are by default classified A1 (see Commission Decision [96/603/EC (2)]) no further testing needed.”

2 Modification to 4.4.2.2

At the end of Clause 4.4.2.2, add the following text:

“ The maximum surface temperature of combustible materials adjacent to the draft regulator, and if appropriate the standstill opening device, shall not exceed 85 °C during the heat stress test when related to an ambient temperature of 20 °C at the declared distance.”

3 Modification to 4.4.2.3

At the end of the first paragraph in Clause 4.4.2.3 add the following text:

“The maximum surface temperature of combustible materials adjacent to the draft regulator shall not exceed 100 °C during the sootfire resistance test when related to an ambient temperature of 20 °C at the declared distance.”