



SLOVENSKI STANDARD

SIST EN 14972-7:2023

01-november-2023

Vgrajeni gasilni sistemi - Sistemi s pršečo vodo - 7. del: Protokol preskušanja sistemov s samodejnimi šobami za komercialne prostore z nizko stopnjo nevarnosti

Fixed firefighting systems - Water mist systems - Part 7: Test protocol for commercial low hazard occupancies for automatic nozzle systems

Ortsfeste Brandbekämpfungsanlagen - Wassernebelsysteme - Teil 7: Prüfprotokoll für kommerzielle Belegung geringer Gefährdung für automatische Düsensysteme

Installations fixes de lutte contre l'incendie - Systèmes à brouillard d'eau - Partie 7 : Protocole d'essai des systèmes à buses automatiques pour locaux commerciaux à risque faible

[SIST EN 14972-7:2023](#)

<https://standards.iteh.ai> Ta slovenski standard je istoveten z: [6280 EN 14972-7:2023 49e6d7d406bf/sist-en-14972-7-2023](#)

ICS:

13.220.10 Gašenje požara Fire-fighting

SIST EN 14972-7:2023 en,fr,de

**EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM**

EN 14972-7

July 2023

ICS 13.220.20

English Version

**Fixed firefighting systems - Water mist systems - Part 7:
Test protocol for commercial low hazard occupancies for
automatic nozzle systems**

Installations fixes de lutte contre l'incendie - Systèmes
à brouillard d'eau - Partie 7 : Protocole d'essai des
systèmes à buses automatiques pour locaux
commerciaux à risque faible

Ortsfeste Brandbekämpfungsanlagen -
Wassernebelssysteme - Teil 7: Prüfprotokoll für
kommerzielle Belegung geringer Gefährdung für
automatische Düsenhydrate

This European Standard was approved by CEN on 9 July 2023.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.

[SIST EN 14972-7:2023](#)

<https://standards.iteh.ai/catalog/standards/sist/146280e8-6fb6-4088-952d-49e6d7d406bf/sist-en-14972-7-2023>



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

	Page
European foreword	3
1 Scope.....	5
2 Normative references.....	5
3 Terms and definitions.....	5
4 General requirements.....	5
4.1 General.....	5
4.2 Categories	6
4.2.1 Category I system.....	6
4.2.2 Category II system	6
4.2.3 Category III system.....	6
5 Fuel packages	6
5.1 Fuel package 1 (bunk beds)	6
5.2 Fuel package 2 (corner crib and simulated furniture)	6
5.3 Fuel package 3 (sofas)	6
5.4 Fuel package 4 (simulated work station).....	6
6 Test arrangement	9
6.1 Test room A (small compartment)	9
6.2 Test room B (large compartment).....	9
6.3 Test room C (open space)	9
6.4 Test room D: open space	9
7 Test equipment requirements	9
8 Test conditions	11
9 Fire tests.....	12
9.1 Procedure	12
9.2 Small compartment with bunk beds	13
9.3 Large compartment with corner crib and simulated furniture	13
9.4 Open space with sofas under one nozzle.....	14
9.5 Open space with sofas between two nozzles.....	14
9.6 Open space with sofas between four nozzles.....	14
9.7 Open space with simulated work station under one nozzle	14
9.8 Open space with simulated work station between two nozzles	14
9.9 Open space with simulated work station between four nozzles	15
10 Pass/fail criteria.....	15
11 Test report.....	16
Bibliography	17

European foreword

This document (EN 14972-7:2023) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by January 2024, and conflicting national standards shall be withdrawn at the latest by January 2024.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

The EN 14972 series, *Fixed firefighting systems — Water mist systems*, consists of the following parts:

- *Part 1: Design, installation, inspection and maintenance*
- *Part 2: Test protocol for shopping areas for automatic nozzle systems*
- *Part 3: Test protocol for office, school class rooms and hotel for automatic nozzle systems*
- *Part 4: Test protocol for non-storage occupancies for automatic nozzle systems*
- *Part 5: Test protocol for car garages for automatic nozzle systems*
- *Part 6: Test protocol for false floors and false ceilings for automatic nozzle systems*
- *Part 7: Test protocol for commercial low hazard occupancies for automatic nozzle systems*
- *Part 8: Test protocol for machinery in enclosures exceeding 260 m³ for open nozzle systems*
- *Part 9: Test protocol for machinery in enclosures not exceeding 260 m³ for open nozzle systems*
- *Part 10: Test protocol for atrium protection with sidewall nozzles for open nozzle systems*
- *Part 11: Test protocol for cable tunnels for open nozzle systems*
- *Part 12: Test protocol for commercial deep fat cooking fryers for open nozzle systems*
- *Part 13: Test protocol for wet benches and other similar processing equipment for open nozzle systems*
- *Part 14: Test protocol for combustion turbines in enclosures exceeding 260 m³ for open nozzle systems*
- *Part 15: Test protocol for combustion turbines in enclosures not exceeding 260 m³ for open nozzle systems*
- *Part 16: Test protocol for industrial oil cookers for open nozzle systems*
- *Part 17: Test protocol for residential occupancies for automatic nozzle systems*

NOTE This list includes standards that are in preparation and other standards can be added. For current status of published standards refer to www.cencenelec.eu.

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

EN 14972-7:2023 (E)

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[SIST EN 14972-7:2023](#)

<https://standards.iteh.ai/catalog/standards/sist/146280e8-6fb6-4088-952d-49e6d7d406bf/sist-en-14972-7-2023>