

SLOVENSKI STANDARD oSIST prEN 17432:2019

01-december-2019

Samostojne hladilne enote za male hladilnice - Razvrstitev, tehnične lastnosti in preskus porabe energije

Packaged refrigerating units for walk-in cold rooms - Classification, performance and energy consumption testing

Kälteaggregate für begehbare Kühlräume - Klassifikation, Prüfung der Leistung und des Energieverbrauchs **iTeh STANDARD PREVIEW**

Groupes frigorifiques prêts à monter pour chambres froides - Classification, performance et essai de consommation d'énergie

<u>kSIST FprEN 17432:2021</u>

https://standards.iteh.ai/catalog/standards/sist/2603ce09-72b4-4bc5-9d6d-

Ta slovenski standard je istoveten 2.391/ksiprEN 17432021

<u>ICS:</u>

27.200 Hladilna tehnologija

Refrigerating technology

oSIST prEN 17432:2019

en,fr,de



iTeh STANDARD PREVIEW (standards.iteh.ai)

kSIST FprEN 17432:2021 https://standards.iteh.ai/catalog/standards/sist/2603ce09-72b4-4bc5-9d6deadddaaf739f/ksist-fpren-17432-2021



EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

DRAFT prEN 17432

October 2019

ICS 27.200

English Version

Packaged refrigerating units for walk-in cold rooms -Classification, performance and energy consumption testing

Groupes frigorifiques prêts à monter pour chambres froides - Classification, performance et essai de consommation d'énergie Kälteaggregate für begehbare Kühlräume -Klassifikation, Prüfung der Leistung und des Energieverbrauchs

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 44.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Heland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2019 CEN All rights of exploitation in any form and by any means reserved worldwide for CEN national Members.

Ref. No. prEN 17432:2019 E

oSIST prEN 17432:2019

prEN 17432:2019 (E)

Contents

Europ	ean foreword	3
Introd	uction	4
1	Scope	5
2	Normative references	5
3	Terms and definitions	5
4	Symbols	8
5	Classification	9
6 6.1 6.2 6.3	Test conditions General Testing conditions Measurement uncertainty	9 9
7 7.1 7.2	Test setup General Calorimeter room	11 11 11
7.3	Arrangement of test and measurement equipment	12
7.4 7.5	Measurement criteria	12 13
7.6	Measurement criteria	
8 8.1 8.2	Performance Testing <u>kSIST.EprEN.17432.2021</u> General	14
8.3	Cooling Capacity tests	
8.3.1 8.3.2	Steady-state conditions Data acquisition	
8.3.3	Heat recovery capacity	15
8.4 8.5	Calculation of the cooling capacity Measuring of total electric power consumption	
o.5 9	Test results	
10	Test report	18
10.1	General information	18
10.2	Information on the type plate	
Annex	A (informative) Examples for the test setup	
A.1	General	20
A.2	Examples	20
Bibliog	graphy	23

European foreword

This document (prEN 17432:2019) has been prepared by Technical Committee CEN/TC 44 "Commercial and Professional Refrigerating Appliances and Systems, Performance and Energy Consumption", the secretariat of which is held by UNI.

This document is currently submitted to the CEN Enquiry.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

iTeh STANDARD PREVIEW (standards.iteh.ai)

kSIST FprEN 17432:2021 https://standards.iteh.ai/catalog/standards/sist/2603ce09-72b4-4bc5-9d6deadddaaf739f/ksist-fpren-17432-2021

prEN 17432:2019 (E)

Introduction

This document was developed in order to provide a suitable method of performance testing of packaged refrigerating unit for stationary cold room applications.

This is the first edition of this document. It includes testing only in so-called "dry conditions". That means, the evaporator does not show any ice formation during the test. Although it is well-known, that such conditions do not represent the typical situation in the practical use of the packaged refrigerating units, this edition of the document focusses on the description of a test procedure providing reliable test results, which can be used to compare the performance of different models/types of packaged refrigerating unit.

In order to keep the test procedure in this document practically oriented, tests under so-called "wet conditions" as well as taking defrost periods into account will be a future Work Item of the responsible working group. The aim is to integrate such tests in a later revision of this document.

This document reflects the current market situation which shows that only refrigerating units without integrated pump for the heat transfer medium on the exterior heat exchanger are offered.

iTeh STANDARD PREVIEW (standards.iteh.ai)

kSIST FprEN 17432:2021 https://standards.iteh.ai/catalog/standards/sist/2603ce09-72b4-4bc5-9d6deadddaaf739f/ksist-fpren-17432-2021

1 Scope

This document defines classification criteria, test conditions and test procedures for performance testing of packaged refrigerating units for stationary cold room applications. This includes ductless units for cold storage applications at medium temperatures (MT) and low temperatures (LT) in either compact or split designs, fitted with electrically driven compressors, which work according to the vapour compression cycle.

2 Normative references

Not applicable.

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

packaged refrigerating unit

functional unit incorporating a complete factory-made refrigerating system, as defined in EN 378-1, mounted in a suitable frame and/or enclosure, that is fabricated and transported complete, or in two or more sections and in which no refrigerant-containing parts are connected on site other than by isolation valves, such as companion valves, and by interconnecting piping as defined by the manufacturer

iTeh STANDARD PREVIEW

Note 1 to entry: A packaged refrigerating unit incorporates at least one refrigerant circuit, and can incorporate one or more heat transfer circuits.

3.2

kSIST FprEN 17432:2021

compact unit https://standards.iteh.ai/catalog/standards/sist/2603ce09-72b4-4bc5-9d6d-

packaged refrigerating unit, that has been assembled, filled ready for use, and is installed without the need for connecting any refrigerant-containing parts

3.3

split unit

packaged refrigerating unit, comprising one unit providing cooling to the cold room and one unit used for condensing the refrigerant

3.4

factory made

manufactured at a dedicated production location under control of a recognized quality system

Note 1 to entry: Assembling is manufacturing.

[SOURCE: EN 378-1:2016, 3.8.5, modified — The present Note 1 to entry was added.]

3.5

interior heat exchanger

heat exchanger in which liquid refrigerant is vaporized by absorbing heat from the interior heat transfer medium, for the applications regarded here, the interior heat exchanger is usually called 'evaporator'

prEN 17432:2019 (E)

3.6

exterior heat exchanger

heat exchanger in which the refrigerant is cooled down due to heat dissipation by the exterior heat transfer medium, for the applications regarded here, the exterior heat exchanger is usually called 'condenser'

3.7

heat transfer medium

medium (water, air, etc.) which transfers heat without undergoing phase changes

3.8

dry bulb temperature

temperature of air measured by a thermometer exposed to the air but shielded from radiation and moisture

3.9

calorimeter room

insulated test chamber which houses a heating device and the interior heat exchanger

3.10

test chamber

room in which the ambient air can be conditioned and kept in a steady state condition and in which the exterior heat exchanger as well as the calorimeter are located

iTeh STANDARD PREVIEW

Note 1 to entry: See 7.2 for further explanation. (standards.iteh.ai)

3.11

total cooling capacity

kSIST FprEN 17432:2021

heat per unit of time transferred to the unitivia heat transfer/medium-minusbintroduced heat of the fans installed at the interior heat exchanger eadddaaf739fksist-fpren-17432-2021

3.12

latent cooling capacity

heat flow extracted from surrounding air by condensation of water vapour as well as icing, including sub-cooling, of the evaporator surface

3.13

sensible cooling capacity

heat flow extracted from surrounding air by lowering the dry bulb temperature

3.14

total power consumption

average electrical power consumption of a system over time defined by:

- a) power consumption of installed compressor and any power consumption during de-frosting periods;
- b) power consumption of any installed control or safety devices;
- c) power consumption of any integrated device, like fans or pumps, for ensuring heat transfer medium transport within the unit.

3.15

energy efficiency ratio

ratio of total cooling capacity to total power consumption of the unit

3.16

energy efficiency ratio including heat recovery

ratio of total cooling capacity to total power consumption of the unit including recovered heat from the exterior heat exchanger of water-to-air units

3.17

operating limits

limitations in terms of maximum and minimum operating conditions (range of pressure, temperature, voltage, humidity, etc.)

Note 1 to entry: The unit shall work as intended within the operating limits specified by the manufacturer.

3.18

nominal conditions

conditions that define a standard which reveals if a packaged refrigerating unit is working within those defined limits

3.19

standard air conditions

condition of dry air at 20 °C with an air pressure of 101.325 kPa and with a density of 1.204 kg/m³

3.20

(standards.iteh.ai)

support cold

independently working refrigeratingkunit Horcompensate heat losses through the calorimeter room envelope https://standards.iteh.ai/catalog/standards/sist/2603ce09-72b4-4bc5-9d6deadddaaf739f/ksist-fibren-17432-2021

3.21

low temperature

LT

application, at which the packaged refrigerating unit is capable of delivering its nominal cooling capacity at the interior heat exchanger inlet temperature of -20 °C

3.22

medium temperature

MT

application, at which the packaged refrigerating unit is capable of delivering its nominal cooling capacity at the interior heat exchanger inlet temperature of 0 $^{\circ}$ C

prEN 17432:2019 (E)

4 Symbols

Table 1 — Quantities

Symbol	Quantity	Unit	UnitSy mbol
Q_0	Total cooling capacity	Watt	W
$Q_{\it OL}$	Latent cooling capacity	Watt	W
Q_{OS}	Sensible cooling capacity	Watt	W
P_E	Total power consumption	Watt	W
EER	Energy efficiency ratio	_	_
EER _x	Energy efficiency ratio including waste heat	_	_
А	Length of the air inlet of the interior heat exchanger	millimetres	mm
В	Width/Height of the air inlet of the interior heat exchanger	millimetres	mm
q Heat loss	Heat loss during calibration of the calorimeter room	Watt per Kelvin	W/K
P _{Heater}	Total electric power consumption of the heating	Watt	W
T int	Internal temperature of the calorimeter room DPR	Kelvin C	К
T _{out}	Ambient temperature of the test chamberds.iteh.a	Kelvin	К
ΔT	Temperature spread (calibration)	Kelvin	К
T _{out,w}	Temperature of the heat transfer medium (water) at (heat exchanger outlet eadddaaf739f/ksist-fpren-17432-20	PDegree Celsius	°C
T int, w	Temperature of the heat transfer medium (water) at heat exchanger inlet	Degree Celsius	°C
m	mass flow	kilogram per second	kg/s
V	Volume	Cubic metre	m ³
ρ	Density	kilogram per cubic metre	kg/m ³
Q_{Heat}	heating capacity of the heat exchanger	kilowatt	kW
V F	nominal volume flow	Cubic meters per second	m³/s
$\Delta p_{\rm i}$	maximum measured external static pressure difference between water inlet and outlet	Pascal	Р
η	pump efficiency	Percent	%
$Q_{\mathit{Heat,i}}$	total heating capacity of the heating device	Watt	W
$Q_{\it support\ cold}$	cooling capacity of the support cold	Watt	W
ΔT,i	Temperature spread between interior and exterior heat exchanger (measurement)	Kelvin	К

Symbol Description		Value	
Cp	Specific heat capacity of water	4,19 kJ/(kg ⋅ K)	

5 Classification

Refrigerating units are labelled by listing their heat transfer mediums. The heat transfer medium of the exterior heat exchanger (condenser) is listed in the first column, the heat transfer medium of the interior heat exchanger (evaporator) is listed in the second column (see Table 3).

Heat transfer medium		Term
Exterior heat exchanger	Interior heat exchanger	
Air	Air	Air cooled refrigerating unit
Water	Air	Water cooled refrigerating unit
Liquid	Air	Liquid cooled refrigerating unit

Table 3 — Labelling of refrigerating units

6 Test conditions Teh STANDARD PREVIEW 6.1 General (standards.iteh.ai)

The test procedures defined in this document provide methods for determining cooling capacities and electrical power consumption of packaged refrigerating units as well as for determining heat recovery capacities of water-cooled packaged refrigerating units. The tests can be performed under dry conditions inside a calorimeter room, which is placed in a test chamber.

6.2 Testing conditions

The following test procedures are to be conducted under the nominal conditions given in Tables 4, 5 and 6), unless stated otherwise.

		Exterior Heat Exchanger	Interior Heat Exchanger			
		Dry Bulb Temperature at Inlet	Dry Bulb Temperature at Inlet	Rel. Humidity at inlet		
Nominal	LT	32 °C	−20 °C	а		
Conditions for:	МТ	32 °C	0 °C	а		
^a As low, as to prevent icing on the heat exchanger surface.						

Table 4 — Air-to-Air Refrigerating unit – Nominal Dry Conditions

The manufacturer may choose the following additional testing conditions for air-to-air refrigerating units:

— for cold climate: 15 °C for dry bulb temperature at inlet of exterior heat exchanger;