



SLOVENSKI STANDARD

SIST EN 50341-2-9:2019

01-april-2019

Nadomešča:

SIST EN 50341-2-9:2016

Nadzemni električni vodi za izmenične napetosti nad 1 kV - 2-9. del: Nacionalna normativna določila (NNA) za Veliko Britanijo in Severno Irsko (na podlagi EN 50341-1:2012)

Overhead electrical lines exceeding AC 1 kV - Part 2-9: National Normative Aspects (NNA) for Great Britain and Northern Ireland (based on EN 50341-1:2012)

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 50341-2-9:2019](https://standards.iteh.ai/catalog/standards/sist/cf354a3f-73f1-4c4f-867c-844fa7dd9c48/sist-en-50341-2-9-2019)

<https://standards.iteh.ai/catalog/standards/sist/cf354a3f-73f1-4c4f-867c-844fa7dd9c48/sist-en-50341-2-9-2019>

Ta slovenski standard je istoveten z: EN 50341-2-9:2017

ICS:

29.240.20

Daljnovodi

Power transmission and
distribution lines

SIST EN 50341-2-9:2019

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 50341-2-9:2019](https://standards.iteh.ai/catalog/standards/sist/cf354a3f-73f1-4c4f-867c-844fa7dd9c48/sist-en-50341-2-9-2019)

<https://standards.iteh.ai/catalog/standards/sist/cf354a3f-73f1-4c4f-867c-844fa7dd9c48/sist-en-50341-2-9-2019>

EUROPEAN STANDARD

EN 50341-2-9

NORME EUROPÉENNE

EUROPÄISCHE NORM

May 2017

ICS 29.240.20

Supersedes EN 50341-2-9:2015

English Version

Overhead electrical lines exceeding AC 1 kV - Part 2-9: National
Normative Aspects (NNA) for Great Britain and Northern Ireland
(based on EN 50341-1:2012)

This European Standard was approved by CENELEC on 2017-04-26.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 50341-2-9:2019](https://standards.iteh.ai/catalog/standards/sist/cf354a3f-73f1-4c4f-867c-844fa7dd9c48/sist-en-50341-2-9-2019)

<https://standards.iteh.ai/catalog/standards/sist/cf354a3f-73f1-4c4f-867c-844fa7dd9c48/sist-en-50341-2-9-2019>



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

CONTENTS

1	Scope	6
1.1	General	6
2	Normative References, definitions and symbols	6
2.1	Normative references	6
2.3	Symbols	7
3	Basis of design	7
3.2	Requirements of overhead lines	7
3.2.2	Reliability requirements	7
3.2.5	Strength coordination	7
3.2.6	Additional considerations.....	7
3.3	Limit states	7
3.3.3	Serviceability limit states	7
4	Actions on lines	8
4.1	Introduction	8
4.3	Wind loads	8
4.3.1	Field of application and basic wind velocity	8
4.3.2	Mean wind velocity	9
4.3.3	Mean wind pressure	9
4.4	Wind forces on overhead line components	9
4.4.1	Wind forces on conductors.....	10
4.4.3	Wind forces on lattice towers	11
4.5	Ice loads	11
4.6	Combined Wind and Ice loads	12
4.7	Temperature effects	13
4.8	Security loads	13
4.9	Safety loads	14
4.9.1	Construction and maintenance loads	14
4.9.2	Loads related to the weight of linesmen	14
4.10	Forces due to short-circuit currents	14
4.11	Other special forces	14
4.12	Load cases	15
4.12.2	Standard load cases.....	15
4.13	Partial factors for actions	16
5	Electrical requirements	19
5.2	Currents	19

iTech STANDARD PREVIEW

(standards.iteh.ai)

SIST EN 50341-2-9:2019

[https://standards.iteh.ai/catalog/standards/sist/cf354a3f-73f1-4c4f-867c-](https://standards.iteh.ai/catalog/standards/sist/cf354a3f-73f1-4c4f-867c-81467110e48/sist-en-50341-2-9-2019)

81467110e48/sist-en-50341-2-9-2019

5.2.1	Normal current.....	19
5.2.2	Short circuit current	19
5.5	Minimum air clearance distances to avoid flashover	20
5.5.3	Empirical method based on European experience.....	20
5.6	Load cases for calculation of clearances.....	20
5.6.1	Load cases for calculation of clearances	20
5.6.3	Wind load for determination of electric clearances	20
5.6.4	Ice load for determination of electric clearances	20
5.6.5	Combined wind and ice loads.....	20
5.8	Internal clearances within the span and at the top of support	20
5.9	External clearances	21
5.9.1	General.....	21
5.9.4	External clearances to crossing traffic routes	21
5.9.6	External clearances to other power lines or overhead telecommunication lines.....	22
5.9.7	External clearances to recreational areas (playgrounds, sports areas, etc.)	22
5.10	Corona effect.....	22
5.10.2	Audible noise	22
5.10.3	Corona loss	22
5.11	Electrical and magnetic field	22
5.11.1	Electrical and magnetic fields under a line.....	22
6	Earthing Systems.....	22
6.2	Ratings with regard to corrosion and mechanical strength.....	22
6.2.1	Earth electrodes	22
6.4	Dimensioning with regard to human safety.....	22
7	Supports	23
7.3	Lattice steel towers	23
7.3.6	Ultimate limit states.....	23
7.4	Steel poles.....	23
7.4.5	Structural analysis	23
7.4.6	Ultimate limit states	23
7.5	Wood Poles	24
7.5.1	General.....	24
7.5.5	Ultimate limit states	24
7.7	Guyed structures	25
8.	Foundations.....	25
8.2	Basis of geotechnical design	25
8.2.2	Geotechnical design	25
8.2.3	Design by prescriptive measures	25
8.2.4	Load tests and tests on experimental models.....	25
8.4	Supervision of construction, monitoring and maintenance	25
9.	Conductor and earth wires	26

iteh STANDARD PREVIEW
(standards.iteh.ai)

<https://standards.iteh.ai/catalog/standards/sist/cf354a3f-73f1-4c4f-867c-444444444444/sist-en-50341-2-9-2019>

10. Insulators	26
10.10 Characteristics and dimensions of insulators	26
11 Line equipment – overhead line fittings	27
11.9 Characteristics and dimensions of insulator fittings	27
12 Quality assurance, checks and taking-over	27
Annex J Angles in lattice steel towers	27
J.4 Buckling resistance of angles in compression (see 7.3.6.4)	27
J.4.2 Effective non-dimensional slenderness for flexural buckling.....	27
J.4.3 Slenderness of members	27
J.4.3.3 Primary bracing patterns.....	27
J.5 Design resistance of bolted connections (see 7.3.8)	28
J.5.1 General.....	28
Figure NA.1 10-Minute mean wind speeds for GB, $v_{b, map}$ in metres per second	29
Figure NA.2 Ice thickness for GB, r_o and (r_w) in millimetres	30
Figure NA.3 Weather Zones for site heights of 0 to 100m	31
Figure NA.4 Weather Zones for site heights of 100 to 200m	32
Figure NA.5 Weather Zones for site heights of 200 to 300m	33
Figure NA.6 Weather Zones for site heights of 300 to 400m	34
Figure NA.7 Weather Zones for site heights of 400 to 500m	35

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 50341-2-9:2019

<https://standards.iteh.ai/catalog/standards/sist/054a3f-75ff-4c4f-867c-844fa7dd9c48/sist-en-50341-2-9-2019>

844fa7dd9c48/sist-en-50341-2-9-2019

European foreword

1. The British National Committee is identified by the following address:

British Standards Institution
389 Chiswick High Road
London W4 4AL

Tel: + 44 20 8996 9000
Fax: + 44 20 8996 7799
email: info@bsi.org.uk

Attention: Secretary of PEL/11 Overhead lines – Standards Development

2. The British National Committee has prepared this NNA (part 2-9 of EN 50341) listing the GB National Normative Aspects under its sole responsibility and duly passed this document through the CENELEC and CLC/TC 11 procedures.

NOTE: The British National NC also takes sole responsibility for the technically correct co-ordination of this NNA with EN 50341-1. It has performed the necessary checks in the frame of quality assurance / control. However, it is noted that this quality control has been made in the framework of the general responsibility of a standards committee under the national laws / regulations.

3. This Part 2-9 is normative in GB and informative for other countries.
4. This document shall be read in conjunction with Part 1 (EN 50341-1). All clause numbers used in this NNA correspond to those in Part 1. Specific sub-clauses that are prefixed “GB” are to be read as amendments to the relevant text in Part 1. Any necessary clarification regarding the application of this NNA in conjunction with Part 1 shall be referred to the British NC who will, in co-operation with CLC/TC 11, clarify the requirements.

Where no reference is made in this NNA to a specific sub-clause, then Part 1 shall apply.

5. In the case of “boxed values” defined in Part 1, amended values (if any), which are defined in this NNA, shall be taken into account in GB and Northern Ireland.

However any boxed value whether in Part 1 or in this NNA, shall not be amended in the direction of greater risk in a Project Specification.

6. The GB and Northern Ireland standards/ regulations relating to overhead electrical lines exceeding A.C. 1 kV are listed in subclause 2.1.
7. The British NC declares in accordance with clause 4.1 of Part 1 that this NNA follows both design “Approach 1” and design “Approach 3”. The specific design Approach to be used shall be specified in the Project Specification.

1 SCOPE

1.1 General

(ncpt) **GB.1 General**

This NNA is only applicable to all new overhead lines above A.C. 1kV.

This Euronorm is only applicable to new overhead lines and shall not be applied to maintenance, reconductoring, tee-offs, extensions or diversions to existing overhead lines unless specifically required by the Project Specification.

For details of the application of this standard for overhead lines constructed with covered conductor refer to the Project Specification.

For details of the application of this standard to telecommunication systems involving optical fibres either incorporated in or wrapped around earthwires or conductors or suspended from overhead line supports, reference should be made to the Project Specification.

2 NORMATIVE REFERENCES, DEFINITIONS AND SYMBOLS

2.1 Normative references

(A-dev) **GB.1 National statutes**

Reference

Name and Date of GB and NI Statute

<i>Reference</i>	<i>Name and Date of GB and NI Statute</i>
	<i>Electricity Act 1989, Chapter 29,</i>
	<i>Health and Safety at Work Act 1974 and subsequent amendments</i>
SI 635	<i>The Electricity at Work Regulations 1989 (Northern Ireland) 1991</i>
SI 1355	<i>The Electricity (Overhead Lines) Regulations 1970</i>
SI 2035	<i>The Overhead Lines (Exemption) Regulations 1990</i>
SI 2665	<i>The Electricity Safety, Quality and Continuity Regulations 2002</i>
SI 381	<i>The Electricity Safety, Quality and Continuity Regulations (Northern Ireland) 2012</i>
SI 3074	<i>The Overhead Lines (Exemption) Regulations 1992</i>
SI 320	<i>The Construction (Design & Management) Regulations 2007</i>
SI 231(NI)	<i>Electricity (Northern Ireland) Order 1992</i>
SR 142	<i>The Construction (Design & Management) (Amendment) Regulations (Northern Ireland) 2001</i>
SR 209	<i>The Construction (Design & Management) Regulations (Northern Ireland) 1995</i>
SR 536	<i>Electricity Supply Industry Regulations (Northern Ireland) 1991</i>
SR 21	<i>Electricity Supply (Amendment) Regulations (Northern Ireland) 1993</i>
SI 1039 (NI9)	<i>Health and Safety at Work (Northern Ireland) Order 1978</i>
SI 2448 (S.165)	<i>The Electricity Act 1989 (Scotland)</i>

(ncpt) **GB.2 National normative standards**

<i>BSEN 1991-1-4:2005</i>	<i>Actions on Structures - Part 1-4: General Actions – Wind actions</i>
<i>BSEN 1995-1-1:2008</i>	<i>Design of Timber Structures – Part 1-1 General – Common rules and rules for buildings</i>
<i>BS 7354:1990</i>	<i>Design of high-voltage open-terminal stations</i>
<i>BSEN 10025</i>	<i>Hot rolled products of structural steels</i>
<i>BSEN 14229:2010</i>	<i>Structural timber – wood poles for overhead lines</i>
<i>BSEN 50182:2001</i>	<i>Conductors for overhead lines – round wire concentric lay stranded conductors</i>

Electricity Association Technical Report (EATR) 111 - High Voltage Single Circuit Overhead Lines on Wood Poles (1991)

2.3 Symbols

(ncpt)

GB.1 Additional symbols

A_{SITE}	altitude of the site above mean sea level
a	altitude in metres above sea level of the conductor
C_{alt}	altitude factor
C_{dir}	wind direction factor
D_c	diameter of the conductor, mm
f_{yb}	yield strength for bolt
K_i	ice thickness coefficient
K_c	shape factor
L	length of conductor span, m
N_c	number of phases and earthwires
q_c	wind pressure on conductor, N/m ²
q_x	wind pressure on structural element, N/m ²
r_B	basic radial thickness of ice, mm
r_o	radial ice thickness in mm in the absence of wind, mm
r_r	reference ice thickness, mm
r_w	radial ice thickness in mm in the presence of wind
$V_{b,0}$	fundamental basic wind velocity, m/sec
$V_{b,map}$	10-minute wind velocity at sea level taken from a GB map, m/sec
Z	height above ground, m
γ_v	partial safety factor on wind speed and ice thickness (partial factors on actions)
γ_m	partial factor on strength of structural materials
γ_{dl}	partial factors on permanent actions

FULL STANDARD PREVIEW
 (standards.iteh.ai)

3 BASIS OF DESIGN

SIST EN 50341-2-9:2019

GB.1 Basic Requirements

<https://standards.iteh.ai/catalog/standards/sist/cf354a3f-73f1-4c4f-867c-844fa7dd9c48/sist-en-50341-2-9-2019>

3.2 Requirements of overhead lines

Design Approach 1

3.2.2 Reliability requirements

(ncpt)

GB.1 Reliability levels

The partial coefficients to be used for the reliability levels are shown in Table 4.13.1/GB.1. The required reliability level shall be stated in the Project Specification. For temporary loading conditions reduced reliability levels may be specified.

3.2.5 Strength coordination

(ncpt)

GB.1 Strength coordination

The required degree of strength coordination shall be stated in the Project Specification.

3.2.6 Additional considerations

(ncpt)

GB.1 Additional considerations

Higher partial factors than those shown within this NNA may be specified in the Project Specification. Any additional considerations shall also be stated in the Project Specification.

3.3 Limit states

3.3.3 Serviceability limit states

(ncpt)

GB.1 Specific requirement

These shall be defined in the Project Specification.

4 ACTIONS ON LINES

4.1 Introduction

Design Approach 1

(ncpt)

GB.1 Peak factor equation

The formulation in the UK National Annex to BS EN 1991-1-4 modifies the parameter to define peak pressures by adopting a “peak factor” of 3,0 with a quadratic equation, rather than 3,5 with a linear equation, as used in BS EN 1991-1-4. The decision to change the formulation was due to the use of the ten minute wind speed in BS EN 1991-1-4 and the greater accuracy in the quadratic expression. As a consequence of this, equations included in clauses 4.3.4, 4.4.1.2, 4.4.3.2, 4.4.3.3 need to be amended as follows for use in the UK:

Replace the expression: $[1 + 7I_v(z)]$
with: $[1 + 3,0I_v(z)]^2$

(ncpt)

GB.2 Design approach definition

Approach 1 (as detailed in BS EN 50341-1:2012 Clause 4.1) shall be adopted for all new overhead lines supported on steel poles or lattice steel towers.

Approach 2 (as detailed in BS EN 50341-1:2012 Clause 4.1) may be used subject to the availability of suitable statistical data, and the agreement of the client. Before doing so, the proposed methodology for design, and the quality of the statistical data, shall be subject to a rigorous review by an independent expert to confirm that Reliability Levels equivalent to those provided by Design Approach 1 would be achieved with the proposed Design Approach 2.

For overhead lines supported on timber poles, the project specification shall specify either design Approach 3 or 1.

NOTE Approaches 1 and 3 are based on different design philosophies and care should be taken not to combine elements of the two when undertaking calculations. The parts of this standard which apply only to Approach 3 are shown shaded grey in this document.

4.3 Wind loads

SIST EN 50341-2-9:2019
<https://standards.iteh.ai/catalog/standards/sist/cf354a3f-73f1-4c4f-867c-844fa7dd9c48/sist-en-50341-2-9-2019>

4.3.1 Field of application and basic wind velocity

Design Approach 1

(snc)

GB.1 Calculation of basic wind velocity

Partial factor (γ_v) taken from Table 4.13.1/GB.1 for the specified Reliability Level shall be applied to the basic wind velocity ($v_{b,0}$) instead of applied to wind loading as given in Table 4.7 of BSEN 50341-1. The partial factor Ψ_w shall not be used.

The fundamental basic wind velocity, $v_{b,0}$ should be determined by the equation:

$$v_{b,0} = \gamma_v v_{b,map} c_{alt}$$

Where, $v_{b,map}$ is the fundamental velocity indicated in Figure NA.1 and c_{alt} is the altitude factor calculated as follows:

$$c_{alt} = 1 + 0,001 A_{SITE}$$

where: A_{SITE} is the altitude of the site in metres above mean sea level

The above may be used for all site altitudes, but may be considered over-conservative at high altitudes, in which case c_{alt} may be calculated for each element greater than 10m above ground using the modified formula:

$$c_{alt} = 1 + 0,001 A_{SITE} (10/h)^{0,2}$$

Where h is the height above ground level in metres at the point of application of the wind load. For calculation of wind loading on conductors and insulators, h may be taken as the mean height of the conductor attachment points. For calculation of wind on towers, structures may be divided

in a number of panels of up to 10m in height, and h taken as the mean height of each panel.

4.3.2 Mean wind velocity

(ncpt)

GB.1 Wind Direction

Wind direction factor C_{dir} may conservatively be taken as 1,0 or from Table 4.3.2/GB.1 below.

Table 4.3.2/GB.1 Wind direction factors

Direction	0	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°	330°
C_{dir}	0,78	0,73	0,73	0,74	0,73	0,80	0,85	0,93	1,00	0,99	0,91	0,82
NOTE 1 Interpolation may be used												
NOTE 2 The directions are defined by angles from due North in a clockwise direction, for wind <i>from</i> the specified direction (eg. 0° means wind <i>from</i> due North)												

NOTE. Unless stated otherwise in the project specification, wind from every direction from 0 to 345° shall be considered for the design in 15° increments.

(ncpt)

GB.2 Seasonal factor, c_{season}

Where a temporary loading condition will remain in place for less than 1 year, the appropriate C_{season} factor may be applied in the calculation of mean wind speed as indicated in Table NA.2.7 in National Annex to BSEN 1991-1-4:2005. Note that the appropriate factor will not be applied in conjunction with wind speeds of less return period than 50 years.

(ncpt)

GB.3 Orography factor, c_o

The orography factor, c_o shall be taken as 1,0 where the average ground slope is not greater than 5% (1:20), measured over a distance of 10 times the height of the supports from the line. For greater slopes, reference shall be made to Figure NA.2 in National Annex to BSEN 1991-1-4:2005+A1, "Definition of significant orography [definition of symbols given in A.3(3)]". For sites lying within the shaded area of that figure, the method given in BSEN 1991-1-4 A.3 for calculation of c_o may be used. As an alternative, or if the topography is complex, calculation by wind engineering specialists using digital terrain models may be less labour intensive and give more accurate results. [SIST EN 50341-2-9:2019](https://standards.iteh.ai/catalog/standards/sist/cf354a3f-73f1-4c4f-867c-48/sist-en-50341-2-9-2019)

[https://standards.iteh.ai/catalog/standards/sist/cf354a3f-73f1-4c4f-867c-](https://standards.iteh.ai/catalog/standards/sist/cf354a3f-73f1-4c4f-867c-48/sist-en-50341-2-9-2019)

(ncpt)

GB.4 Loading on conductors

For calculation of the load on supports due to wind loading on conductors (excluding those indirect effects due to conductor tension) the magnitude of the height above ground (h) adopted for the calculation of $V_h(h)$ shall generally be taken as the average height to the attachment of the support considered except in the case of spans crossing deep valleys, river estuaries or hills where the attachment heights would not be representative of the actual heights to the conductors away from the supports. In these cases, the value of h adopted shall be adjusted to approximately represent the mean height from the ground or water level to the attachment points on the supports. Alternatively, advice from a wind engineering specialist may be sought.

4.3.3 Mean wind pressure

(snc)

GB.1 Air density

Air density in Great Britain shall be taken as 1,226 kg/m³. Table 4.2 in BSEN 50341-1:2012 shall not be used.

4.4 Wind forces on overhead line components

(snc)

GB.1 Design Approach 3

Table 4.4.1/GB.1 details the design wind pressures and drag factors to be adopted for design Approach 3.

The span factor G_c shall be assumed to be 1,0 for wind span lengths up to 200m and $(0,75L + 30)/L$ metres for wind span lengths greater than 200m. Normal and High altitudes are defined as follows:

Normal altitude: All of GB and Northern Ireland, except Scotland, site altitudes not exceeding 300m. For Scotland, site altitudes not exceeding 200m. More onerous requirements may be detailed in the Project Specification.

High altitude: All of GB and Northern Ireland, except Scotland, site altitudes greater than 300m but not exceeding 500m. For Scotland, site altitudes greater than 200m but not exceeding 500m. For lines at altitudes greater than 500m, a special consideration should be made as detailed in the Project Specification.

Table 4.4.1/GB.1 Wind pressures and aerodynamic drag factors

Load Condition	Wind Pressure (N/m ²)		Aerodynamic drag factors	
	q _x	q _c	C _x	C _c
High Wind (no ice)	1740	1740	0,8	1,0
Combined Wind and Ice (Normal altitude)	380	380	1,0	1,0
Combined Wind and Ice (High altitude)	570	570	1,0	1,0
Wind only (no ice)	0	760	-	1,0
Security (broken wire)	380	380	1,0	1,0

NOTE: for the leeward (shielded) pole, a shielding factor of 0,5 shall be assumed

4.4.1 Wind forces on conductors

Design Approach 1

4.4.1.1 General

(ncpt)

GB.1 Calculation of G_c

The wind loading adopted for calculation of the mechanical tension in a section of line shall be based on a value of conductor structural factor, G_c derived using a length value, L_m equal to the section length or 800m whichever is the less, together with a height, h based on the mean height of the conductor attachment point over length L_m. The mean height of the conductors shall be adjusted for deep valleys, river estuaries and hills as described in 4.3.2/ GB.4 above.

4.4.1.3 Drag Factor

(ncpt)

GB.1 Calculation of Reynold's number

In the calculation of drag factor for conductors (c) Method 3 shall be used for stranded conductors, using an effective Reynold's number (Re). The values given in 4.4.1.3 shall be used for normal stranded conductors without ice. Other values are given in Table 4.4.1/GB.2 below.

Where: $Re = (1,42 V_h \cos \varnothing_c d) / \nu$

and where: ν is the kinematic viscosity of air, taken as $1,46 \times 10^{-5} \text{ m}^2/\text{s}$

\varnothing_c is the angle between the wind direction and plane normal to the conductor

Table 4.4.1/GB.2 Typical Drag Factors for elements

Member type	Effective Reynold's number (Re)	Drag Factor (C _c)	
		Ice free	Iced
Circular sections, smooth wire and smooth bodied conductors	$\leq 2 \times 10^5$	1,2	1,2
	4×10^5	0,6	1,0
	$> 10 \times 10^5$	0,7	1,0
Normal stranded conductors with more than seven strands	$\leq 6 \times 10^4$	1,2	-
	$\geq 10^5$	0,9	-
	$\leq 1 \times 10^5$	-	1,25
Thick stranded cable, e.g small wire ropes, round wire ropes, spiral steel strand with seven wires only	$\geq 2 \times 10^5$	-	1,0
	$\leq 4 \times 10^4$	1,3	-
	$> 4 \times 10^4$	1,1	-
Flat sided sections and plates	$\leq 1 \times 10^5$	-	1,25
	$\geq 2 \times 10^5$	-	1,0
Flat sided sections and plates	All values	2,0	2,0

NOTE For intermediate values of Re, C_c should be obtained by linear interpolation