

SLOVENSKI STANDARD

SIST EN 61784-5-3:2019

01-februar-2019

Nadomešča:
SIST EN 61784-5-3:2014

**Industrijska komunikacijska omrežja - Profili - 5-3. del: Inštalacija procesnih vodil -
Inštalacijski profili za CPF 3 (IEC 61784-5-3:2018)**

Industrial communication networks - Profiles - Part 5-3: Installation of fieldbuses -
Installation profiles for CPF 3 (IEC 61784-5-3:2018)

Industrielle Kommunikationsnetze - Profile - Teil 5-3: Feldbusinstallation -
Installationsprofile für die Kommunikationsprofilfamilie 3 (IEC 61784-5-3:2018)

Réseaux de communication industriels - Profils - Partie 5-3: Installation des bus de
terrain - Profils d'installation pour CPF 3 (IEC 61784-5-3:2018)

Ta slovenski standard je istoveten z: EN IEC 61784-5-3:2018

ICS:

25.040.40	Merjenje in krmiljenje industrijskih postopkov	Industrial process measurement and control
35.100.40	Transportni sloj	Transport layer

SIST EN 61784-5-3:2019

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/0055a268-4ec2-4f33-8719-0f13bacac96a/sist-en-61784-5-3-2019>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN IEC 61784-5-3

November 2018

ICS 25.040.40; 35.100.40

English Version

**Industrial communication networks - Profiles - Part 5-3:
 Installation of fieldbuses - Installation profiles for CPF 3
 (IEC 61784-5-3:2018)**

Réseaux de communication industriels - Profils - Partie 5-3:
 Installation des bus de terrain - Profils d'installation pour
 CPF 3
 (IEC 61784-5-3:2018)

Industrielle Kommunikationsnetze - Profile - Teil 5-3:
 Feldbusinstallation - Installationsprofile für die
 Kommunikationsprofilfamilie 3
 (IEC 61784-5-3:2018)

This European Standard was approved by CENELEC on 2018-10-04. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
 Comité Européen de Normalisation Electrotechnique
 Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN IEC 61784-5-3:2018 (E)**European foreword**

The text of document 65C/924/FDIS, future edition 4 of IEC 61784-5-3, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61784-5-3:2018.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2019-07-04
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2021-10-04

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61784-5-3:2018 was approved by CENELEC as a European Standard without any modification.

Annex ZA

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61918	2018	Industrial communication networks - Installation of communication networks in industrial premises	EN IEC 61918	2018

iTeh STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/0055a268-4ec2-4f33-8719-0f13bacac96a/sist-en-61784-5-3-2019>



INTERNATIONAL STANDARD



Industrial communication networks – Profiles –
Part 5-3: Installation of fieldbuses – Installation profiles for CPF 3

iTeh STANDARD PREVIEW
(Standard preview)
Full standard
<https://standardsite.iteh.ai/catalog/standard/ist055a268-4ec2/>
4513-8719-013bacac96a/ist-055a268-4ec2/

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 25.040.40; 35.100.40

ISBN 978-2-8322-5939-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	7
INTRODUCTION	9
1 Scope	10
2 Normative references	10
3 Terms, definitions and abbreviated terms	10
4 CPF 3: Overview of installation profiles	10
5 Installation profile conventions	11
6 Conformance to installation profiles	11
Annex A (normative) CP 3/1 (PROFIBUS) specific installation profile	13
A.1 Installation profile scope	13
A.2 Normative references	13
A.3 Installation profile terms, definitions, and abbreviated terms	13
A.3.1 Terms and definitions	13
A.3.2 Abbreviated terms	14
A.3.3 Conventions for installation profiles	14
A.4 Installation planning	14
A.4.1 General	14
A.4.2 Planning requirements	14
A.4.3 Network capabilities	16
A.4.4 Selection and use of cabling components	18
A.4.5 Cabling planning documentation	28
A.4.6 Verification of cabling planning specification	28
A.5 Installation implementation	28
A.5.1 General requirements	28
A.5.2 Cable installation	28
A.5.3 Connector installation	30
A.5.4 Terminator installation	34
A.5.5 Device installation	34
A.5.6 Coding and labelling	34
A.5.7 Earthing and bonding of equipment and device and shielded cabling	35
A.5.8 As-implemented cabling documentation	36
A.6 Installation verification and installation acceptance test	36
A.6.1 General	36
A.6.2 Installation verification	36
A.6.3 Installation acceptance test	38
A.7 Installation administration	43
A.8 Installation maintenance and installation troubleshooting	43
Annex B (normative) CP 3/2 (PROFIBUS) specific installation profile	44
B.1 Installation profile scope	44
B.2 Normative references	44
B.3 Installation profile terms, definitions, and abbreviated terms	44
B.3.1 Terms and definitions	44
B.3.2 Abbreviated terms	45
B.3.3 Conventions for installation profiles	45

B.4 Installation planning	46
B.4.1 General.....	46
B.4.2 Planning requirements	47
B.4.3 Network capabilities	54
B.4.4 Selection and use of cabling components	60
B.4.5 Cabling planning documentation	75
B.4.6 Verification of cabling planning specification	75
B.5 Installation implementation	75
B.5.1 General requirements	75
B.5.2 Cable installation	75
B.5.3 Connector installation	76
B.5.4 Terminator installation	77
B.5.5 Device installation.....	77
B.5.6 Coding and labelling	77
B.5.7 Earthing and bonding of equipment and device and shielded cabling	77
B.5.8 As-implemented cabling documentation	77
B.6 Installation verification and installation acceptance test	77
B.6.1 General.....	77
B.6.2 Installation verification	78
B.6.3 Installation acceptance test.....	78
B.7 Installation administration	79
B.8 Installation maintenance and installation troubleshooting.....	79
Annex C (normative) CP 3/3, CP 3/4, CP 3/5, CP 3/6 (PROFINET) specific installation profile	80
C.1 Installation profile scope	80
C.2 Normative references	80
C.3 Installation profile terms, definitions, and abbreviated terms	80
C.3.1 Terms and definitions.....	80
C.3.2 Abbreviated terms.....	80
C.3.3 Conventions for installation profiles	80
C.4 Installation planning	81
C.4.1 General.....	81
C.4.2 Planning requirements	81
C.4.3 Network capabilities	81
C.4.4 Selection and use of cabling components	84
C.4.5 Cabling planning documentation	106
C.4.6 Verification of cabling planning specification	106
C.5 Installation implementation	106
C.5.1 General requirements	106
C.5.2 Cable installation	106
C.5.3 Connector installation	108
C.5.4 Terminator installation	110
C.5.5 Device installation.....	110
C.5.6 Coding and labelling	110
C.5.7 Earthing and bonding of equipment and device and shielded cabling	111
C.5.8 As-implemented cabling documentation	112
C.6 Installation verification and installation acceptance test.....	112
C.6.1 General.....	112

C.6.2 Installation verification	112
C.6.3 Installation acceptance test.....	113
C.7 Installation administration	114
C.8 Installation maintenance and installation troubleshooting.....	114
Bibliography.....	115
 Figure 1 – Standards relationships.....	9
Figure A.1 – Recommended combination of shielding and earthing for CP 3/1 networks with RS 485-IS.....	26
Figure A.2 – Sub-D connector pin numberings (front view).....	31
Figure A.3 – 5-pin M12 female socket	32
Figure A.4 – 5-pin M12 male plug for CP 3/1.....	33
Figure A.5 – Test circuit A – Resistance measurement of data line B and shield	39
Figure A.6 – Test circuit B – Resistance measurement of data line A and shield	39
Figure A.7 – Test circuit C – Resistance measurement of data line A, data line B, and shield.....	39
Figure A.8 – Test circuit D – Resistance measurement between data line A and B.....	40
Figure A.9 – Resistance measurement without 9-pin Sub-D plug.....	40
Figure A.10 – Loop core resistance (cable type A).....	41
Figure A.11 – Action and resolution tree for measurement 1 (RS 485 and RS 485-IS)	41
Figure A.12 – Action and resolution tree for measurement 2 (RS 485 and RS 485-IS)	42
Figure A.13 – Action and resolution tree for measurement 3 (RS 485 and RS 485-IS)	42
Figure B.1 – Connection of CP 3/1 networks.....	47
Figure B.2 – Typical fieldbus architecture	50
Figure B.3 – Fieldbus with stations supplied by auxiliary power sources	50
Figure B.4 – Fieldbus model	53
Figure B.5 – Current modulation (Manchester II code)	53
Figure B.6 – Tree topology	55
Figure B.7 – Bus topology.....	55
Figure B.8 – Combination of the tree topology and the bus topology	56
Figure B.9 – Fieldbus extension.....	56
Figure B.10 – Recommended combination of shielding and earthing	70
Figure B.11 – Ideal combination of shielding and earthing	71
Figure B.12 – Capacitive earthing	72
Figure B.13 – Galvanic isolated field device.....	73
Figure B.14 – Pin assignment of the male and female connectors IEC 60947-5-2 (A-coding)	77
Figure C.1 – Definition of End-to-end link.....	101
Figure C.2 – End-to-end link without interconnections.....	101
Figure C.3 – Assembled End-to-end link	101
Figure C.4 – Connectionless optical fibre link	102
Figure C.5 – Assembled optical fibre link	102
Figure C.6 – Shielded connectors for CP 3/3, CP 3/4, CP 3/5 and CP 3/6 fieldbus networks	108
Figure C.7 – Pin-assignment for a straight cable.....	109

Table A.1 – Excerpt of MICE definition.....	16
Table A.2 – Basic network characteristics for balanced cabling not based on Ethernet (ISO/IEC 8802-3)	17
Table A.3 – Network characteristics for optical fibre cabling.....	18
Table A.4 – Information relevant to copper cable: fixed cables.....	19
Table A.5 – Information relevant to optical fibre cables	20
Table A.6 – Connectors for copper cabling CPs not based on Ethernet.....	21
Table A.7 – Optical fibre connecting hardware	21
Table A.8 – Relationship between FOC and fibre types (CP 3/1).....	21
Table A.9 – Parameters for balanced cables	29
Table A.10 – Parameters for silica optical fibre cables	29
Table A.11 – Parameters for POF optical fibre cables	29
Table A.12 – Parameters for hard clad silica optical fibre cables	30
Table A.13 – Use of 9 pin Sub-D connector pins (RS 485)	31
Table A.14 – Use of 9 pin Sub-D connector pins (RS 485-IS).....	32
Table A.15 – Use of M12 connector pins (RS 485).....	33
Table A.16 – Use of M12 connector pins (RS 485-IS)	34
Table A.17 – Maximum fibre channel attenuation for CP 3/1 (PROFIBUS)	43
Table B.1 – Valid parameter range of the FISCO model for use as EEx ib IIC / IIB.....	51
Table B.2 – Valid parameter range of the FISCO model for use as EEx ia IIC	52
Table B.3 – Power supply (operational values)	58
Table B.4 – Line lengths which can be achieved	58
Table B.5 – Limit values for distortion, reflection and signal delay.....	59
Table B.6 – Recommended maximum cable lengths including spurs	59
Table B.7 – Recommended length of the spurs	60
Table B.8 – Maximum length of the splices	60
Table B.9 – Information relevant to copper cable: fixed cables.....	61
Table B.10 – Safety limit values for the fieldbus cable	62
Table B.11 – Connectors for copper cabling CPs not based on Ethernet.....	63
Table B.12 – Mixing devices from different categories	65
Table B.13 – Electrical characteristics of fieldbus interfaces	66
Table B.14 – Recommended data sheet specifications for CP 3/2 devices	67
Table B.15 – Parameters for balanced cables	75
Table B.16 – Contact assignments for the external connector for harsh industrial environments	76
Table C.1 – General transmission media selection information	82
Table C.2 – Network characteristics for balanced cabling based on Ethernet (ISO/IEC 8802-3)	83
Table C.3 – Network characteristics for optical fibre cabling	83
Table C.4 – Information relevant to copper cable: CP 3/3, CP 3/4, CP 3/5 and CP 3/6 type A fixed cables	85
Table C.5 – Information relevant to copper cable: CP 3/3, CP 3/4, CP 3/5 and CP 3/6 type B flexible cables	86

Table C.6 – Information relevant to copper cable: CP 3/3, CP 3/4, CP 3/5 and CP 3/6 type C special cables	87
Table C.7 – Information relevant to copper cable: CP 3/3, CP 3/4, CP 3/5 and CP 3/6 of cabinet cord sets	88
Table C.8 – Requirement data cable inside and outside cabinet: CP 3/3, CP 3/4, CP 3/5 and CP 3/6 type B flexible cables	89
Table C.9 – Requirement to copper cable inside and outside cabinet: CP 3/3, CP 3/4, CP 3/5 and CP 3/6 type B flexible cables	90
Table C.10 – Information relevant to optical fibre cables	91
Table C.11 – Requirements for plastic and hard clad silica optical fibre cables	91
Table C.12 – Requirements for glass multimode optical fibre cables	93
Table C.13 – Requirements for glass singlemode optical fibre cables	94
Table C.14 – Requirements of industrial FO-cord sets	95
Table C.15 – Standard of test of industrial FO-cord sets	96
Table C.16 – Information relevant to hybrid cables (application type B)	96
Table C.17 – Information relevant to hybrid cables (application type C)	97
Table C.18 – Connectors for balanced cabling CPs based on Ethernet	99
Table C.19 – Connectors for balanced cabling CPs not based on Ethernet	99
Table C.20 – Connectors for balanced cabling CPs based on Ethernet	99
Table C.21 – Optical fibre connecting hardware	100
Table C.22 – Relationship between FOC and fibre types (CP 3/3, CP 3/4, CP 3/5, CP3/6)	100
Table C.23 – Typical fibre channels common for industrial applications	103
Table C.24 – Parameters for balanced cables	107
Table C.25 – Parameters for silica optical fibre cables	107
Table C.26 – Parameters for POF optical fibre cables	107
Table C.27 – Parameters for hard clad silica optical fibre cables	108
Table C.28 – Colour coding of 2 pair cabling for CP 3/3, CP 3/4, CP 3/5 and CP 3/6 connectors	109
Table C.29 – Colour coding of 4 pair cabling for CP 3/3, CP 3/4, CP 3/5 and CP 3/6 connectors	109
Table C.30 – Contact arrangement M12 2 pair to M12 4 pair for CP 3/3, CP 3/4, CP 3/5 and CP 3/6 connectors	110
Table C.31 – Maximum fibre channel attenuation for CP 3/3, CP 3/4, CP 3/5 and CP 3/6 (PROFINET)	114

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
PROFILES –****Part 5-3: Installation of fieldbuses –
Installation profiles for CPF 3****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61784-5-3 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This fourth edition cancels and replaces the third edition published in 2013. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) an addition of 4-pair cabling (see C.4.4.1.2.1 and C.5.3.2);
- b) an addition of the connector M12 X-Coding (see C.4.4.2.2);
- c) an addition of the definition of End-to-end links (see C.4.4.3.1);