# FINAL DRAFT

# INTERNATIONAL STANDARD

ISO/FDIS 10140-4

ISO/TC 43/SC 2

Secretariat: DIN

Voting begins on: **2016-08-10** 

Voting terminates on:

2016-10-05

Acoustics — Laboratory measurement of sound insulation of building elements —

Part 4:

Measurement procedures and

iTeh STANDARD PREVIEW

S Acoustique Mesurage en laboratoire de l'isolation acoustique des éléments de construction

Partie 4: Exigences et modes opératoires de mesure

https://standards.iteh.ai/catalog/standards/sist/1928f407-290f-43fb-9922-87160284e88d/iso-fdis-10140-4

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

# ISO/CEN PARALLEL PROCESSING



Reference number ISO/FDIS 10140-4:2016(E)

# iTeh STANDARD PREVIEW (standards.iteh.ai)

ISO/FDIS 10140-4 https://standards.iteh.ai/catalog/standards/sist/1928f407-290f-43fb-9922-87160284e88d/iso-fdis-10140-4



# **COPYRIGHT PROTECTED DOCUMENT**

# 

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office Ch. de Blandonnet 8 • CP 401 CH-1214 Vernier, Geneva, Switzerland Tel. +41 22 749 01 11 Fax +41 22 749 09 47 copyright@iso.org www.iso.org

CO	Contents						
Fore	eword	vord					
Intr	oductio	1		<b>v</b>			
1	Scon	<b>1</b>		1			
	•						
2	Normative references						
3	Tern	s and definitions.		1			
4	Measurement procedures and requirements						
	4.1	Frequency range		2			
	4.2		sound pressure levels				
		4.2.1 General		3			
		4.2.2 Minimur	m separation distances for microphone positions	3			
		4.2.3 Averagin	ng times	3			
			overage sound pressure level				
	4.3		ckground noise level				
	4.4		airborne sound insulation				
		4.4.2 Measure 4.4.3 Measure	ements with fixed microphone positions	5			
	4.5	4.4.3 Measure	ements with a continuously moving microphoneimpact sound insulation	5			
	4.5	4.5.1 General	impact sound insulation	5			
		4.5.2 Measure	nents with fixed microphone positions	5			
		4.5.3 Continuo	ously moving microphone	6			
	4.6	Measurement of	reverberation time and evaluation of the equivalent sound				
	1.0	absorption area		6			
			ISO/FDIS 10140-4				
			ment of reverberation time 407-290f 43fb-9922				
			ent sound absorption area 40.4				
	4.7 Measurement of structural reverberation time						
	4.8		radiated sound power by surface velocity of elements				
5	Sour		surements				
3	5.1		surements.				
	5.2		re for the determination of airborne sound insulation				
	5.2		Te for the determination of an borne sound insulation				
			icrophone positions and multiple loudspeakers operating				
			neously or a moving loudspeaker	8			
			icrophone positions and a single loudspeaker operated at more				
			e position	8			
			ously moving microphone and multiple loudspeakers operating				
			neously or a moving loudspeaker	9			
			ously moving microphone and a single loudspeaker operated at				
			an one position	9			
	5.3		re for the determination of impact sound insulation of floors				
			-				
			icrophone position				
		5.3.3 Continuo	ously moving microphone	10			
Ann	ex A (no	rmative) <b>Addition</b>	al procedures for measurements at low frequencies	11			
			•				
וטוטו	וטצו מטו	v		14			

# **Foreword**

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see <a href="www.iso.org/directives">www.iso.org/directives</a>).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see <a href="https://www.iso.org/patents">www.iso.org/patents</a>).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: <a href="https://www.iso.org/iso/foreword.html">www.iso.org/iso/foreword.html</a>.

The committee responsible for this document is ISO/TC 43, *Acoustics*, Subcommittee SC 2, *Building acoustics*.

ISO/FDIS 10140-4

This second edition cancels and replaces the first aedition (1807-10140-14:2010), which has been technically revised. 87160284e88d/iso-fdis-10140-4

A list of all parts in the ISO 10140 series can be found on the ISO website.

# Introduction

ISO 10140 (all parts) concerns laboratory measurement of the sound insulation of building elements (see <u>Table 1</u>).

ISO 10140-1 specifies the application rules for specific elements and products, including specific requirements for preparation, mounting, operating and test conditions. ISO 10140-2 and ISO 10140-3 contain the general procedures for airborne and impact sound insulation measurements, respectively, and refer to this document and ISO 10140-5 where appropriate. For elements and products without a specific application rule described in ISO 10140-1, it is possible to apply ISO 10140-2 and ISO 10140-3. This document contains basic measurement techniques and processes. ISO 10140-5 contains requirements for test facilities and equipment. For the structure of ISO 10140 (all parts), see Table 1.

Table 1 — Structure and contents of ISO 10140 (all parts)

Relevant part of ISO 10140	Main purpose, contents and use	Detailed content
ISO 10140-1	It indicates the appropriate test procedure for elements and products. For certain types of element/product, it can contain additional and more specific instructions about quantities and test element size and about preparation, mounting and operating conditions. Where no specific details are included, the general guidelines are according to ISO 10140-2 and ISO 10140-3.	Appropriate references to ISO 10140-2 and ISO 10140-3 and product-related, specific and additional instructions on:  — specific quantities measured;  — size of test element;  boundary and mounting conditions;  — conditioning, testing and operating conditions;
ISO 10140-2	It gives a complete procedure for air borne 4 sound insulation measurements accordist/192 ing to ISO 10140-4 and ISO 10140-5; Foris-1014 products without specific application rules, it is sufficiently complete and general for the execution of measurements. However, for products with specific application rules, measurements are carried out according to ISO 10140-1, if available.	— additional specifics for test report.  — Definitions of main quantities measured; 8f407-290f-43fb-9922- 10-4 General mounting and boundary conditions;  — General measurement procedure;  — Data processing;  — Test report (general points).
ISO 10140-3	It gives a complete procedure for impact sound insulation measurements according to ISO 10140-4 and ISO 10140-5. For products without specific application rules, it is sufficiently complete and general for the execution of measurements. However, for products with specific application rules, measurements are carried out according to ISO 10140-1, if available.	<ul> <li>Definitions of main quantities measured;</li> <li>General mounting and boundary conditions;</li> <li>General measurement procedure;</li> <li>Data processing;</li> <li>Test report (general points).</li> </ul>

Relevant part of ISO 10140	Main purpose, contents and use	Detailed content
ISO 10140-4	It gives all the basic measurement techniques and processes for measurement according to ISO 10140-2 and ISO 10140-3 or facility qualifications according to ISO 10140-5. Much of the content is implemented in software.	— Definitions;
		— Frequency range;
		— Microphone positions;
		— SPL measurements;
		— Averaging, space and time;
		— Correction for background noise;
		— Reverberation time measurements;
		— Loss factor measurements;
		— Low-frequency measurements;
		— Radiated sound power by velocity measurement.
ISO 10140-5	It specifies all information needed to design, construct and qualify the laboratory facility, its additional accessories and measurement equipment (hardware).	Test facilities, design criteria:
		— volumes, dimensions;
		— flanking transmission;
		— laboratory loss factor;
		— maximum achievable sound reduction index;
	iTeh STANDAR	reverberation time;
	,	influence of lack of diffusivity in the laboratory.
		Test openings:
	https://standards.iteh.ai/catalog/standard	140-4 — standard openings for walls and floors;
	87160284e88d/iso-	cther openings (windows, doors, small technical elements);
		— filler walls in general.
		Requirements for equipment:
		— loudspeakers, number, positions;
		— tapping machine and other impact sources;
		— measurement equipment.
		Reference constructions:
		— basic elements for airborne and impact insulation improvement;
		— corresponding reference performance curves.

ISO 10140 (all parts) was created to improve the layout for laboratory measurements, ensure consistency and simplify future changes and additions regarding mounting conditions of test elements in laboratory and field measurements. It is intended for ISO 10140 (all parts) to present a well-written and arranged format for laboratory measurements.

# Acoustics — Laboratory measurement of sound insulation of building elements —

# Part 4:

# Measurement procedures and requirements

# 1 Scope

This document specifies the basic measurement procedures for airborne and impact sound insulation in laboratory test facilities.

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3382-2, Acoustics — Measurement of room acoustic parameters — Part 2: Reverberation time in ordinary rooms

ISO 10140-1:2010, Acoustics — Laboratory measurement of sound insulation of building elements — Part 1: Application rules for specific products

ISO 10140-2, Acoustics Laboratory measurement of sound insulation of building elements — Part 2: Measurement of airborne sound insulation 84e88d/iso-fdis-10140-4

ISO 10140-3, Acoustics — Laboratory measurement of sound insulation of building elements — Part 3: Measurement of impact sound insulation

ISO 10140-5:2010, Acoustics — Laboratory measurement of sound insulation of building elements — Part 5: Requirements for test facilities and equipment

ISO 10848-1:2006, Acoustics — Laboratory measurement of the flanking transmission of airborne and impact sound between adjoining rooms — Part 1: Frame document

ISO 18233, Acoustics — Application of new measurement methods in building and room acoustics

#### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <a href="http://www.electropedia.org/">http://www.electropedia.org/</a>
- ISO Online browsing platform: available at <a href="http://www.iso.org/obp">http://www.iso.org/obp</a>

# ISO/FDIS 10140-4:2016(E)

#### 3.1

# energy average sound pressure level in a room

I

ten times the common logarithm of the ratio of the space and time average of the squared sound pressure to the square of the reference sound pressure, the space average being taken over the entire room with the exception of those parts where the direct radiation of a sound source or the near field of the boundaries (walls, etc.) is of significant influence

Note 1 to entry: *L* is expressed in decibels.

#### 3.2

#### reverberation time

T

time required for the sound pressure level in a room to decrease by 60 dB after the sound source has stopped

Note 1 to entry: The reverberation time is expressed in seconds.

Note 2 to entry: The range evaluated is defined by the times at which the decay curve first reaches 5 dB and 25 dB, respectively, below the initial level.

#### 3.3

#### structural reverberation time

 $T_{\rm S}$ 

time required for the acceleration level in a structure to decrease by 60 dB after the structure-borne sound source has stopped iTeh STANDARD PREVIEW

Note 1 to entry: The structural reverberation time is expressed in seconds.

Note 2 to entry:  $T_s$  is calculated using linear extrapolation of much shorter evaluation ranges than 60 dB, preferably 15 dB or 20 dB.

ISO/FDIS 10140-4

# 3.4

https://standards.iteh.ai/catalog/standards/sist/1928f407-290f-43fb-9922-

#### 87160284e88d/iso-fdis-10140-4

background noise level

measured sound pressure level in the receiving room from all sources other than the loudspeaker or tapping machine in the source room

#### 3.5

#### continuously moving microphone

microphone that, with respect to a fixed point,

- a) moves with approximately constant speed in a circle, or
- b) sweeps to and fro along the arc of a circle, which is as large as possible, but is not to be less than 270°, over a fixed time period

# 4 Measurement procedures and requirements

### 4.1 Frequency range

All quantities shall be measured using one-third octave band filters having at least the following centre frequencies, in hertz:

100, 125, 160, 200, 250, 315, 400, 500, 630, 800, 1000, 1250, 1600, 2000, 2500, 3150, 4000, 5000

If additional information in the low-frequency range is required, use one-third octave band filters with the following centre frequencies, in hertz:

50, 63, 80

For measurements including low frequencies (i.e. starting at third octave band 50 Hz), additional criteria from Annex A shall be used. In case of differences between standard measurements (starting at third octave band 100 Hz) and those following Annex A additional criteria, the measurements performed using Annex A are assumed to be more reliable over the complete frequency range (50 Hz to 5000 Hz third octave bands).

# 4.2 Measurement of sound pressure levels

#### 4.2.1 General

Obtain the energy average sound pressure level using a single microphone moved from position to position, an array of fixed microphones or a continuously moving microphone.

# 4.2.2 Minimum separation distances for microphone positions

The following separation distances are minimum values and shall be exceeded where possible:

- a) 0,7 m between fixed microphone positions;
- b) 0,7 m between any microphone position and the room boundaries;
- c) 0,7 m between any microphone position and any diffusers;
- d) 1,0 m between any microphone position and the test element;
- e) 1,0 m between any microphone position and the sound source.

If fixed microphone positions are used, they shall not be concentrated in the centre of the room (in a centred volume of  $1 \text{ m} \times 1 \text{ m}$  in the room). This constraint is assumed to be achieved with a continuously moving microphone using a rotating arm4

https://standards.iteh.ai/catalog/standards/sist/1928f407-290f-43fb-9922-

# 4.2.3 Averaging times

87160284e88d/iso-fdis-10140-4

#### 4.2.3.1 Fixed microphone positions

At each individual microphone position, the averaging time shall be at least 6 s for each frequency band, with centre frequencies in the frequency range of 100 Hz to 400 Hz. For bands of higher frequencies, it is permissible to decrease the time to not less than 4 s.

#### 4.2.3.2 Continuously moving microphone

The averaging time shall cover a whole number of traverses and shall not be less than 30 s. Using a moving loudspeaker, the measurement period shall equal the time of movement of the loudspeaker which shall be at least 30 s.

## 4.2.4 Energy average sound pressure level

#### 4.2.4.1 Fixed microphone positions

The energy average sound pressure level is determined using Formula (1):

$$L = 10\lg \frac{p_1^2 + p_2^2 + \dots + p_n^2}{np_0^2}$$
 (1)

where  $p_1$ ,  $p_2$ , ...,  $p_n$  are root-mean-square (r.m.s.) sound pressures at n different positions in the room and  $p_0$  is the reference sound pressure and is equal to 20  $\mu$ Pa.

# ISO/FDIS 10140-4:2016(E)

In practice, the sound pressure levels are usually measured and the energy average level, *L*, shall be determined using Formula (2):

$$L = 10\lg \frac{1}{n} \sum_{j=1}^{n} 10^{L_j/10}$$
 (2)

where  $L_1, L_2, ..., L_n$  are the sound pressure levels at n different positions in the room.

#### 4.2.4.2 Continuously moving microphone

The energy average sound pressure level is determined using Formula (3):

$$L = 10 \lg \frac{\frac{1}{T_m} \int_0^{T_m} p^2(t) dt}{p_0^2}$$
 (3)

where

*p* is the sound pressure at the moment *t*, in pascals;

 $p_0$  is the reference sound pressure and is equal to 20 μPa;

 $T_{\rm m}$  is the integration time, which is equal to the averaging time of the sound pressure level, in seconds. **iTeh STANDARD PREVIEW** 

# 4.3 Correction for background noise level ards. iteh.ai)

Measurements of background noise levels shall be made to ensure that the observations in the receiving room are not affected by the background noise. Extraneous sound, such as noise from outside the test room, electrical noise in the receiving system or electrical cross-talk between the source and the receiving systems, all contribute to the background noise level! The background noise level shall be at least 6 dB (and preferably more than 15 dB) below the level of signal and background noise combined at each frequency band.

If the difference in levels is smaller than 15 dB but greater than 6 dB, calculate corrections to the signal level according to Formula (4):

$$L = 10\lg(10^{L_{\rm sb}/10} - 10^{L_{\rm b}/10}) \tag{4}$$

where

L is the adjusted signal level, in decibels:

 $L_{\rm sb}$  is the level of signal and background noise combined, in decibels;

 $L_{\rm b}$  is the background noise level, in decibels.

If the difference in levels is less than or equal to 6 dB in any of the frequency bands, L will be equal to  $L_{\rm sb}$  minus 1,3 dB. For each frequency band where this is the case, it shall be clearly indicated in the report that a 1,3 dB correction has been made and these values are the limit of measurement.

To check the electrical noise in the receiving system or electrical cross-talk between the source and the receiving systems, replace the microphone by a dummy microphone or replace the loudspeaker by an equivalent impedance.

#### 4.4 Measurement of airborne sound insulation

#### 4.4.1 General

Sound shall be generated in the source room using loudspeakers in at least two positions or a single loudspeaker moved to at least two positions or a moving loudspeaker. The qualification procedure for loudspeakers and loudspeaker positions is given in ISO 10140-5:2010, Annex D. The sound pressure level shall be measured using microphones in fixed positions or a moving microphone.

# 4.4.2 Measurements with fixed microphone positions

- a) When using more than one loudspeaker at the same time or a moving loudspeaker, a minimum of five microphone positions shall be used in each room. These shall be distributed within the maximum permitted space throughout each room. Microphone positions shall not lie in the same plane relative to the room boundaries.
- b) When using a single loudspeaker, a minimum of five microphone positions shall be used in each room for each loudspeaker position (additional sets of microphone positions may be different from the first set of positions). Each set of microphone positions shall be distributed within the maximum permitted space throughout each room. Microphone positions shall not lie in the same plane relative to the room boundaries and the positions shall not be in a regular grid.

# 4.4.3 Measurements with a continuously moving microphone

- a) When using more than one loudspeaker at the same time or a moving loudspeaker, at least one measurement with a continuously moving microphone shall be used. The sweep radius shall be at least 1 m. The plane of the traverse shall be inclined in order to cover a large proportion of the permitted room space and shall not lie in any plane that is less than 10° to any room surface (wall, floor or ceiling). The duration of a traverse period shall be not less than 15 s.
- b) When using a single loudspeaker, a minimum of one measurement using a continuously moving microphone shall be used for each loudspeaker position. The sweep radius shall be at least 1 m. The plane of the traverse shall be inclined to cover a large proportion of the permitted room space and shall not lie in any plane that is less than 10° to a room surface (wall, floor or ceiling). The duration of a traverse period shall be not less than 15 s.

The location of the fixed point about which the continuously moving microphone moves may be changed for each loudspeaker position. The same number of measurements shall be taken at each location.

#### 4.5 Measurement of impact sound insulation

## 4.5.1 General

Sound shall be generated using the standard tapping machine. Requirements for the tapping machine are specified in ISO 10140-5:2010, Annex E. Not less than four tapping machine positions shall be used for any measurement.

### 4.5.2 Measurements with fixed microphone positions

The number of microphone positions shall equal the number of tapping machine positions or integer multiples of the number of tapping machine positions.

The same number of microphone positions shall be used for each tapping machine position.

If four or five tapping machine positions are used, at least two measurements of impact sound pressure level shall be made for each tapping machine position. Measurements shall be made in at least two microphone positions for each tapping machine position.