



SLOVENSKI STANDARD
SIST HD 60364-7-704:2007/A11:2017
01-oktober-2017

Nizkonapetostne električne inštalacije - 7-704. del: Zahteve za posebne inštalacije ali lokacije - Gradbišča - Dopnilo A11

Low-voltage electrical installations - Part 7-704: Requirements for special installations or locations - Construction and demolition site installations

Errichten von Niederspannungsanlagen - Teil 7-704: Anforderungen für Betriebsstätten, Räume und Anlagen besonderer Art - Baustellen

Installations électriques basse tension - Partie 7-704: Exigences pour les installations ou emplacements spéciaux - Installations de chantiers de construction et de démolition

<https://standards.iteh.ai/catalog/standards/sist/c1e35fad-e521-4953-973c-68bb4ebc6d21/sist-hd-60364-7-704-2007-a11-2017>

Ta slovenski standard je istoveten z: HD 60364-7-704:2007/A11:2017

ICS:

91.140.50	Sistemi za oskrbo z elektriko	Electricity supply systems
91.200	Gradbena tehnologija	Construction technology

SIST HD 60364-7-704:2007/A11:2017 en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST HD 60364-7-704:2007/A11:2017](https://standards.iteh.ai/catalog/standards/sist/c1e35fad-e521-4953-973c-68bb4ebc6d21/sist-hd-60364-7-704-2007-a11-2017)

<https://standards.iteh.ai/catalog/standards/sist/c1e35fad-e521-4953-973c-68bb4ebc6d21/sist-hd-60364-7-704-2007-a11-2017>

HARMONIZATION DOCUMENT
DOCUMENT D'HARMONISATION
HARMONISIERUNGSDOKUMENT

HD 60364-7-704:2007/A11

August 2017

ICS 29.020; 91.140.50

English Version

**Low-voltage electrical installations - Part 7-704: Requirements
for special installations or locations - Construction and demolition
site installations**

Installations électriques basse tension - Partie 7-704:
Exigences pour les installations ou emplacements spéciaux
- Installations de chantiers de construction et de démolition

Errichten von Niederspannungsanlagen - Teil 7-704:
Anforderungen für Betriebsstätten, Räume und Anlagen
besonderer Art - Baustellen

This amendment A11 modifies the Harmonization Document HD 60364-7-704:2007; it was approved by CENELEC on 2017-05-31. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this amendment at national level.

Up-to-date lists and bibliographical references concerning such national implementations may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This amendment exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

HD 60364-7-704:2007/A11:2017 (E)

European foreword

This document (HD 60364-7-704:2007/A11:2017) has been prepared by CLC/TC 64, "Electrical installations and protection against electric shock".

The following dates are fixed:

- latest date by which this document has (dop) 2018-05-31
to be implemented at national level by
publication of an identical national
standard or by endorsement
- latest date by which the national (dow) 2020-05-31
standards conflicting with this document
have to be withdrawn

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST HD 60364-7-704:2007/A11:2017](https://standards.iteh.ai/catalog/standards/sist/c1e35fad-e521-4953-973c-68bb4ebc6d21/sist-hd-60364-7-704-2007-a11-2017)
<https://standards.iteh.ai/catalog/standards/sist/c1e35fad-e521-4953-973c-68bb4ebc6d21/sist-hd-60364-7-704-2007-a11-2017>

1 Modifications to Annex ZB

Delete the following A-deviation for Denmark:

<u>Clause</u>	<u>Deviation</u>
---------------	------------------

704.410.3.10	Denmark
---------------------	----------------

According to the Danish Heavy Current Regulation, Section (b) the following applies in addition: 704.410.3.10 Circuits supplying socket-outlets with rated current up to and including 32A that supply other ACS are exempted from the use of protection by residual current devices provided that a warning is stated in Danish on the ACS e.g. with the following text:

Kun til forsyning af andre tavler.

Er ikke HFI-beskyttet.

(Only for the supply of other ACS. No RCD protection)

704.511.1	Denmark
------------------	----------------

According to the Danish Heavy Current Regulation, Section 107-2-D1 the following applies:

Single-phase socket-outlets up to and equal to 13 A may be used.

Add the following A-deviation for Denmark

<u>Clause</u>	<u>Deviation</u>
---------------	------------------

704	Denmark
------------	----------------

In Denmark applies, Executive Order on Safety in connection with the Construction and Operation of Electrical Installations. 704:2007/A11:2017

Executive Order no. 1082 from July 12th, 2016, § 60

(1) If a temporary electrical installation is kept for more than three months, the installation must be inspected by an authorised electrical contractor every three months. (2). The owner or user of the temporary electrical installation is responsible for ensuring that such inspection is carried out and that the installation is removed when it is no longer used.

ITeH STANDARD PREVIEW
(standards.iteh.ai)