

# DRAFT INTERNATIONAL STANDARD

## ISO/DIS 17561

ISO/TC 206

Voting begins on:

2015-11-26

Secretariat: JISC

Voting terminates on:

2016-02-26

---

### **Fine ceramics (advanced ceramics, advanced technical ceramics) - Test method for elastic moduli of monolithic ceramics at room temperature by sonic resonance**

*Céramiques techniques — Méthode d'essai des modules d'élasticité des céramiques monolithiques, à température ambiante, par résonance acoustique*

ICS: 81.060.30

**iTeh STANDARD PREVIEW**  
(standards.iteh.ai)  
Full standard:  
<https://standards.iteh.ai/catalog/standards/sist/5874a847-5884-4ed8-806a-1c3a68c82d18/iso-17561-2016>

THIS DOCUMENT IS A DRAFT CIRCULATED FOR COMMENT AND APPROVAL. IT IS THEREFORE SUBJECT TO CHANGE AND MAY NOT BE REFERRED TO AS AN INTERNATIONAL STANDARD UNTIL PUBLISHED AS SUCH.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.



---

Reference number  
ISO/DIS 17561:2015(E)

© ISO 2015

**iTeh STANDARD PREVIEW**  
(standards.iteh.ai)  
Full standard:  
<https://standards.iteh.ai/catalog/standards/sist/5874a847-5884-4ed8-806a-1c3a68c82d8/iso-17561-2016>



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2015, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Ch. de Blandonnet 8 • CP 401  
CH-1214 Vernier, Geneva, Switzerland  
Tel. +41 22 749 01 11  
Fax +41 22 749 09 47  
[copyright@iso.org](mailto:copyright@iso.org)  
[www.iso.org](http://www.iso.org)

# Contents

Page

Foreword .....	iv
1 Scope .....	1
2 Normative references .....	1
3 Terms and definitions .....	1
4 Summary of test method .....	3
5 Apparatus .....	3
5.1 General .....	3
5.2 Oscillator .....	5
5.3 Amplifier .....	5
5.4 Driver .....	5
5.5 Detector .....	5
5.6 Frequency counter .....	6
5.7 Specimen suspension means .....	6
5.8 Micrometer .....	7
5.9 Vernier calliper .....	7
5.10 Balance .....	7
6 Test pieces .....	7
7 Test procedure .....	7
7.1 Measurement of the size and the mass .....	7
7.2 Positioning of the specimen .....	8
7.3 Measurement of resonant frequency .....	10
8 Calculations .....	10
9 Test report .....	12
Bibliography .....	14

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 17561 was prepared by Technical Committee ISO/TC 206, *Fine ceramics*.

This second/third/... edition cancels and replaces the first/second/... edition (), [clause(s) / subclause(s) / table(s) / figure(s) / annex(es)] of which [has / have] been technically revised.

# Fine ceramics (advanced ceramics, advanced technical ceramics) — Test method for elastic moduli of monolithic ceramics at room temperature by sonic resonance

## 1 Scope

This International Standard describes the method of test for determining the dynamic elastic moduli of fine ceramics at room temperature by sonic resonance. This International Standard is for fine ceramics that are elastic, homogeneous and isotropic [1].

## 2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this International Standard. For dated references, subsequent amendments to, or revisions of, any of these publications do not apply. However, parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. For undated references, the latest edition of the normative document referred to applies. Members of ISO and IEC maintain registers of currently valid International Standards.

ISO 3611, *Micrometer callipers for external measurement*

ISO 6906, *Vernier callipers reading to 0,02 mm*

ASTM C1259, *Standard Test Method for Dynamic Young's Modulus, Shear Modulus, and Poisson's Ratio for Advanced Ceramics by Impulse Excitation of Vibration*

## 3 Terms and definitions

For the purposes of this International Standard, the following terms and definitions apply.

### 3.1

#### dynamic elastic moduli

adiabatic elastic moduli, which are dynamic Young's modulus, shear modulus and Poisson's ratio

NOTE Adiabatic elastic moduli are obtained by the sonic resonance method.

#### 3.1.1

##### Young's modulus ( $E$ )

elastic modulus in tension or compression

$$E = \sigma / \varepsilon$$

where

$E$  is Young's modulus in pascals;

$\sigma$  is the tension or compression stress in pascals;

$\varepsilon$  is the tension or compression strain.

### 3.1.2

#### **shear modulus ( $G$ )**

elastic modulus in shear or torsion

$$G = \tau / \gamma$$

where

$G$  is the shear modulus in pascals;

$\tau$  is the shear or torsional stress in pascals;

$\gamma$  is the shear or torsional strain.

### 3.1.3

#### **Poisson's ratio ( $\nu$ )**

ratio of transverse strain to the corresponding axial strain resulting from uniformly distributed axial stress below the proportional limit of the material

NOTE In isotropic materials, Young's modulus ( $E$ ), shear modulus ( $G$ ) and Poisson's ratio ( $\nu$ ) are related by the following equation:

$$\nu = E / (2G) - 1$$

## 3.2

### **Vibrations**

#### 3.2.1

##### **flexural vibrations**

those vibrations apparent when the oscillation in a slender bar is in plane normal to the length dimension

NOTE Also defined as vibrations in a flexural mode.

#### 3.2.2

##### **torsional vibrations**

those vibrations apparent when the oscillation in each cross-section plane of a slender bar is such that the plane twists around the length dimension axis

NOTE Also defined as vibrations in a torsional mode.

## 3.3

### **resonance**

the state if, when a slender bar driven into one of the above modes of vibration, the imposed frequency is such that the resultant displacements for a given amount of driving force are at a maximum

NOTE The resonant frequencies are natural vibration frequencies which are determined by the elastic modulus, mass and dimensions of the test piece.

## 3.4

### **fundamental frequency**

those frequency is defined as the lowest frequency of a periodic waveform

## 3.5

### **nodes**

slender rod or bar in resonance contains one or more locations having a constant zero displacement, called nodes

NOTE For the fundamental flexural resonance, the nodes are located at  $0,224 L$  from each end, where  $L$  is the length of the rod or bar.

## 4 Summary of test method


This test method measures the flexural or torsional frequencies of test specimens of rectangular prism or cylindrical geometry by exciting them at continuously variable frequencies. Mechanical excitation of the specimens is provided through the use of a transducer that transforms a cyclic electrical signal into a cyclic mechanical force on the test piece. A second transducer senses the resulting mechanical vibrations of the test piece and transforms them into an electrical signal. The amplitude and the frequency of the signal are measured by an oscilloscope or other means to detect resonance. The peak response is obtained at the resonant frequency. The fundamental resonant frequencies, dimensions and mass of the specimen are used to calculate the dynamic elastic moduli. The Young's modulus is determined from the flexural resonance frequency, and the shear modulus is determined from the torsional resonance frequency, together with the test piece dimensions and mass. Poisson's ratio is determined from the Young's modulus and the shear modulus.

## 5 Apparatus

### 5.1 General

There are various techniques that may be used to determine the resonant frequency of the test piece. The test piece may be excited by direct mechanical contact of a vibrator, or it may be suspended by a wire from a vibrator. It may be driven electromagnetically by attaching thin foils of magnetic material to one surface, or electrostatically by attaching an electrode to one surface.

One example of the test apparatus is shown in Figure 1. The driving circuit consists of an oscillator, an amplifier, a driver and a frequency counter. The detecting circuit consists of a detector, an amplifier and an oscilloscope. Figure 1 shows the suspension style of the apparatus. The direct contact support style of the test apparatus, shown in Figure 2, is also possible. It consists of a variable-frequency audio oscillator, used to generate a sinusoidal voltage, and a power amplifier and suitable transducer to convert the electrical signal to a mechanical driving vibration. A frequency meter (preferably digital) monitors the audio oscillator output to provide accurate frequency determination. A suitable suspension coupling system supports the test piece. A transducer detector acts to detect mechanical vibration in the specimen and to convert it into an electrical signal which is passed through an amplifier and displayed on an indicating meter. The meter may be a voltmeter, a microammeter or an oscilloscope. An oscilloscope is recommended because it enables the operator to positively identify resonances, including higher order harmonics, by Lissajous figure analysis, which is a superposition of two harmonics. If a Lissajous figure is desired, the output of the oscillator is also coupled to the horizontal plates of the oscilloscope.




Key

- 1 Frequency counter
- 2 Oscillator
- 3 Amplifier
- 4 Driver
- 5 Oscilloscope
- 6 Detector
- 7 Suspending string

Figure 1 — Example of the test apparatus and the suspension for fundamental flexural resonance





#### Key

- 1 Driving
- 2 Detecting
- 3 Flexural

**Figure 2 — Example of the direct contact support of the test piece for fundamental flexural resonance**

## 5.2 Oscillator

The oscillator shall be able to vary the frequency from 100 Hz to at least 30 kHz, with a frequency resolution of 1 Hz and a maximum frequency drift of 1 Hz/min.

## 5.3 Amplifier

The audio amplifier shall have a power output sufficient to ensure that the type of transducer used can excite any specimen the mass of which falls within a specified range. A power amplifier in the detector circuit shall be impedance-matched with the type of detector transducer selected and shall serve as a prescope amplifier.

## 5.4 Driver

The driver shall be able to convert electrical vibration to mechanical vibration. The frequency response of the driver transducer across the frequency range of interest shall have at least a 6,5 kHz bandwidth before – 3 dB power loss occurs.

**NOTE** For flexibility in testing, the bandwidth can, with advantage, be at least as large as the frequency range given in Table 1.

## 5.5 Detector

The detector shall generate a voltage proportional to the amplitude, velocity or acceleration of the mechanical vibration of the specimen. The frequency response of the detector across the frequency range of interest shall have at least a 6.5 kHz bandwidth before a – 3 dB power loss occurs.

**NOTE** For flexibility in testing, the bandwidth can, with advantage, be at least as large as the frequency range given in Table 1.