

SLOVENSKI STANDARD
oSIST prEN 61557-3:2018
01-april-2018

Električna varnost v nizkonapetostnih razdelilnih sistemih za izmenične napetosti do 1 kV in enosmerne napetosti do 1,5 kV - Oprema za preskušanje, merjenje ali nadzorovanje zaščitnih ukrepov - 3. del: Impedanca zanke

Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. - Equipment for testing, measuring or monitoring of protective measures - Part 3: Loop impedance

Elektrische Sicherheit in Niederspannungsnetzen bis AC 1 000 V und DC 1 500 V - Geräte zum Prüfen, Messen oder Überwachen von Schutzmaßnahmen - Teil 3: Schleifenwiderstand

Sécurité électrique dans les réseaux de distribution basse tension de 1 000 V c.a. et 1 500 V c.c. - Dispositifs de contrôle, de mesure ou de surveillance de mesures de protection - Partie 3: Impédance de boucle

Ta slovenski standard je istoveten z: prEN 61557-3:2018

ICS:

17.220.20	Merjenje električnih in magnetnih veličin	Measurement of electrical and magnetic quantities
29.080.01	Električna izolacija na splošno	Electrical insulation in general
29.240.01	Omrežja za prenos in distribucijo električne energije na splošno	Power transmission and distribution networks in general

oSIST prEN 61557-3:2018

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[kSIST FprEN 61557-3:2019](https://standards.iteh.ai/catalog/standards/sist/171f2410-32f0-4073-8bda-801197795a30/ksist-fpren-61557-3-2019)

<https://standards.iteh.ai/catalog/standards/sist/171f2410-32f0-4073-8bda-801197795a30/ksist-fpren-61557-3-2019>



85/631/CDV

COMMITTEE DRAFT FOR VOTE (CDV)

PROJECT NUMBER: IEC 61557-3 ED3	
DATE OF CIRCULATION: 2018-02-09	CLOSING DATE FOR VOTING: 2018-05-04
SUPERSEDES DOCUMENTS: 85/609/CD,85/623/CC	

IEC TC 85 : MEASURING EQUIPMENT FOR ELECTRICAL AND ELECTROMAGNETIC QUANTITIES	
SECRETARIAT: China	SECRETARY: Mr Bo Chen
OF INTEREST TO THE FOLLOWING COMMITTEES: TC 44,TC 64,TC 66	PROPOSED HORIZONTAL STANDARD: <input type="checkbox"/> Other TC/SCs are requested to indicate their interest, if any, in this CDV to the secretary.
FUNCTIONS CONCERNED: <input type="checkbox"/> EMC <input type="checkbox"/> ENVIRONMENT <input type="checkbox"/> QUALITY ASSURANCE <input checked="" type="checkbox"/> SAFETY	
<input checked="" type="checkbox"/> SUBMITTED FOR CENELEC PARALLEL VOTING	<input type="checkbox"/> NOT SUBMITTED FOR CENELEC PARALLEL VOTING
<p>Attention IEC-CENELEC parallel voting https://standards.iteh.ai/catalog/standards/sist/171f2410-32f0-4073-8bda-891f97285786/iec-61557-3-2019</p> <p>The attention of IEC National Committees, members of CENELEC, is drawn to the fact that this Committee Draft for Vote (CDV) is submitted for parallel voting.</p> <p>The CENELEC members are invited to vote through the CENELEC online voting system.</p>	

This document is still under study and subject to change. It should not be used for reference purposes.

Recipients of this document are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

TITLE:

Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. - Equipment for testing, measuring or monitoring of protective measures - Part 3: Loop impedance

PROPOSED STABILITY DATE: 2025

NOTE FROM TC/SC OFFICERS:

- 2 -
CONTENTS

85/631/CDV

2			
3			
4	FOREWORD		- 3 -
5	1 Scope		- 5 -
6	2 Normative references		- 5 -
7	3 Terms and definitions		- 5 -
8	4 Requirements		- 6 -
9	4.1 General		- 6 -
10	4.2 Measurement of loop impedance		- 6 -
11	4.3 External resistance		- 6 -
12	4.4 Fault voltage exceeding U_L		- 6 -
13	4.5 Overvoltage		- 6 -
14	5 Marking and operating instructions		- 6 -
15	5.1 Marking		- 6 -
16	5.2 Operating instructions		- 7 -
17	6 Tests		- 7 -
18	6.1 General		- 7 -
19	6.2 Operating uncertainty		- 7 -
20	6.3 External resistance		- 9 -
21	6.4 Fault voltage		- 9 -
22	6.5 Overvoltage		- 9 -
23	Bibliography		- 10 -
24			
25	Table 1 – Calculation of operating uncertainty		- 8 -
26			

ITeCh STANDARD PREVIEW
(standards.iteh.ai)

kSIST EprEN 61557-3:2019
<https://standards.iteh.ai/catalog/standards/sist/17112410-32f0-4073-8bda-801197795a30/ksist-fpren-61557-3-2019>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICAL SAFETY IN LOW VOLTAGE DISTRIBUTION SYSTEMS
UP TO 1 000 V AC AND 1 500 V DC –
EQUIPMENT FOR TESTING, MEASURING OR MONITORING
OF PROTECTIVE MEASURES –****Part 3: Loop impedance****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61557-3 has been prepared by IEC technical committee TC85:
Measuring equipment for electrical and electromagnetic quantities

This third edition cancels and replaces the second edition published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) requirement for measurement category added
- b) new requirements for operating instructions added
- c) Alignment of the structure to the whole series IEC61557

The text of this standard is based on the following documents:

FDIS	Report on voting
XX/XX/FDIS	XX/XX/RVD

83
84 Full information on the voting for the approval of this standard can be found in the report on
85 voting indicated in the above table.

86 This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

87 This part of IEC 61557 shall be used in conjunction with Part 1.

88 A list of all parts in the IEC 61557 series, published under the general title *Electrical safety in*
89 *low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing,*
90 *measuring or monitoring of protective measure,* can be found on the IEC website.

91 The committee has decided that the contents of this publication will remain unchanged until
92 the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data
93 related to the specific publication. At this date, the publication will be

- 94 • reconfirmed,
- 95 • withdrawn,
- 96 • replaced by a revised edition, or
- 97 • amended.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

99 The National Committees are requested to note that for this publication the stability date
100 is 2025

101 THIS TEXT IS INCLUDED FOR THE INFORMATION OF THE NATIONAL COMMITTEES AND WILL BE
102 DELETED AT THE PUBLICATION STAGE.

[kSIST FprEN 61557-3:2019](https://standards.iteh.ai/catalog/standards/sist/171f2410-32f0-4073-8bda-801197795a30/ksist-fpren-61557-3-2019)

<https://standards.iteh.ai/catalog/standards/sist/171f2410-32f0-4073-8bda-801197795a30/ksist-fpren-61557-3-2019>

**ELECTRICAL SAFETY IN LOW VOLTAGE DISTRIBUTION SYSTEMS
UP TO 1 000 V AC AND 1 500 V DC –
EQUIPMENT FOR TESTING, MEASURING OR MONITORING
OF PROTECTIVE MEASURES –**

Part 3: Loop impedance

1 Scope

This part of IEC 61557 specifies the requirements applicable to equipment for measuring the loop impedance between a line conductor and the protective conductor or between a line conductor and neutral or between two line conductors by using the voltage drop when the circuit under test is loaded.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61010-1:2010, AMD1:2016, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1: General requirements*

IEC 61010-2-030:2017, *Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 2-030: Particular requirements for equipment having testing or measuring circuits*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61557-1 and the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

1.1 3.1

loading (method of)

method of loading a circuit within a distribution system to cause a voltage drop

1.2 3.2

loading equipment

part of the measuring equipment to load the circuit being tested

1.3 3.3

test current

electric current controlled by the measuring device to cause a voltage drop in a circuit being tested

1.4 3.4

system phase angle

angle between loop impedance and loop resistance of the distribution system

1.5 3.5

loop impedance

Z_L

sum of the impedances in a current loop comprising the impedance of the source of the current, the impedance of the line conductor (e.g. protective conductor, earth electrode and earth) from the point of measurement to the other terminal of the source of the current

146 4 Requirements

147 4.1 General

148 In addition to the requirements of Clause 4 of IEC 61557-1, the requirements of Clause 4 shall apply.

149 Equipment intended to be used on the distribution system shall be rated at least for measurement
150 category III according to IEC 61010-2-030.

151 Equipment intended to be used on the socket-outlets only can be rated for measurement category II
152 according to IEC 61010-2-030.

153 4.2 Measurement of loop impedance

154 For measurements in close proximity to the transformer of the distribution system, equipment with a
155 specified loop impedance measuring function (influence quantity for system phase angle at the
156 minimum of 30°) shall be used or a specified additional operating uncertainty shall be taken into
157 account by the user.

158 In applications where the measurement of loop resistance is carried out in close proximity to the
159 sourcing transformer (e.g. <50 m) the system phase angle may be more than 18° (e.g. up to 30°) and
160 therefore the inductive part of the internal impedance of transformer may not be negligible.

161 When the loading by loading equipment causes transients on the distribution system, the operating
162 uncertainty shall not be exceeded as a result of the transient.

163 Equipment with specified influence quantity $E_{6.1}$ of system phase angle of 18° shall be marked with the
164 warning symbol No. 14 according to Table 1 of IEC 61010-1:2010 adjacent to the loop function
165 marking or a warning shall be given on the display.

166 4.3 External resistance

167 When external resistances are included in the calibration as a zero offset, this shall be indicated.

168 This offset shall remain included as long as it is indicated regardless of any changes in range or
169 function.

170 4.4 Fault voltage exceeding U_L

171 Fault voltages as a result of the measurement, which exceed U_L at the point of test, shall be avoided.
172 This can be achieved by automatic disconnection in accordance with Figure 2 of IEC 61010-1:2010.

173 4.5 Overvoltage

174 The measuring equipment shall not be damaged nor shall the user be exposed to danger when the
175 measuring equipment is connected to 120 % of the nominal voltage of the distribution system for
176 which the measuring equipment has been designed. Protective devices of the test equipment shall not
177 be activated.

178 The user shall not be exposed to danger and the equipment shall not be damaged when the
179 measuring equipment is accidentally connected to a voltage having a value of 173 % of its rated
180 voltage to earth according to IEC 61010-2-030 for 1 min. Protective devices of the test equipment can
181 be activated.

182 If the measuring equipment indicates the value of the voltage at its measuring terminals, it shall also
183 indicate if the system voltage exists and if the live conductor is exchanged with the protective
184 conductor.

185 5 Marking and operating instructions

186 5.1 Marking

187 In addition to Clause 5 of IEC 61557-1, the following information shall be provided on the measuring
188 equipment.

189 Marking is permitted on the display for any of the following:

- 190 – Range of the resistance of the loop impedance or of the calculated short-circuit current
- 191 respectively within which compliance with the uncertainty limits in accordance with 4.2 is
- 192 maintained.
- 193 – Nominal system voltage for which the equipment is rated.
- 194 – Rated system frequency for which the equipment is rated.
- 195 – Phase angle of the loading equipment when this angle is $>18^\circ$
- 196 – Rated voltage to earth and measurement category.

197 **5.2 Operating instructions**

198 In addition to Clause 5 of IEC 61557-1, the following information shall be provided in the operating
199 instructions for the measuring equipment.

- 200 – Data relating to the loading equipment if the phase angle is $>18^\circ$.
- 201 – The amplitude and waveform of test current and duration of loading.
- 202 – Range of system voltages within which the operating uncertainty stated in 4.2 is not exceeded.
- 203 – Range of loop impedance (magnitude and angle) within which the operating uncertainty stated in
- 204 4.2 is not exceeded.
- 205 – Information on possible measurement uncertainties, for example due to preloading the circuit
- 206 under test.
- 207 – Data relating to the effect of system voltage variations and other effects from the system such as
- 208 measuring in close proximity to the transformer of the distribution system. A specific user
- 209 correction shall be stated, unless the instrument has a fully specified loop impedance measuring
- 210 function.

211 **6 Tests**

212 **6.1 General**

213 In addition to Clause 6 of IEC 61557-1 the following tests shall be performed.

214 **6.2 Operating uncertainty**

215 The operating uncertainty shall be determined under the rated operating conditions of IEC 61557-1
216 and in addition the following shall apply:

- 217 – the electrical distribution system on which a loop impedance test is performed shall be under
- 218 constant load condition, except for load changes provoked by the test instrument;
- 219 – measurement shall be carried out without changing existing loads within the electrical distribution
- 220 system under test;
- 221 – system voltage shall be between 85 % and 110 % of the nominal voltage of the distribution system
- 222 for which the equipment has been designed;
- 223 – system frequency shall be between 99 % and 101 % of the nominal frequency of the distribution
- 224 system for which the equipment has been designed;
- 225 – system voltage and frequency shall not change during the measurement by more than 0,5 %;
- 226 – measured circuit shall be loaded with loading equipment.

227 The operating uncertainty shall be calculated in accordance with Table 1. In this process, the intrinsic
228 uncertainty shall be determined under the following reference conditions:

- 229 – nominal system voltage;
- 230 – nominal system frequency;
- 231 – reference temperature $23\text{ }^\circ\text{C} \pm 2\text{ }^\circ\text{C}$;

- 232 – reference position in accordance with the manufacturer's statement;
- 233 – nominal distribution system supply or battery voltage respectively;
- 234 – difference between phase angle of the loading equipment and the loop impedance of the circuit
- 235 under test $\leq 5^\circ$.
- 236 – The maximum percentage operating uncertainty within the measuring range to be marked or stated
- 237 shall not exceed $\pm 30\%$ with the measured value as the fiducial value, as determined in
- 238 accordance with Table 1.

Table 1 – Calculation of operating uncertainty

Intrinsic uncertainty or influence quantity	Reference conditions or specified operating range	Designation code	Requirements or tests in accordance with relevant parts of IEC 61557	Type of test
Intrinsic uncertainty	Reference conditions	A	Part 3, Subclause 6.1	R
Position (on equipment using mechanical displays)	Reference position $\pm 90^\circ$	E_1	Part 1, Subclause 6.2	R
Supply voltage	At the limits stated by the manufacturer	E_2	Part 1, Subclauses 6.2, 6.3	R
Temperature	0 °C and 35 °C	E_3	Part 1, Subclause 6.2	T
Phase angle	At a phase angle 0° to 18°	E_6	Part 3, Subclause 6.2	T
System phase angle	At a system phase angle 0° to 18° at the bottom of the measurement range	$E_{6.1}^a$	Part 3, Subclause 6.2	T
System phase angle	At a system phase angle 0° to 30° at the bottom of the measurement range	$E_{6.2}^a$	Part 3, Subclause 6.2	T
System frequency	95 % to 105 % of the nominal frequency	E_7	Part 3, Subclause 6.2	T
System voltage	85 % to 110 % of the nominal voltage	E_8	Part 3, Subclause 6.2	T
Harmonics	5 % of 3 rd harmonic at 0° phase angle 6 % of 5 th harmonic at 180° phase angle 5 % of 7 th harmonic at 0° phase angle (percentage of the fundamental of nominal voltage of distribution system)	E_9	Part 3, Subclause 6.2	T
D.c quantity	Add additional DC quantities of 0,5 % of the nominal voltage of distribution system in both polarities. It is recommended that manufacturers include E_{10} into the calculation of operating uncertainty according to this table.	E_{10}^b	Part 3, Subclause 6.2	T
Operating uncertainty	$B = \pm \sqrt{A^2 + \frac{4}{3} \sum_i E_i^2}$		Part 3, Subclause 6.2	R
A	=	intrinsic uncertainty	$B [\%] = \pm \frac{B}{F} \cdot 100 \%$	
E_i	=	variations		
R	=	routine test		
T	=	type test		
F	=	fiducial value		