
**Požarna klasifikacija gradbenih proizvodov in elementov stavb - 2. del:
Klasifikacija na podlagi podatkov iz preskusov požarne odpornosti, izvzete so
prezračevalne naprave**

Fire classification of construction products and building elements - Part 2: Classification using data from fire resistance tests, excluding ventilation services

Klassifizierung von Bauprodukten und Bauarten zu ihrem Brandverhalten - Teil 2: Klassifizierung mit den Ergebnissen aus den Feuerwiderstandsprüfungen, mit Ausnahme von Lüftungsanlagen

Classement au feu des produits et éléments de construction — Partie 2 : Classement à partir des données d'essais de résistance au feu à l'exclusion des produits utilisés dans les systèmes de ventilation

Ta slovenski standard je istoveten z: prEN 13501-2

ICS:

| | | |
|-----------|---|--|
| 13.220.50 | Požarna odpornost gradbenih materialov in elementov | Fire-resistance of building materials and elements |
|-----------|---|--|

oSIST prEN 13501-2:2021

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[oSIST prEN 13501-2:2021](#)

<https://standards.iteh.ai/catalog/standards/sist/6a497ad0-80d6-4f22-8f35-0901933411f5/osist-pren-13501-2-2021>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

DRAFT
prEN 13501-2

August 2021

ICS 13.220.50

Will supersede EN 13501-2:2016

English Version

Fire classification of construction products and building elements - Part 2: Classification using data from fire resistance tests, excluding ventilation services

Classement au feu des produits et éléments de construction - Partie 2 : Classement à partir des données d'essais de résistance au feu à l'exclusion des produits utilisés dans les systèmes de ventilation

Klassifizierung von Bauprodukten und Bauarten zu ihrem Brandverhalten - Teil 2: Klassifizierung mit den Ergebnissen aus den Feuerwiderstandsprüfungen, mit Ausnahme von Lüftungsanlagen

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 127.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

| Contents | Page |
|---|-------------|
| European foreword..... | 4 |
| Introduction..... | 6 |
| 1 Scope | 7 |
| 2 Normative references | 8 |
| 3 Terms and definitions..... | 11 |
| 4 Fire scenarios..... | 16 |
| 4.1 General..... | 16 |
| 4.2 The standard temperature/time curve (post flash-over fire) | 16 |
| 4.3 The slow heating curve (smouldering fire) | 16 |
| 4.4 The ‘semi-natural’ fire | 17 |
| 4.5 The external fire exposure curve | 17 |
| 4.6 Constant temperature attack..... | 17 |
| 5 Resistance to fire performance characteristics..... | 18 |
| 5.1 General..... | 18 |
| 5.2 Performance characteristics | 18 |
| 5.2.1 R - Loadbearing capacity..... | 18 |
| 5.2.2 E - Integrity | 18 |
| 5.2.3 I - Thermal insulation | 19 |
| 5.2.4 W - Radiation..... | 21 |
| 5.2.5 M - Mechanical action..... | 21 |
| 5.2.6 C - Self-closing..... | 21 |
| 5.2.7 S - Smoke leakage | 22 |
| 5.2.8 O - Normal operating conditions..... | 22 |
| 5.2.9 G - ‘Soot fire’ resistance | 22 |
| 5.2.10 K - Fire protection ability | 23 |
| 6 Declaration of fire resistance performance..... | 23 |
| 6.1 Classification periods..... | 23 |
| 6.2 Designatory letters | 23 |
| 6.3 Declaration of performance | 24 |
| 6.4 Combinations of classes | 24 |
| 6.5 Particular classifications | 24 |
| 6.5.1 Doors and shutters..... | 24 |
| 6.5.2 Conveyor systems and their closures..... | 25 |
| 6.6 Additional performance parameters | 25 |
| 6.6.1 Optional performance parameters | 25 |
| 6.6.2 Expansion of performance parameters..... | 25 |
| 6.6.3 Particular performance parameters | 26 |
| 6.7 Presentation of classification..... | 26 |
| 6.8 Declaration of fire resistance classes in product specifications | 26 |
| 7 Classification procedure for fire resistance | 27 |
| 7.1 General..... | 27 |
| 7.1.1 Procedure..... | 27 |

| | | |
|--------|---|----|
| 7.1.2 | General rules for deducing the number of standard temperature/time fire resistance tests | 28 |
| 7.1.3 | Field of application | 30 |
| 7.2 | Classification of loadbearing elements without a fire separating function | 30 |
| 7.2.1 | General | 30 |
| 7.2.2 | Classification of loadbearing walls without separating function..... | 30 |
| 7.2.3 | Classification of loadbearing floors and roofs without fire separating function..... | 31 |
| 7.2.4 | Classification of beams | 32 |
| 7.2.5 | Classification of columns | 33 |
| 7.2.6 | Classification of balconies, walkways and stairs..... | 34 |
| 7.3 | Classification of loadbearing elements with fire separating function | 35 |
| 7.3.1 | General | 35 |
| 7.3.2 | Classification of loadbearing walls with fire separating function | 35 |
| 7.3.3 | Classification of loadbearing floors and roofs with fire separating function | 37 |
| 7.3.4 | Classification of raised floors | 39 |
| 7.4 | Products and systems for protecting elements or parts of works | 41 |
| 7.4.1 | General | 41 |
| 7.4.2 | Tests to be carried out | 41 |
| 7.4.3 | Test methods..... | 42 |
| 7.4.4 | Performance criteria..... | 42 |
| 7.4.5 | Classes..... | 42 |
| 7.4.6 | Classification of protected structural members..... | 42 |
| 7.5 | Classification of non-loadbearing elements..... | 46 |
| 7.5.1 | General | 46 |
| 7.5.2 | Partitions..... | 46 |
| 7.5.3 | Classification of facades (curtain walling) and external walls (including glazed elements)..... | 48 |
| 7.5.4 | Classification of ceilings with independent fire resistance..... | 50 |
| 7.5.5 | Classification of fire doors and shutters including their closing devices..... | 51 |
| 7.5.6 | Classification of smoke control doors..... | 53 |
| 7.5.7 | Classification of closure and conveyor system assemblies | 55 |
| 7.5.8 | Classification of penetration seals..... | 56 |
| 7.5.9 | Classification of linear joint seals..... | 58 |
| 7.5.10 | Classification of service ducts and shafts..... | 60 |
| 7.5.11 | Classification of chimneys | 62 |
| 7.5.12 | Classification of air transfer grilles..... | 65 |
| 7.6 | Classification of wall and ceiling coverings for fire protection ability..... | 67 |
| 7.6.1 | General | 67 |
| 7.6.2 | Test method..... | 67 |
| 7.6.3 | Tests to be carried out | 67 |
| 7.6.4 | Performance criteria for fire protection ability..... | 68 |
| 7.6.5 | Classes..... | 69 |
| | Bibliography | 87 |

European foreword

This document (prEN 13501-2:2021) has been prepared by Technical Committee CEN/TC 127 “Fire safety in buildings”, the secretariat of which is held by BSI.

This document is currently submitted to the CEN Enquiry.

This document will supersede EN 13501-2:2016.

Changes have been made in this revision to bring it in line with the relevant current EC Decisions on fire resistance classification, and experience in use in the first edition. In comparison with the previous edition, the following technical modifications have been made:

- In 7.5.2.1: adding reference to new EXAP standard;
- In all paragraphs concerned: introduction of proposal from TC/166 for Chimney;
- In all paragraphs concerned: introduction of proposal for Air transfer Grid;
- In all paragraphs concerned: introduction of FprEN 15882-5;
- In all paragraphs concerned: update on criterion description for load bearing elements (EN 1363-1):
- In 7.3.2: modification related to EN 1365-1;
- In 7.5.2.1: introduction of EN 15252-3;
- In 7.3.4.4: modification of classification table;
- In 7.5.9.4: modification of classification table.

EN 13501, *Fire classification of construction products and building elements*, consists of the following Parts:

- *Part 1: Classification using data from reaction to fire tests*
- *Part 2: Classification using data from fire resistance tests, excluding ventilation services*
- *Part 3: Classification using data from fire resistance tests on components of normal building service installations: fire resisting ducts and fire dampers*
- *Part 4: Classification using data from fire resistance tests on components of smoke control systems*
- *Part 5: Classification using data from external fire exposure to roof tests*
- *Part 6: Classification using data from reaction to fire tests on power, control and communication cables*

CEN, CENELEC and EOTA committees preparing technical specifications which contain performance requirements against fire resistance tests are expected to make reference to the fire resistance classification given in this document and not refer directly to any specific fire test method.

This document has been prepared under a Standardization Request given to CEN by the European Commission and the European Free Trade Association.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[oSIST prEN 13501-2:2021](https://standards.iteh.ai/catalog/standards/sist/6a497ad0-80d6-4f22-8f35-0901933411f5/osist-pren-13501-2-2021)

<https://standards.iteh.ai/catalog/standards/sist/6a497ad0-80d6-4f22-8f35-0901933411f5/osist-pren-13501-2-2021>

Introduction

The aim of this document is to define a harmonized procedure for the classification for resistance to fire of construction products and building elements. This classification is based on the test procedures listed in Clause 2 and the relevant field of application procedures.

This document is prepared in support of the second basic requirement, in the EC Construction Products Regulation (305/2011) and is detailed in the Interpretative Document number 2 (ID2): Safety in case of fire (OJC62 Vol 37).

The Interpretative Document and the Commission Decision of 2 May 2000 specify performance and classes regarding fire resistance. These classes are identified by designation letters, each of which refers to an important characteristic of fire resistance behaviour.

This document provides for a common understanding for these requirements. It interprets the functional requirements for the different groups of building elements and explains the method for deriving their classification on the basis of test results and/or extended application results for individual elements.

NOTE Test reports constitute the basis for extended application reports as explained in EN 15725.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[oSIST prEN 13501-2:2021](https://standards.iteh.ai/catalog/standards/sist/6a497ad0-80d6-4f22-8f35-0901933411f5/osist-pren-13501-2-2021)

<https://standards.iteh.ai/catalog/standards/sist/6a497ad0-80d6-4f22-8f35-0901933411f5/osist-pren-13501-2-2021>

1 Scope

This document specifies the procedure for classification of construction products and building elements using data from fire resistance and smoke leakage tests which are within the direct field of application of the relevant test method. Classification on the basis of extended application of test results is also included in the scope of this document.

This document deals with:

- a) loadbearing elements without a fire separating function:
- walls;
 - floors;
 - roofs;
 - beams;
 - columns;
 - balconies;
 - walkways;
 - stairs.
- b) loadbearing elements with a fire separating function, with or without glazing, services and fixtures:
- <https://standards.iteh.ai/catalog/standards/sist/6a497ad0-80d6-4f22-8f35-0901933411f5/osist-pren-13501-2-2021>
- walls;
 - floors;
 - roofs;
 - raised floors.
- c) products and systems for protecting elements or parts of the works:
- ceilings with no independent fire resistance;
 - fire protective coatings, claddings and screens;
- d) non-loadbearing elements or parts of works, with or without glazing, services and fixtures:
- partitions;
 - facades (curtain walls) and external walls;
 - ceilings with independent fire resistance;
 - raised floors;

prEN 13501-2:2021(E)

- fire doors and shutters and their closing devices;
 - smoke control doors;
 - conveyor systems and their closures;
 - penetration seals;
 - linear joint seals;
 - service ducts and shafts;
 - air transfer grilles.
 - chimneys.
- e) wall and ceiling coverings with fire protection ability.
- f) lift landing doors which are tested according to EN 81-58 are excluded from this document. Lift landing doors which are tested in accordance with EN 1634-1 are classified in accordance with 7.5.5.

Relevant test methods which have been prepared for these elements are listed in Clauses 2 and 7.

iTeh STANDARD PREVIEW (standards.iteh.ai)

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-2, *Fire resistance tests - Part 2: Alternative and additional procedures*

EN 1364-1:2015, *Fire resistance tests for non-loadbearing elements - Part 1: Walls*

EN 1364-2:1999, *Fire resistance tests for non-loadbearing elements — Part 2: Ceilings*

EN 1364-3, *Fire resistance tests for non-loadbearing elements - Part 3: Curtain walling - Full configuration (complete assembly)*

EN 1364-4, *Fire resistance tests for non-loadbearing elements - Part 4: Curtain walling - Part configuration*

EN 1364-5:2017, *Fire resistance tests for non-loadbearing elements - Part 5: Air transfer grilles*

EN 1365-1:2012, *Fire resistance tests for loadbearing elements - Part 1: Walls*

EN 1365-2:2014, *Fire resistance tests for loadbearing elements - Part 2: Floors and roofs*

EN 1365-3, *Fire resistance tests for loadbearing elements - Part 3: Beams*

EN 1365-4, *Fire resistance tests for loadbearing elements - Part 4: Columns*

EN 1365-5, *Fire resistance tests for loadbearing elements - Part 5: Balconies and walkways*

- EN 1365-6, *Fire resistance tests for loadbearing elements - Part 6: Stairs*
- EN 1366-3, *Fire resistance tests for service installations - Part 3: Penetration seals*
- EN 1366-4, *Fire resistance tests for service installations - Part 4: Linear joint seals*
- EN 1366-5, *Fire resistance tests for service installations - Part 5: Service ducts and shafts*
- EN 1366-6, *Fire resistance tests for service installations - Part 6: Raised access and hollow core floors*
- EN 1366-7:2004, *Fire resistance tests for service installations - Part 7: Conveyor systems and their closures*
- EN 1443:2019, *Chimneys - General requirements*
- EN 1634-1:2014, *Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware — Part 1: Fire resistance test for door and shutter assemblies and openable windows*
- EN 1634-3:2004, *Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware - Part 3: Smoke control test for door and shutter assemblies*
- EN 13216-1:2019, *Chimneys - Test methods for system chimneys - Part 1: General test methods*
- EN 13381-1, *Test methods for determining the contribution to the fire resistance of structural members - Part 1: Horizontal protective membranes*
- EN 13381-2, *Test methods for determining the contribution to the fire resistance of structural members - Part 2: Vertical protective membranes*
- EN 13381-3, *Test methods for determining the contribution to the fire resistance of structural members - Part 3: Applied protection to concrete members*
- EN 13381-4, *Test methods for determining the contribution to the fire resistance of structural members - Part 4: Applied passive protection to steel members*
- EN 13381-5, *Test methods for determining the contribution to the fire resistance of structural members - Part 5: Applied protection to concrete/profiled sheet steel composite member*
- EN 13381-6, *Test methods for determining the contribution to the fire resistance of structural members - Part 6: Applied protection to concrete filled hollow steel columns*
- ENV 13381-7, *Test methods for determining the contribution to the fire resistance of structural members — Part 7: Applied protection to timber members*
- EN 13381-8, *Test methods for determining the contribution to the fire resistance of structural members - Part 8: Applied reactive protection to steel members*
- EN 13381-9, *Test methods for determining the contribution to the fire resistance of structural members - Part 9: Applied fire protection systems to steel beams with web openings*
- EN 14135, *Coverings - Determination of fire protection ability*

prEN 13501-2:2021(E)

EN 15080-8, *Extended application of results from fire resistance tests - Part 8: Beams*

EN 15080-12, *Extended application of results from fire resistance tests - Part 12: Loadbearing masonry walls*

EN 15254-2, *Extended application of results from fire resistance tests - Non-loadbearing walls - Part 2: Masonry and Gypsum Blocks*

EN 15254-4, *Extended application of results from fire resistance tests - Non-loadbearing walls - Part 4: Glazed constructions*

EN 15254-3, *Extended application of results from fire resistance tests - Non-loadbearing walls - Part 3: Lightweight partitions*

EN 15254-5, *Extended application of results from fire resistance tests - Non-loadbearing walls - Part 5: Metal sandwich panel construction*

EN 15254-6, *Extended application of results from fire resistance tests - Non-loadbearing walls - Part 6: Curtain walling*

EN 15254-7, *Extended application of results from fire resistance tests - Non-loadbearing ceilings - Part 7: Metal sandwich panel construction*

EN 15269-1, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware - Part 1: General requirements*

EN 15269-2, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware - Part 2: Fire resistance of hinged and pivoted steel doorsets*

EN 15269-3, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware - Part 3: Fire resistance of hinged and pivoted timber doorsets and openable timber framed windows*

EN 15269-5, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware — Part 5: Fire resistance of hinged and pivoted metal framed glazed doorsets and openable windows*

prEN 15269-6, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware — Part 6: Fire resistance of sliding timber doorsets*

EN 15269-7, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware - Part 7: Fire resistance for steel sliding doorsets*

EN 15269-10, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies including their elements of building hardware - Part 10: Fire resistance of steel rolling shutter assemblies*

prEN 15269-11, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware — Part 11: Fire resistance for operable fabric curtains*

EN 15269-20, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware - Part 20: Smoke control for doors, shutters, operable fabric curtains and openable windows*

EN 15725, *Extended application reports on the fire performance of construction products and building elements*

EN 15882-3, *Extended applications of results from fire resistance tests for service installations - Part 3: Penetration seals*

EN 15882-4, *Extended application of results from fire resistance tests for service installations - Part 4: Linear joint seals*

EN 16034, *Pedestrian doorsets, industrial, commercial, garage doors and openable windows - Product standard, performance characteristics - Fire resisting and/or smoke control characteristics*

EN ISO 13943:2010, *Fire safety — Vocabulary (ISO 13943:2008)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN ISO 13943:2010 and the following apply.

3.1

element of building construction

defined part of a construction component, such as wall, partition, floor, roof, beam or column

Note 1 to entry: Element covers both individual products and elements made up of one or more products.

[SOURCE: EN 1363-1:2012]

3.2

ceiling

non-loadbearing element of a building construction designed to provide horizontal fire separation

[SOURCE: EN 1364-2:1999]

3.3

self-supporting ceiling

ceiling with a span from wall to wall, without any additional suspension devices

[SOURCE: EN 1364-2:1999]

3.4

door or shutter assembly (doorset)

pedestrian doorset or industrial type doorset including any frame or guide, door leaf or leaves, rolling or folding curtain, etc; which is provided to give a fire resisting capability when used for the closing of permanent openings in fire resisting elements, which includes any side panel(s), flush over panel(s) transom panel(s) and/or glazing together with the building hardware and any seals (whether provided for the purpose of fire resistance or smoke control or for other purposes such as draught or acoustics) which form the assembly

[SOURCE: EN 1634-1:2014]

prEN 13501-2:2021(E)**3.5****floor**

horizontal separating element of building construction which is loadbearing

[SOURCE: EN 1365-2:2014]

3.6**roof**

horizontal or sloped separating element of building construction which is loadbearing and includes the roof covering

[SOURCE: EN 1365-2:2014]

3.7**ceiling****suspended ceiling**

lining plus any supporting framework, including hangers, fixings and any insulation material suspended from the structural building member

[SOURCE: EN 1365-2:2014]

3.8**ceiling system**

full ceiling assembly submitted for test, including hangers and fixings, e.g. lighting and ventilation ductings and access points

[SOURCE: EN 1365-2:2014]

3.9**loadbearing wall**

wall designed to support a vertically applied load

3.10**non-loadbearing wall**

wall designed not to be subjected to any load other than its self weight

[SOURCE: EN 1364-1:2015]

3.11**internal wall**

wall with or without glazing which provides fire separation and which may be exposed separately to a fire from either side

[SOURCE: EN 1364-1:2015 and EN 1365-1:2012]

3.12**external wall**

wall forming the external envelope of a building including glazing which may be exposed separately to an internal or an external fire

[SOURCE: EN 1364-1:2015 and EN 1365-1:2012]

3.13**insulated wall**

wall, with or without glazing, which satisfies both the integrity and insulation criteria for the achieved fire resistance period

[SOURCE: EN 1364-1:2015 and EN 1365-1:2012]

3.14**un-insulated wall**

wall, with or without glazing, which satisfies the integrity and, where required, the radiation criteria for the achieved fire resistance period but which is not intended to provide insulation

Note 1 to entry: Such a wall can consist entirely of un-insulated fire resistant glazing.

[SOURCE: EN 1364-1:2015 and EN 1365-1:2012]

3.15**separating wall**

wall with or without glazing provided within a building or between adjoining buildings to prevent the transfer of fire from one side to the other

[SOURCE: EN 1365-1:2012]

3.16**curtain wall**

external non-loadbearing wall which is independent of the structural frame and supported in place in front of loadbearing structures. A curtain wall typically includes panels, glazing, seals, fixings, transoms and mullions

iTeh STANDARD PREVIEW

(standards.iteh.ai)

[oSIST prEN 13501-2:2021](https://standards.iteh.ai/catalog/standards/sist/6a497ad0-80d6-4f22-8f35-0901933411f5/osist-pren-13501-2-2021)

<https://standards.iteh.ai/catalog/standards/sist/6a497ad0-80d6-4f22-8f35-0901933411f5/osist-pren-13501-2-2021>

3.17**fire resistant glazing**

glazing system consisting of one or more transparent or translucent panes with a suitable method of mounting, with e.g. frames, seals and fixing materials, capable of satisfying the appropriate fire resistance criteria

[SOURCE: EN 1364-1:2015]

3.18**insulated glazing**

fire resistant glazing which satisfies both the integrity and insulation criteria for the achieved fire resistance period

[SOURCE: EN 1364-1:2015]

3.19**un-insulated glazing**

fire resistance glazing which satisfies the integrity and, where required, the radiation criteria for the achieved fire resistance period but which is not intended to provide insulation

[SOURCE: EN 1364-1:2015]