



SLOVENSKI STANDARD
oSIST prEN IEC 60309-2:2019

01-oktober-2019

Vtiči, fiksne ali prenosne vtičnice in vtičnice za industrijsko rabo - 2. del: Zahteve za dimenzijsko izmenljivost pribora s trni in pušami

Plugs, fixed or portable socket- outlets and appliance inlets for industrial purposes - Part 2: Dimensional interchangeability requirements for pin and contact-tube accessories

Stecker, Steckdosen und Kupplungen für industrielle Anwendungen - Teil 2: Anforderungen und Hauptmaße für die Austauschbarkeit von Stift- und Buchsensteckvorrichtungen

(standards.iteh.ai)

Prises de courant pour usages industriels - Partie 2: Règles d'interchangeabilité dimensionnelle pour les appareils à broches et alvéoles

KSIST prEN IEC 60309-2:2021
<https://standards.iteh.ai/catalog/standards/sist/6d7336c3-dbf5-4d2e-b9f6-4c6908c45b05/ksist-pr-en-iec-60309-2-2021>

Ta slovenski standard je istoveten z: prEN IEC 60309-2:2019

ICS:

29.120.30 Vtiči, vtičnice, spojke Plugs, socket-outlets,
couplers

oSIST prEN IEC 60309-2:2019 **en,fr,de**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[kSIST FprEN IEC 60309-2:2021](https://standards.iteh.ai/catalog/standards/sist/6d7336c3-db5f-4d2e-b9f6-4c6908c45b05/ksist-fpren-iec-60309-2-2021)

<https://standards.iteh.ai/catalog/standards/sist/6d7336c3-db5f-4d2e-b9f6-4c6908c45b05/ksist-fpren-iec-60309-2-2021>



23H/457/CDV

COMMITTEE DRAFT FOR VOTE (CDV)

PROJECT NUMBER: IEC 60309-2 ED5	
DATE OF CIRCULATION: 2019-08-09	CLOSING DATE FOR VOTING: 2019-11-01
SUPERSEDES DOCUMENTS: 23H/432/CD,23H/453/CC	

IEC SC 23H : PLUGS, SOCKET-OUTLETS AND COUPLERS FOR INDUSTRIAL AND SIMILAR APPLICATIONS, AND FOR ELECTRIC VEHICLES	
SECRETARIAT: France	SECRETARY: Mr Bertrand Doignon
OF INTEREST TO THE FOLLOWING COMMITTEES:	PROPOSED HORIZONTAL STANDARD: <input type="checkbox"/> Other TC/SCs are requested to indicate their interest, if any, in this CDV to the secretary.
FUNCTIONS CONCERNED: iTeh STANDARD PREVIEW (standards.iteh.ai) <input type="checkbox"/> EMC <input type="checkbox"/> ENVIRONMENT <input type="checkbox"/> QUALITY ASSURANCE <input type="checkbox"/> SAFETY	
<input checked="" type="checkbox"/> SUBMITTED FOR CENELEC PARALLEL VOTING Attention IEC-CENELEC parallel voting The attention of IEC National Committees, members of CENELEC, is drawn to the fact that this Committee Draft for Vote (CDV) is submitted for parallel voting. The CENELEC members are invited to vote through the CENELEC online voting system.	<input type="checkbox"/> NOT SUBMITTED FOR CENELEC PARALLEL VOTING kSIST FprEN IEC 60309-2:2021 https://standards.iteh.ai/catalog/standards/sist/6d7336c3-db5-4d2e-b9f6-4c6908c45b05/ksist-fpr-en-iec-60309-2-2021

This document is still under study and subject to change. It should not be used for reference purposes.

Recipients of this document are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

TITLE:

Plugs, fixed or portable socket-outlets and appliance inlets for industrial purposes - Part 2: Dimensional interchangeability requirements for pin and contact-tube accessories

PROPOSED STABILITY DATE: 2025

NOTE FROM TC/SC OFFICERS:

Copyright © 2019 International Electrotechnical Commission, IEC. All rights reserved. It is permitted to download this electronic file, to make a copy and to print out the content for the sole purpose of preparing National Committee positions. You may not copy or "mirror" the file or printed version of the document, or any part of it, for any other purpose without permission in writing from IEC.

1	CONTENTS	
2	FOREWORD.....	3
3	INTRODUCTION.....	5
4	1 Scope.....	6
5	2 Normative references	6
6	3 Terms and definitions	6
7	4 General	7
8	5 Standard ratings	7
9	6 Classification.....	8
10	7 Marking	8
11	8 Dimensions	11
12	9 Protection against electric shock	30
13	10 Provision for earthing	30
14	11 Terminals and terminations	30
15	12 Interlocks	32
16	13 Resistance to ageing of rubber and thermoplastic material	32
17	14 Construction.....	32
18	15 Construction of socket-outlets	35
19	16 Construction of plugs and portable socket-outlets.....	35
20	17 Construction of appliance inlets.....	35
21	18 Degrees of protection	36
22	19 Insulation resistance and dielectric strength	36
23	20 Breaking capacity.....	36
24	21 Normal operation.....	36
25	22 Temperature rise	37
26	23 Flexible cables and their connection.....	37
27	24 Mechanical strength	37
28	25 Screws, current-carrying parts and connections.....	37
29	26 Creepage distances, clearances and distances through sealing compound	37
30	27 Resistance to heat, to fire and to tracking.....	37
31	28 Corrosion and resistance to rusting	37
32	29 Conditional short-circuit current withstand test	37
33	30 Electromagnetic compatibility	37
34	bibliography	72
35		

ITC STANDARD PREVIEW
 (standards.iteh.ai)

<https://standards.iteh.ai/catalog/standards/sist/6d7336c3-dbf5-4d2e-b9f6-4c6908c45b05/ksist-pr-en-iec-60309-2-2021>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**PLUGS, FIXED OR PORTABLE SOCKET-OUTLETS AND APPLIANCE
INLETS
FOR INDUSTRIAL PURPOSES –****Part 2: Dimensional compatibility requirements
for pin and contact-tube accessories**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60309-2 has been prepared by subcommittee SC 23H: Plugs, socket-outlets and couplers for industrial and similar applications, and for electric vehicles, of IEC technical committee 23: Electrical accessories.

This fifth edition cancels and replaces the fourth edition published in 1999, Amendment 1:[2005] and Amendment 2:[2012]. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) addition of requirements and test for non-solid pins;
- b) additional rating IPX9;
- c) additional marking to indicate neutral terminal and/or earthing terminal.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
23H/---/FDIS	23H/---/RVD

94

95 Full information on the voting for the approval of this International Standard can be found in
96 the report on voting indicated in the above table.

97 This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

98 The committee has decided that the contents of the base publication and its amendments will
99 remain unchanged until the stability date indicated on the IEC web site under
100 "http://webstore.iec.ch" in the data related to the specific publication. At this date, the
101 publication will be

- 102 • reconfirmed,
103 • withdrawn,
104 • replaced by a revised edition, or
105 • amended.

106

iTeh STANDARD PREVIEW (standards.iteh.ai)

[kSIST FprEN IEC 60309-2:2021](https://standards.iteh.ai/catalog/standards/sist/6d7336c3-db5-4d2e-b9f6-4c6908c45b05/ksist-fpren-iec-60309-2-2021)

<https://standards.iteh.ai/catalog/standards/sist/6d7336c3-db5-4d2e-b9f6-4c6908c45b05/ksist-fpren-iec-60309-2-2021>

107
108

INTRODUCTION

109 A list of all the parts in the IEC 60309 series, under the general title *Plugs, fixed or portable*
110 *socket-outlets, and appliance inlets for industrial purposes*, can be found on the IEC website.

111 Part 1 deals with general requirements and comprises all clauses of a general character.

112 Subsequent parts deal with the requirements of particular types of accessories. The clauses
113 of these particular requirements supplement or modify the corresponding clauses in Part 1.

114 In this standard, the following print types are used:

- 115 – requirements proper: in roman type;
- 116 – *test specifications: in italic type;*
- 117 – notes: in smaller roman type.

118

iTeh STANDARD PREVIEW (standards.iteh.ai)

[ksIST FprEN IEC 60309-2:2021](https://standards.iteh.ai/catalog/standards/sist/6d7336c3-db5-4d2e-b9f6-4c6908c45b05/ksist-fpren-iec-60309-2-2021)

<https://standards.iteh.ai/catalog/standards/sist/6d7336c3-db5-4d2e-b9f6-4c6908c45b05/ksist-fpren-iec-60309-2-2021>

119 **PLUGS, FIXED OR PORTABLE SOCKET-OUTLETS AND APPLIANCE**
120 **INLETS FOR INDUSTRIAL PURPOSES –**

121

122

Part 2: Dimensional compatibility requirements for
pin and contact-tube accessories

124

125

126

127 **1 Scope**

128 This international standard applies to plugs, fixed or portable socket-outlets, and appliance
129 inlets, hereinafter referred to as accessories, with a rated operating voltage not exceeding
130 1 000 V DC or 1000 V AC not exceeding 500 Hz and a rated current not exceeding 125 A,
131 primarily intended for industrial use, either indoors or outdoors.

132 These accessories are intended to be installed by instructed persons (IEV 195-04-02) or
133 skilled persons (IEV 195-04-01) only.

134 NOTE 1 All references for accessories with a rated current of more than 125 A in part 1 are not applicable to this
135 part 2.

136 This standard applies to accessories with pins and contact-tubes of standardized
137 configurations.

138 This standard applies to accessories, for use when the ambient temperature is normally within
139 the range $-25\text{ }^{\circ}\text{C}$ to $40\text{ }^{\circ}\text{C}$.

140 The use of these accessories on building sites and for agricultural, commercial and domestic
141 applications is not precluded. [kSIST FprEN IEC 60309-2:2021](https://standards.iteh.ai/catalog/standards/sist/6d7336c3-db5-4d2e-b9f6-4e608c15b05/iec-60309-2-2021)

[https://standards.iteh.ai/catalog/standards/sist/6d7336c3-db5-4d2e-b9f6-](https://standards.iteh.ai/catalog/standards/sist/6d7336c3-db5-4d2e-b9f6-4e608c15b05/iec-60309-2-2021)

142 This standard applies to accessories with screwless type terminals or insulation piercing
143 terminals, with a rated current up to and including 32 A for series I and 30 A for series II.

144 Socket-outlets or appliance inlets incorporated in or fixed to electrical equipment are within
145 the scope of this standard. This standard also applies to accessories intended to be used in
146 extra-low voltage installations.

147 NOTE 2 This standard does not apply to accessories primarily intended for domestic and similar general
148 purposes.

149 In locations where special conditions prevail, for example on board ship or where explosions
150 are liable to occur, additional requirements may be necessary.

151 **2 Normative references**

152 Clause 2 of IEC 60309-1:2020 applies except as follows:

153 *Additional normative references:*

154 IEC 60364-4-41, *Low-voltage electrical installations – Part 4-41: Protection for safety –*
155 *Protection against electric shock*

156 IEC 60617-2, *Graphical symbols for diagrams – Part 2: Symbol elements, qualifying symbols*
157 *and other symbols having general application*

158 **3 Terms and definitions**

159 Clause 3 of IEC 60309-1:2020 applies except as follows:

160 *Additional terms and definitions:*

161 **3.201**

162 **phase inverter**

163 a plug or an appliance inlet with operating means to interchange the position of two phase
164 pins without disconnecting them from the conductors

165 **3.202**

166 **solid pin**

167 pin made from a single homogeneous material, without holes, slots, slits or similar outside the
168 terminal area

169 **4 General**

170 Clause 4 of IEC 60309-1:2020 applies except as follows:

171 **4.1** The last paragraph does not apply.

172 *Add the following:*

173 In this standard:

174 2P + E covers both 2P + E and 1P + N + E and

175 3P + E covers both 3P + E and 2P + N + E

176 unless specifically excluded (see Table 205).

177 *Additional subclause:*

178 **4.201** If gauges are used, they shall be of hardened steel, all corners shall be slightly
179 rounded-off with a maximum radius of 0,1 mm, and the surface finish for all measurement
180 surfaces shall be $\sqrt[NS]{\quad}$ min., if not otherwise specified.

181 **5 Standard ratings**

182 Clause 5 of IEC 60309-1:2020 applies except as follows:

183 **5.1 Replacement**

Preferred rated operating voltage range or rated operating voltage
20 V to 25 V
40 V to 50 V
100 V to 130 V
200 V to 250 V
277 V
380 V to 415 V
440 V to 460 V
480 V to 500 V
600 V to 690 V
750 V
1 000 V

184

185 **5.2 Replacement:**

186 Standard rated currents are given in Table 201.

187

Table 201 – Rated currents

Series I	Series II
A	A
16	20
32	30
63	60
125	100

188

189 *Additional subclause:*190 **5.201** The standard IP ratings according to IEC 60529 are:

- 191 – IP44,
- 192 – IP67,
- 193 – IP66/IP67.
- 194 – IP67/IP69,
- 195 – IP66/IP67/IP69

196 **6 Classification**

197 Clause 6 of IEC 60309-1:2020 applies except as follows:

198 **6.1.2** Not applicable. iTeh STANDARD PREVIEW
(standards.iteh.ai)

199 **7 Marking**

200 Clause 7 of IEC 60309-1:2020 applies except as follows.
<https://standards.iteh.ai/catalog/standards/sist/6d7336c3-db5-4d2e-b9f6-4c6908c45b05/ksist-fpren-iec-60309-2-2021>

201 *7.1 The note does not apply.*202 *Additional paragraphs:*

203 The symbol indicating the position of the earthing contact or of the minor key or keyway shall
 204 be placed before or above the figure for the rated operating voltage and separated from it by
 205 a line.

206 These markings shall be placed after that for rated current, separated from it by a dash if an
 207 oblique line separates the symbol indicating the position of the earthing contact or of the
 208 minor key or keyway from the figure for the rated operating voltage.

209 If a symbol for nature of supply is used, it shall be placed next to or below the marking for
 210 rated operating voltage.

211 For three-phase accessories it is not necessary to mark the voltage phase to neutral, if any.

212 The marking for rated current(s), position of the earthing contact or the minor key, keyway,
 213 rated operating voltage(s) and nature of supply accordingly may be as follows:

214

215 For series I:

16 A - 9 h/400 V~	16 - 9 h/400~	16 - $\frac{9 \text{ h}}{400 \sim}$
16 A - 9 h/380-415 V~	16 - 9 h/380-415~	16 - $\frac{9 \text{ h}}{380 - 415 \sim}$
32 A - 6 h/230/400 V~	32 - 6 h/230/400~	32 - $\frac{6 \text{ h}}{230 / 400 \sim}$
32 A - $\frac{6 \text{ h} / 220 / 380 \text{ V} \sim}{240 / 415 \text{ V} \sim}$	32 - $\frac{6 \text{ h} / 220 / 380 \sim}{240 / 415 \text{ V} \sim}$	32 $\frac{6 \text{ h}}{200/346\sim}$ 240/415~

216

217 For series II

20 A - 7 h/480 V AC	20 A - 7 h/480~	20 A - $\frac{7 \text{ h}}{480 \sim}$
30 A - 7 h/480 V	3 Phase, or 30 A - 7 h/480, 3Φ	30 A - $\frac{7 \text{ h}}{480 \text{ V}, 3\Phi}$
60 A - 7 h/277/480 V, 3 Phase Y	60 A - 7 h/277/480, 3ΦY	60 A - $\frac{7 \text{ h}}{277 / 480 \text{ V}, 3\Phi \text{ Y}}$

218 It is allowed to put the symbols for AC (~) [IEC 60417-5032 (2002-10)] and DC (===) [IEC 60417-5031 (2002-10)] or (—) [IEC 60417-5006 (2002-10)] after the values.

219
220 The drawings of standard sheets 2-I, 2-II, 2-III and 2-IV show accessories with the symbol 6 h and those of standard sheets 2-VIII and 2-IX accessories with the symbol 12 h.

222 For accessories having rated operating voltages exceeding 50 V, the symbol indicating the position of the earthing contact shall be a numeral followed by the letter h.

224 The numeral is derived from the position of the earth contact tube, when compared with the face of a clock, the socket-outlet being viewed from the front with the keyway at the sixth hour.

227 For accessories having rated operating voltages not exceeding 50 V, the symbol indicating the position of the minor key shall be a numeral followed by the letter h.

229 The numeral is derived from the position of the minor key, when compared with the face of a clock, the socket-outlet being viewed from the front with the major key at the sixth hour.

231 For plugs and appliance inlets, the symbol indicating the position of the earthing contact or the minor keyway shall be the same as that for the corresponding socket-outlet.

233 Contact tubes of socket-outlets shall be positioned in the clockwise order when viewed from the front as shown in the standard sheets (see also 7.5).

235 Pins of plugs and appliance inlets shall be positioned in the opposite order viewed from the front.

237

238 **7.4 Replacement**

239 For plugs and portable socket-outlet, the marking specified in 7.1 shall be easily discernible
240 when the accessory is wired ready for use.

241 The marking for insulation voltage shall be on the main part; it shall not be visible when the
242 accessory is mounted and wired as in normal use.

243 NOTE 1 The term "ready for use" does not imply that the plug or portable socket-outlet is engaged with its
244 complementary accessory.

245 *Compliance is checked by inspection.*

246 **7.5 Replacement**

247 For rewirable accessories, the contacts shall be indicated by the following symbols.

248 – for accessories with three contacts (phase + neutral + earth, or, phase + phase + earth):

249 L / +, unmarked, Ⓛ (preferred) [IEC 60417-5019 (2006-08)] or Ⓛ [IEC 60417-5017
250 (2006-08)]

251 except for Series II clock position 4 h and 5 h which are marked:

252 N, unmarked, Ⓝ or Ⓝ

253 – for accessories with four contacts (three-phase + earth):

254 L1, L2, L3, Ⓛ or Ⓛ , or alternatively 1, 2, 3, Ⓛ or Ⓛ

255 except for Series II clock position 12 h (phase + centre tap + phase + earth) which is
256 marked:

257 L1, N, L2, Ⓛ or Ⓛ

258 – for accessories with five contacts (three-phase + neutral + earth):

259 L1, L2, L3, N, Ⓛ or Ⓛ , or alternatively 1, 2, 3, N, Ⓛ or Ⓛ

260 – for accessories having a rated operating voltage not exceeding 50 V, 8 h clock position for
261 portable electric incubator: +12, +24.

262 These symbols shall be placed close to the relevant terminals; they shall not be placed on
263 screws, removable washers or other removable parts.

264 For phase inverters these symbols shall conform in one position with the requirements of 7.1.
265 In the other position of the inverting means, the phase marking need not conform.

266 Additional marking to indicate neutral terminal and/or earthing terminal may be used as
267 follows:

268 – letter W and/or white colour for neutral

269 – letter G and/or green colour for earthing

270 The terminals for pilot conductors are not required to be indicated. In the case they are
271 marked it is recommended to use the marking P or PILOT

272 The figures used with the letters may be written as an index. It is recommended that where
273 practicable the symbol Ⓛ be used.

274 *Compliance is checked by inspection.*

275 **7.7 Addition:**

276 The 2P + N + E, 12 h, Series II accessories shall use the indicating colour orange.

277 **8 Dimensions**

278 Clause 8 of IEC 60309-1:2020 applies except as follows:

279 **8.1 Replacement:**

280 Accessories shall comply with the relevant standard sheets as specified below:

281 – accessories having rated operating voltages exceeding 50 V:

Accessory	Degree of protection	Standard sheet
16/20 A and 32/30 A	IP44	2-I 2-I continuation 1 2-II 2-II continuation 1
	IP67 IP67/IP69 IP66/IP67 IP66/IP67/IP69	2-I 2-I continuation 2 2-II 2-II continuation 2
63/60 A, without pilot contact	IP44	2-III 2-III continuation 1 2-IV 2-IV continuation 1
63/60 A and 125/100 A, without pilot contact	IP67 IP67/IP69 IP66/IP67 IP66/IP67/IP69	2-III 2-III continuation 2 2-IV 2-IV continuation 2
63/60 A, with pilot contact	IP44	2-IIIa 2-III continuation 1 2-IVa 2-IV continuation 1
63/60 A and 125/100 A, with pilot contact	IP67 IP67/IP69 IP66/IP67 IP66/IP67/IP69	2-IIIa 2-III continuation 2 2-IVa 2-IV continuation 2
Mechanical interlock for 16 A to 125 A accessories	IP44 IP67 IP67/IP69 IP66/IP67 IP66/IP67/IP69	2-V

282

283 – accessories having rated operating voltages not exceeding 50 V:

Accessory	Degree of protection	Standard sheet
16/20 A and 32/30 A	IP44	2-VIII 2-VIIIa 2-VIII continuation 1 2-IX 2-IXa 2-IX continuation 1
	IP67 IP67/IP69 IP66/IP67 IP66/IP67/IP69	2-VIII 2-VIIIa 2-VIII continuation 2 2-IX 2-IXa 2-IX continuation 2

284

285 - retaining device as indicated in Table 209

286 **Table 209 – Retaining devices**

Rated current of the accessory A	Classification according to degree of protection against moisture	Socket-outlets			Plugs and appliance inlets		
		Retaining means	Standard sheet		Retaining means	Standard sheet	
			Rated operating voltage exceeding 50 V	Rated operating voltage not exceeding 50 V		Rated operating voltage exceeding 50 V	Rated operating voltage not exceeding 50 V
16/20 and 32/30	IP44	Lid	2-I (continuation 1)	2-VIII (continuation 1)	Lug or cavity	2-II (continuation 1)	2-IX (continuation 1)
	IP66/IP67 and IP67	Two-ramp system	2-I (continuation 2)	2-VIII (continuation 2)	Lug or cavity and bayonet ring	2-II (continuation 2)	2-IX (continuation 2)
63/60	IP44	Lid and two-ramp system	2-III (continuation 1)	–	Lug or cavity	2-IV (continuation 1)	–
	IP66/IP67 and IP67	Two-ramp system	2-III (continuation 2)	–	Bayonet ring	2-IV (continuation 2)	–
125/100	IP66/IP67 and IP67 ^{a)}	Two-ramp system	2-III (continuation 2)	–	Bayonet ring	2-IV (continuation 2)	–

a) When 125/100 A fixed socket-outlets are mounted on or integrated with enclosures, the whole unit can also be IP44.

287 Deviations from the dimensions specified in the standard sheets may be made, but only if
 288 they provide a technical advantage and do not adversely affect the purpose and safety of the
 289 accessories complying with the standard sheets, especially with regard to compatibility and
 290 non-compatibility.

291 Compliance is checked by means of gauges or by measurement for those dimensions not
 292 covered by gauges,

293 – for accessories having rated operating voltages exceeding 50 V according to:

- 294 • Figures 201 and 202 for socket-outlets;
- 295 • Figures 203 and 204 for plugs and appliance inlets;

296 – for accessories having rated operating voltages not exceeding 50 V according to:

- 297 • Figures 205 and 206 for 16/20 A and 32/30 A accessories.

298 The gauges shall be moved axially to the centre line of the accessory with a force as shown in
 299 the Table 202, applied for 1 min.

300 **Table 202 – Forces applied to "GO"/"NO GO" gauges**

Rated operating voltage V	Rated current A		Force (max.) for "GO" gauge N	Force (max.) for "NO GO" gauge N $\begin{pmatrix} 0 \\ -1 \end{pmatrix}$
	Series I	Series II		
Not exceeding 50	16	20	150	30
	32	30	150	30
Exceeding 50	16	20	60	20
	32	30	90	30
	63	60	165	55
	125	100	240	80

301 Before the test, the test specimen of insulating material shall be stored at a temperature of
 302 (20 ± 5) °C and a relative humidity between 45 % and 75 % for four weeks.

303 For accessories having rated operating voltages not exceeding 50 V, the position of the minor
 304 key or keyway shall be as shown in Tables 203-1 or 203-2

305 For accessories having rated operating voltages exceeding 50 V, the position of the earthing
 306 contact shall be as shown in Table 205.

307 Compliance is checked by inspection.

308 **Table 203 – General purpose accessories with rated operating voltage**
 309 **not exceeding 50 V**

Rated operating voltage V	Frequency Hz	Minor key or keyway position ^{a)}
20 to 25	50 and 60	No minor key or keyway
40 to 50	50 and 60	12
20 to 25 and 40 to 50	100 up to and including 200	4
	300	2
	400	3
	Over 400 up to and including 500	11
	Direct current	10
^{a)} The minor key or keyway position is indicated by the relevant number (see 7.1).		

310

311 **Table 204 – Special application accessories with rated operating voltage**
 312 **not exceeding 50 V**

Rated operating voltage	Rated current	Numbers of poles	Other characteristics and application	Minor key or keyway position ^{a)}
25 V	32 A	3	Portable electric incubators – use at 12 V DC or 24 V DC on ambulances or helicopters	8
^{a)} The minor key or keyway is indicated by the relevant number.				

313

314 Positions 1 and 9 are reserved for future standardisation. For constructional reasons,
 315 positions 5, 6 and 7 cannot be used.