

---

**Mehanske konstrukcije za električno in elektronsko opremo - Omejitev prehoda za IT-omarice - 2. del: Podrobnosti o zahtevah za pretok, ločevanje in hlajenje zraka (IEC 62966-2:2020)**

Mechanical structures for electrical and electronic equipment - Aisle containment for IT cabinets - Part 2: Details of air flow, air separation and air cooling requirements (IEC 62966-2:2020)

Mechanische Bauweisen für elektrische und elektronische Einrichtungen – Gangeinhausung für IT-Schränke – Teil 2: Einzelheiten zu Luftstrom-, Lufttrennungs- und Luftkühlungsanforderungen (IEC 62966-2:2020)

[SIST EN IEC 62966-2:2020](https://standards.iteh.ai/catalog/standards/sist/aac3935b-955a-4172-9cd2-3a070a994e72/sist-en-iec-62966-2-2020)

Structures mécaniques pour équipements électriques et électroniques - Confinement d'allées pour les baies informatiques - Partie 2: Détails des exigences relatives au flux d'air, à la séparation des flux d'air et au refroidissement par air (IEC 62966-2:2020)

**Ta slovenski standard je istoveten z: EN IEC 62966-2:2020**

---

**ICS:**

31.240	Mehanske konstrukcije za elektronsko opremo	Mechanical structures for electronic equipment
--------	---	--

**SIST EN IEC 62966-2:2020** en

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN IEC 62966-2:2020

<https://standards.iteh.ai/catalog/standards/sist/aae3935b-955a-4172-9cd2-5a670a994e72/sist-en-iec-62966-2-2020>

EUROPEAN STANDARD

EN IEC 62966-2

NORME EUROPÉENNE

EUROPÄISCHE NORM

September 2020

ICS 31.240

English Version

Mechanical structures for electrical and electronic equipment -  
Aisle containment for IT cabinets - Part 2: Details of air flow, air  
separation and air cooling requirements  
(IEC 62966-2:2020)

Structures mécaniques pour équipements électriques et  
électroniques - Confinement d'allées pour les baies  
informatiques - Partie 2: Détails des exigences relatives au  
flux d'air, à la séparation des flux d'air et au refroidissement  
par air  
(IEC 62966-2:2020)

Mechanische Bauweisen für elektrische und elektronische  
Einrichtungen - Gangeinhausung für IT-Schränke - Teil 2:  
Einzelheiten zu Luftstrom-, Lufttrennungs- und  
Luftkühlungsanforderungen  
(IEC 62966-2:2020)

This European Standard was approved by CENELEC on 2020-08-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

**EN IEC 62966-2:2020 (E)****European foreword**

The text of document 48D/722/FDIS, future edition 1 of IEC 62966-2, prepared by SC 48D "Mechanical structures for electrical and electronic equipment" of IEC/TC 48 "Electrical connectors and mechanical structures for electrical and electronic equipment" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62966-2:2020.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2021-05-19
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2023-08-19

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

**Endorsement notice****iTeh STANDARD PREVIEW**

The text of the International Standard IEC 62966-2:2020 was approved by CENELEC as a European Standard without any modification.

[SIST EN IEC 62966-2:2020](https://standards.iteh.ai/catalog/standards/sist/aae3935b-955a-4172-9cd2-5a670a994e72/sist-en-iec-62966-2-2020)

<https://standards.iteh.ai/catalog/standards/sist/aae3935b-955a-4172-9cd2-5a670a994e72/sist-en-iec-62966-2-2020>

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: [www.cenelec.eu](http://www.cenelec.eu).

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 62966-1	-	Mechanical structures for electrical and electronic equipment - Aisle containment for IT cabinets - Part 1: Dimensions and mechanical requirements	EN IEC 62966-1	-
ISO 9972	-	Thermal performance of buildings - Determination of air permeability of buildings - Fan pressurization method	EN ISO 9972	-

[SIST EN IEC 62966-2:2020](https://standards.iteh.ai/catalog/standards/sist/aae3935b-955a-4172-9cd2-5a670a994e72/sist-en-iec-62966-2-2020)

<https://standards.iteh.ai/catalog/standards/sist/aae3935b-955a-4172-9cd2-5a670a994e72/sist-en-iec-62966-2-2020>

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN IEC 62966-2:2020

<https://standards.iteh.ai/catalog/standards/sist/aae3935b-955a-4172-9cd2-5a670a994e72/sist-en-iec-62966-2-2020>



IEC 62966-2

Edition 1.0 2020-07

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



**Mechanical structures for electrical and electronic equipment – Aisle  
containment for it cabinets –  
Part 2: Details of air flow, air separation and air cooling requirements**

**Structures mécaniques pour équipements électriques et électroniques –  
Confinement d'allées pour les baies informatiques –  
Partie 2: Détails des exigences relatives au flux d'air, à la séparation des flux  
d'air et au refroidissement par air**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

ICS 31.240

ISBN 978-2-8322-8510-7

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references .....	7
3 Terms and definitions .....	7
4 Determination of the air leak rate.....	9
4.1 Determination of the air leak rate of the individual components of an aisle containment.....	9
4.2 Components and system characteristic curves.....	10
4.2.1 General .....	10
4.2.2 Equipment requirements.....	11
4.3 Measurement procedure .....	11
4.3.1 Measurement conditions.....	11
4.3.2 Preparing the elements of the test housing for measurement.....	11
4.3.3 Measurement of the air leak rate .....	13
4.4 Test report.....	14
4.5 Measurement precision.....	14
5 Air leakage rate of the aisle containment – Creation of an overall system characteristic curve for the aisle containment.....	15
6 Determination of the air leak rate – Determination of the air leak rate of the overall system in operation, including the IT equipment.....	15
Annex A (informative) Aisle containments according to operation mode.....	17
A.1 Allocation of the aisle containments according to operation mode.....	17
A.1.1 General .....	17
A.1.2 Types of climate control.....	17
A.1.3 Closed-circuit climate control.....	17
A.1.4 In-line climate control .....	17
A.2 Cold aisle containment.....	18
A.2.1 Principle of the cold aisle containment.....	18
A.2.2 Objective of the cold aisle.....	18
A.2.3 Climate control .....	18
A.3 Hot aisle containment .....	18
A.3.1 Principle of the hot aisle containment .....	18
A.3.2 Objective of the hot aisle .....	19
A.3.3 Climate control .....	19
A.4 Cold and hot aisle containment.....	19
A.4.1 Principle of the cold and hot aisle containment .....	19
A.4.2 Objective of the cold aisle in a cold and hot aisle containment.....	20
A.4.3 Climate control .....	20
Annex B (informative) Thermodynamic variables within aisle containments.....	21
B.1 Air pressure .....	21
B.1.1 General .....	21
B.1.2 Minimum differential pressure.....	21
B.1.3 Overpressure in hot aisle containments .....	21
B.1.4 Negative pressure in hot aisle containments.....	21
B.1.5 Overpressure in cold aisle containments.....	21
B.1.6 Negative pressure in cold aisle containments .....	21



B.2	Directions of flow .....	22
B.2.1	Directions of flow "from the front to the back" .....	22
B.2.2	Direction of flow "to the side" .....	22
B.3	Flow velocities .....	22
B.3.1	Closed-circuit climate control .....	22
B.3.2	In-line climate control .....	22
B.3.3	Design of the aisle containments .....	22
B.4	Temperatures and humidity .....	23
B.4.1	General .....	23
B.4.2	Temperatures .....	23
B.4.3	Humidity .....	23
Bibliography .....		24
Figure 1	– Example of the components – Roof .....	9
Figure 2	– Example of the components – Door .....	10
Figure 3	– Example of the components – Enclosures .....	10
Figure 4	– Sealing the installation level .....	12
Figure 5	– Example of a connecting design to the neighbouring enclosure .....	12
Figure 6	– Example of a connecting design to the roof .....	13
Figure 7	– Example of a connecting design to the end door .....	13
Figure 8	– Example of component and system characteristic curves .....	14
Figure 9	– Example of a hydraulic addition of individual characteristic curves .....	15
Figure 10	– Classification of aisle containment by class factors .....	16
Figure A.1	– Example of an in-line climate control .....	17
Figure A.2	– Example of a cold aisle containment .....	18
Figure A.3	– Example of a hot aisle containment .....	19
Figure A.4	– Example of a cold and hot aisle containment .....	20

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**MECHANICAL STRUCTURES FOR  
ELECTRICAL AND ELECTRONIC EQUIPMENT –  
AISLE CONTAINMENT FOR IT CABINETS –**

**Part 2: Details of air flow, air separation and air cooling requirements**

**FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62966-2 has been prepared by subcommittee 48D: Mechanical structures for electrical and electronic equipment, of IEC technical committee 48: Electrical connectors and mechanical structures for electrical and electronic equipment.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
48D/722/FDIS	48D/727/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62966 series, published under the general title *Mechanical structures for electrical and electronic equipment – Aisle containment for its cabinets*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN IEC 62966-2:2020](https://standards.iteh.ai/catalog/standards/sist/aae3935b-955a-4172-9cd2-5a670a994e72/sist-en-iec-62966-2-2020)

<https://standards.iteh.ai/catalog/standards/sist/aae3935b-955a-4172-9cd2-5a670a994e72/sist-en-iec-62966-2-2020>

## INTRODUCTION

Cabinets of the IEC 60297 and IEC 60917 standard series are used as enclosures of electronic and electrical equipment in many different fields of application. A wide field of application is represented by enclosures equipped with electronic information technology (IT) equipment. They are frequently set up in large numbers in server rooms and data centres. During their operation, the electronic equipment installed generates a considerable amount of heat that will be removed from the equipment by means of cooling air. Precise adjustment of the supply air temperature and a sufficient cooling air flow are indispensable prerequisites for the fail-safe operation of equipment in information technology.

It is a common practice to set up cabinets in rows. The server cabinets along the rows are usually arranged in such a way that surfaces with cold supply air inlets face each other across an aisle, and surfaces with hot exhaust air outlets also face each other across an aisle. This row configuration is generally known as hot aisle/cold aisle configuration. Moreover, air is supplied and discharged exclusively via the front and rear panels of the server cabinets, which are frequently perforated doors. It is assumed that inside the IT equipment, the cooling air is moved in a horizontal direction, taking it in at the front and discharging it at the rear.

This part of IEC 62966 specifies the quantification of the air separation, in particular the air leak rate that describes the content of the volumetric flow not used for cooling in the aisle containment for information technology (IT) cabinets. The objective of this document is to stipulate properties and requirements of aisle containment ensuring cost effective installation, energy-efficient and user-friendly operation of IT equipment in data centres server rooms.

The fan pressurization method (overpressure at the system and elements) is used to categorize the air tightness of the aisle containment. In doing so, it is used to quantify the air tightness, in order to compare aisle containments with regard to the air tightness. It is also useful for finding leaks, or to determine the improvement due to improving the air tightness. The fan pressurization method cannot measure the air leak rate, but serves as a basis for determining the air leak rate by calculation. The method can be used to determine air leak rates of the aisle containment at low-pressure and overpressure on the inside compared with the surroundings. Thus, this allows a categorization of the elements of an aisle containment – the enclosure – to be determined.

For this purpose, aisle containment is dismantled into typical individual elements, for example enclosures, doors and roof covers. The corresponding characteristic curves of these components are recorded separately and added to the system characteristic curve of the aisle containment.

The quality of the resulting aisle containment is then classified using a differential pressure measurement.

The IEC 62966 series, *Mechanical structures for electrical and electronic equipment – Aisle containment for IT cabinets*, is subdivided into the following parts:

- IEC 62966-1: *Dimensions and mechanical requirements*
- IEC 62966-2: *Details of air flow, air separation and air cooling requirements*
- IEC 62966-3: *Aspects of operational safety of IT equipment and users of aisle containment*

IEC 62966-1 defines geometric dimensions and mechanical properties ensuring undisturbed, energy-efficient and user-friendly operation of the data centre.

IEC 62966-2 provides the methods and process to get the aisle containment air leakage and define the classification (evaluation) system on the aisle containment air leakage, for designers and users of aisle containments for IT cabinets based on the IEC 60297 and IEC 60917 series.

IEC 62966-3 deals with aspects of safely operating IT equipment in aisle containment, with respect to special fire-protection and fire-fighting issues. It also describes the nature of the doors for access to the aisle containment and possible access control.