



# SLOVENSKI STANDARD SIST-TP ISO/TR 19815:2018

01-oktober-2018

---

**Informatika in dokumentacija - Upravljanje okoljskih pogojev za zbirke arhivov in knjižnic**

Information and documentation -- Management of the environmental conditions for archive and library collections

**iTeh STANDARD PREVIEW**

Information et documentation -- (Standards.iTeh.ai) Gestion des conditions environnementales pour les documents d'archive et de bibliothèque

[SIST-TP ISO/TR 19815:2018](https://standards.iTeh.ai/catalog/standards/sist/91f13640-6d60-432c-9989-9c585c974ac/sist-tp-iso-tr-19815-2018)

**Ta slovenski standard je istoveten z: ISO/TR 19815:2018**

---

**ICS:**

01.140.20      Informacijske vede      Information sciences

**SIST-TP ISO/TR 19815:2018**      **en,fr,de**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST-TP ISO/TR 19815:2018](https://standards.iteh.ai/catalog/standards/sist/91f13640-6d60-432c-9989-9e5585c94fac/sist-tp-iso-tr-19815-2018)

<https://standards.iteh.ai/catalog/standards/sist/91f13640-6d60-432c-9989-9e5585c94fac/sist-tp-iso-tr-19815-2018>

TECHNICAL  
REPORT

ISO/TR  
19815

First edition  
2018-07

---

---

**Information and documentation —  
Management of the environmental  
conditions for archive and library  
collections**

*Information et documentation — Gestion des conditions  
environnementales pour les documents d'archive et de bibliothèque*

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST-TP ISO/TR 19815:2018](https://standards.iteh.ai/catalog/standards/sist/91f13640-6d60-432c-9989-9e5585c94fac/sist-tp-iso-tr-19815-2018)

<https://standards.iteh.ai/catalog/standards/sist/91f13640-6d60-432c-9989-9e5585c94fac/sist-tp-iso-tr-19815-2018>



Reference number  
ISO/TR 19815:2018(E)

© ISO 2018

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST-TP ISO/TR 19815:2018  
<https://standards.iteh.ai/catalog/standards/sist/91f13640-6d60-432c-9989-9e5585c94fac/sist-tp-iso-tr-19815-2018>



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2018

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
CP 401 • Ch. de Blandonnet 8  
CH-1214 Vernier, Geneva  
Phone: +41 22 749 01 11  
Fax: +41 22 749 09 47  
Email: [copyright@iso.org](mailto:copyright@iso.org)  
Website: [www.iso.org](http://www.iso.org)

Published in Switzerland

# Contents

Page

<b>Foreword</b> .....	<b>v</b>
<b>Introduction</b> .....	<b>vi</b>
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>1</b>
<b>3 Terms and definitions</b> .....	<b>1</b>
<b>4 General</b> .....	<b>6</b>
<b>5 Management of environment for optimization of preservation and sustainability</b> .....	<b>8</b>
<b>6 Temperature</b> .....	<b>10</b>
<b>7 Relative humidity</b> .....	<b>11</b>
<b>8 Climate and its consequences for collections</b> .....	<b>13</b>
8.1 General.....	13
8.2 Seasonal climates.....	15
<b>9 Insects and other pests</b> .....	<b>15</b>
<b>10 Pollution</b> .....	<b>15</b>
<b>11 Light</b> .....	<b>16</b>
<b>12 Setting a temperature and relative humidity specification</b> .....	<b>18</b>
<b>13 Psychrometrics</b> .....	<b>22</b>
<b>14 Good practices for sustainability</b> .....	<b>27</b>
14.1 General.....	27
14.2 Arnamagnæan Institute archive, Copenhagen, Denmark.....	28
14.3 Territorial archives, St Martin, West Indies.....	28
14.4 Japanese Imperial Archives, Tokyo.....	28
14.5 Jersey Archive, Jersey, Channel Islands.....	28
14.6 Norwegian National Library, Mo i Rana.....	29
14.7 Central State Archive of Saxony, Dresden, Germany.....	29
14.8 National Library of Singapore.....	29
14.9 Archives départementales du Nord, Lille, France.....	29
14.10 School library, Gando, Burkina Faso.....	29
<b>15 Educational and assessment tools</b> .....	<b>29</b>
15.1 General.....	29
15.1.1 Overview.....	29
15.1.2 Isoperm.....	30
15.1.3 Preservation index (PI) and time weighted preservation index (TWPI).....	30
15.2 Environmental management tools and assessments.....	31
15.2.1 General.....	31
15.2.2 Fundamental microclimate concepts.....	31
15.2.3 Air exchange between an enclosure and its surroundings.....	31
15.2.4 Calculator for atmospheric moisture.....	32
15.2.5 Calculator for energy use in museums.....	32
15.2.6 Calculator for conservation heating.....	32
15.2.7 Calculator for dehumidification energy load.....	32
<b>Annex A (informative) Energy economy</b> .....	<b>33</b>
<b>Annex B (informative) Impact of temperature</b> .....	<b>38</b>
<b>Annex C (informative) Impact of relative humidity</b> .....	<b>40</b>
<b>Annex D (informative) Material damage associated with temperature and relative humidity</b> .....	<b>43</b>

## ISO/TR 19815:2018(E)

<b>Annex E (informative) Sources of pollutants and their impact on materials significant to archive or library collections</b> .....	<b>46</b>
<b>Annex F (informative) Interactions between temperature, RH, light and pollution</b> .....	<b>50</b>
<b>Bibliography</b> .....	<b>51</b>

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST-TP ISO/TR 19815:2018](https://standards.iteh.ai/catalog/standards/sist/91f13640-6d60-432c-9989-9e5585c94fac/sist-tp-iso-tr-19815-2018)

<https://standards.iteh.ai/catalog/standards/sist/91f13640-6d60-432c-9989-9e5585c94fac/sist-tp-iso-tr-19815-2018>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html).

This document was prepared by Technical Committee ISO/TC 46, *Information and documentation*, Subcommittee SC 10, *Requirements for document storage and conditions for preservation*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at [www.iso.org/members.html](http://www.iso.org/members.html).

## ISO/TR 19815:2018(E)

### Introduction

This document covers much of the same ground as BSI/PAS 198[46]. The main difference is that BSI/PAS 198 was designed to be applied in British conditions with a temperate climate. Challenges vary in different climatic zones. Nevertheless, there are principles that are generally applicable.

No one set of conditions is appropriate for all collections in all circumstances because environmental specifications are tailored to the needs of a specific collection, the resources of the institution and the context within which it operates, and the local climate. This document sets out a framework for decision making relating to appropriate environmental conditions for cultural collections in the specific climatic zones.

Since archives, libraries and cultural institutions are guardians of the collective memory, their aim is to preserve material in the long term. They also have a duty to do so in a manner that minimizes the impact on the world's resources and climate. Climate change will affect cultural institutions as much as any other institution, if not more, and the use of energy, particularly from non-renewable sources, should be minimized. Wherever possible, passive (non-energy consuming) solutions are preferred, and buildings should be designed with this aim in mind.

First, the extent and composition of the collections, their significance, their current condition, the ways in which they are used, and the desired lifetime should be taken into account. For example, archive and library collections are likely to contain (in addition to bound and unbound paper and parchment and other organic materials, such as Xuan paper and silk, black and white and colour photographic prints and negatives) gramophone records, tapes and films, and, increasingly, diverse electronic media. In addition, the collections can contain all manner of artefacts in various materials. While many of these materials have similar environmental sensitivities, some have specific requirements that need to be taken into account.

The environment in which the collections are stored, used or displayed, and the resulting risks to them should also be understood. On the basis of the information gathered about the collections, regarding the nature and condition of the collections, it is possible to assess the vulnerability to factors such as temperature, relative humidity, light and pollutants, and thus what steps need to be taken to mitigate those risks. These might include the design of, or modifications to buildings, passive measures to control the environment, or improvements to storage and display techniques.

Every collecting institution can and should be able to carry out these steps, no matter how limited their resources, and irrespective of their climate. Knowledge of the collections, and of the risks, is indispensable to proper management and long term survival of the collections.

The consensus amongst conservation professionals regarding environmental parameters for exhibitions and loans is evolving rapidly. References [29], [206] and [236] give additional information on this. Although there is no doubt that a controlled environment is significant in the preservation of collections, provided that the parameters are appropriate to the materials, it is now generally accepted that daily and seasonal variations in temperature and relative humidity will not cause harm to the majority of collections.

This document also provides access to research that led to some of the changes in ISO 11799.



# Information and documentation — Management of the environmental conditions for archive and library collections

## 1 Scope

This document provides information on recent discussions and changes in recommendations and guidance on environmental management within the cultural heritage field. Conservation research on preventive methodologies and passive control provided by specific construction methods and renovations, developments in technology for controlling the environment, and energy and climate change issues are included.

This document is intended for archives and libraries and other institutions with large volumes of collections that are based on paper. Archives and libraries also have collections that include film, magnetic media, leather, and other organic, inorganic or composite materials. These institutions have a unique challenge of extending the lifespan of these materials for access and use in the present and for future generations. The environment plays a key role in extending the lifespan of all of these materials.

This document is intended for use in preservation planning and ongoing environmental management of permanent storage conditions for archives and library collections and applies to all collections being permanently stored for an institution.

## 2 Normative references

There are no normative references in this document.

## 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

### 3.1

#### air change rate

air flow rate to a space, expressed as volume per unit time, divided by the volume of the space in consistent units

Note 1 to entry: Air change rate is often expressed as air changes per hour.

Note 2 to entry: This term is used where there is active ventilation [see also *ventilation rate* (3.40)].

[SOURCE: ISO 16814:2008, 3.5]

### 3.2

#### thermal stratification

tendency of heated air to rise and to arrange itself in layers with the warmest air at the top

**ISO/TR 19815:2018(E)****3.3  
collection**

holding

type of documents kept in archives and libraries regardless of their physical format

Note 1 to entry: These are mainly books, manuscripts, files, maps, graphic collections and other documents consisting of paper, but also parchment, papyrus, films, photographic materials, audio-visual recordings, magnetic and optical media, as well as bindings and protective material.

Note 2 to entry: Holdings is a term used more often in archival institutions.

**3.4  
dew point**

measure of atmospheric moisture

Note 1 to entry: It is the temperature at which the water vapour in the air becomes saturated and condensation begins.

**3.5  
document**

recorded information or material object which can be treated as a unit in a documentation process

**3.6  
effectiveness**

extent to which planned activities are realized and planned results are achieved

**3.7  
energy**

electricity, fuels, steam, heat, compressed air, and other like media

Note 1 to entry: For the purposes of this document, energy refers to the various forms of energy, including renewable, which can be purchased, stored, treated, used in equipment or in a process, or recovered.

Note 2 to entry: Energy can be defined as the capacity of a system to produce external activity or perform work.

[SOURCE: ISO 50001:2011, 3.5]

**3.8  
energy economy**

careful management of energy resources

Note 1 to entry: This focuses on appropriate minimal consumption of energy within an institution, and incorporates both knowledge of energy performance and specific *energy efficiency* (3.9) of a building and/or mechanical systems.

**3.9  
energy efficiency**

measures that ensure the building and system function in accordance with the design parameters by the efficient use of energy

[SOURCE: ISO 16813:2006, 3.17]

**3.10  
energy performance**measurable results related to *energy efficiency* (3.9), energy use and energy consumption

Note 1 to entry: In the context of *energy management systems* (3.12), results can be measured against the organization's energy policy, objectives, targets and other energy performance requirements.

[SOURCE: ISO 50001:2011, 3.12]

### 3.11 environment

surroundings in which an organization operates, including air, water, land, natural resources, flora, fauna, humans and their interrelationships

Note 1 to entry: Surroundings can extend from within an organization to the local, regional and global system.

Note 2 to entry: Surroundings can be described in terms of biodiversity, ecosystems, climate or other characteristics.

[SOURCE: ISO 14001:2015, 3.2.1]

### 3.12 environmental management system

part of the management system used to manage environmental aspects, fulfil compliance obligations, and address risks and opportunities

[SOURCE: ISO 14001:2015, 3.1.2]

### 3.13 environmental performance

performance related to the management of environmental aspects

Note 1 to entry: For an *environmental management system* (3.12), results can be measured against the organization's *environmental policy* (3.14), environmental objectives or other criteria, using indicators.

[SOURCE: ISO 14001:2015, 3.4.11]

### 3.14 environmental policy

intentions and direction of an organization related to environmental performance formally expressed by its top management

[SOURCE: ISO 14001:2015, 3.1.3]

### 3.15 glass transition

reversible change in an amorphous polymer or in amorphous regions of a partially crystalline polymer from (or to) a viscous or rubbery condition to (or from) a hard and relatively brittle one

[SOURCE: ISO 11357-2:2013, 3.1]

### 3.16 glass transition temperature

$T_g$   
characteristic value of the temperature range over which the glass transition takes place

Note 1 to entry: The assigned glass transition temperature ( $T_g$ ) may vary, depending on the specific property and on the method and conditions selected to measure it.

[SOURCE: ISO 11357-2:2013, 3.2]

### 3.17 HVAC system

system that provides heating, ventilation or air conditioning for buildings

[SOURCE: ISO 16814:2008, 3.18]

### 3.18 hydrolyse

chemical decomposition in which a compound is split into other compounds by reacting with water

**ISO/TR 19815:2018(E)****3.19****indicator**

measurable representation of the condition or status of operations, management or conditions

[SOURCE: ISO 14031:2013, 3.15]

**3.20****infiltration air**

uncontrolled passage of air into a space through leakage paths in the building envelope

[SOURCE: ISO 16814:2008, 3.20]

**3.21****insulation**

materials that conduct heat poorly and thereby slow down heat loss from an object or space

**3.22****long term storage**

storage, for a period of undefined length, of material kept for permanent retention

**3.23****maintenance**

actions of prevention or correction to support long term functionality of repositories and the systems that support them

Note 1 to entry: Corrective action is taken to prevent recurrence whereas preventive action is taken to prevent occurrence.

**3.24****management system**

set of interrelated or interacting elements of an organization to establish policies and objectives and processes to achieve those objectives

Note 1 to entry: A management system can address a single discipline or several disciplines (e.g. quality, environment, occupational health and safety, energy, financial management).

Note 2 to entry: The system elements include the organization's structure, roles and responsibilities, planning and operation, performance evaluation and improvement.

Note 3 to entry: The scope of a management system can include the whole of the organization, specific and identified functions of the organization, specific and identified sections of the organization, or one or more functions across a group of organizations.

[SOURCE: ISO 14001:2015, 3.1.1]

**3.25****mechanical ventilation**

ventilation provided by mechanically powered equipment

[SOURCE: ISO 16814:2008, 3.22]

**3.26****monitoring**

determining the status of a system, a process or an activity

Note 1 to entry: To determine the status, there might be a need to check, supervise or critically observe.

[SOURCE: ISO 14001:2015, 3.4.8]

**3.27****natural ventilation**

ventilation through leakage paths (infiltration) and intentional openings (ventilation) in the building envelope or room enclosure, which relies on pressure differences without the aid of powered air-moving components

[SOURCE: ISO 16814:2008, 3.24]

**3.28****occupied zone**

area designed for occupancy that is dependent on the geometry and the use of the room and specified case by case

Note 1 to entry: Usually used only for areas designed for human occupancy and defined as a volume of air that is confined by horizontal and vertical planes. The vertical planes are usually parallel with the walls of the room.

[SOURCE: ISO 16814:2008, 3.28]

**3.29****outdoor air**

air entering the system, or opening from outdoors before any air treatment

[SOURCE: ISO 16814:2008, 3.31]

**3.30****outdoor air intake**

opening through which outdoor air is admitted

[SOURCE: ISO 16814:2008, 3.30]

**3.31****performance**

measurable result

<https://standards.iteh.ai/catalog/standards/sist/91f13640-6d60-432c-9989-9e5585c94fac/sist-tp-iso-tr-19815-2018>

Note 1 to entry: Performance can relate either to quantitative or qualitative findings.

Note 2 to entry: Performance can relate to the management of activities, processes, products (including services), systems or organizations.

[SOURCE: ISO 14001:2015, 3.4.10]

**3.32****process**

set of interrelated or interacting activities which transforms inputs into outputs

Note 1 to entry: A process can be documented or not.

[SOURCE: ISO 14001:2015, 3.3.5]

**3.33****relative humidity****RH**

mass of water vapour in the air by volume divided by mass of water vapour by volume at saturation at the same temperature

[SOURCE: ISO 16814:2008, 3.34]

**3.34****repository**

building or room designed or arranged and used specifically and exclusively for long term storage of archive or library material

**ISO/TR 19815:2018(E)****3.35****requirement**

need or expectation that is stated, generally implied or obligatory

Note 1 to entry: “Generally implied” means that it is custom or common practice for the organization and interested parties that the need or expectation under consideration is implied.

Note 2 to entry: A specified requirement is one that is stated, for example in documented information.

Note 3 to entry: Requirements other than legal requirements become obligatory when the organization decides to comply with them.

[SOURCE: ISO 14001:2015, 3.2.8]

**3.36****sub-cool**

process of cooling air below its initial dew point temperature to dehumidify via condensation

Note 1 to entry: The condensation dehumidification is followed by a reheat stage to manage temperature and relative humidity.

**3.37****sustainability**

maintenance of ecosystem components and functions for future generations, to address economic efficiency, social issues and environmental preservation

[SOURCE: ISO 16813:2006, 3.27]

**3.38****systems**

processes undergoing assessment

Note 1 to entry: Examples include heating, cooling, domestic hot water, lighting, ventilation and relevant automation or control.

[SOURCE: ISO 23045:2008, 3.3]

**3.39****ventilation**

process of supplying or removing air by natural means or mechanical means to or from a space for the purpose of controlling air contaminant levels, humidity, odours or temperature within the space

[SOURCE: ISO 16814:2008, 3.44]

**3.40****ventilation rate**

airflow rate at which outdoor air enters a building or enclosed space

[SOURCE: ISO 16814:2008, 3.45]

**4 General**

To manage the environment in an archive or library, objectives for planning and decisions should be determined. It should be determined what purpose environmental management will serve in meeting the preservation needs of the collections. Environmental management is often the major form of preservation action that can be carried out for all collections to prevent or slow down the deterioration of the most common materials found in archive and library collections. Determining the expected lifespan for the collections will help to determine limits to exposure to high temperature and high relative humidity and the priority within the collections for maintaining the best environment possible. To do this appropriately, the knowledge of the collections and the specific vulnerabilities of materials and formats is vital.

It is advisable to collect data relating to the collections, including:

- the materials present in the collections, and the quantities of each;
- the significance of the items, and the aspects of the items that form the basis of their significance;
- the desired lifetime of the items;
- the present condition of the collections;
- the ways in which the collections are used, including storage, handling, display or loan;
- the history of any conservation or other interventions that might affect the stability or vulnerability.

The quantities need only be approximate, but it is important that all materials present are identified.

The significance of an item is the key to why it is in the collections: it is important to understand what aspect of it gives it its significance, as it is this that should be preserved.

All materials deteriorate slowly even under the best conditions. It is not helpful to say that items should be preserved “in perpetuity”, as this implies that infinite resources should be spent on doing so. It may be more useful to speak about the point at which the original significance of the item is lost, or when it has become “unfit for use”. It has been suggested<sup>[29]</sup> that each institution should select a planning horizon that is realistic for their circumstances (possibly 50, 100, 500 years, or longer) and, on the basis of the nature of the collections and the present storage environment, to predict when the item will cease to be fit for purpose. If the point at which the item become unusable comes before the planning horizon, it indicates that there is a choice of doing something about the lifetime or, if resources do not allow action, accepting that this point is the item’s lifetime. If the point of non-usability is beyond the planning horizon, it indicates that nothing needs to be changed. If the point of non-usability is somewhere close to the planning horizon, it indicates that nothing needs to be changed in the present because a review at set intervals may involve new information and a new starting point.

The long term planning horizon has been explored recently in a series of papers based on research carried out at the Centre for Sustainable Heritage, University College of London<sup>[24]</sup>. In this research, surveys of public users of archive and library materials studied what is considered “unfit for use” in terms of the threshold of damage, or extent of physical change that is assessed as damage. This research is significant for the environmental management of collections because the changes considered were discolouration and mechanical deterioration, such as tears and missing pieces, often an indicator of brittle and fragile materials. These physical changes are often seen in archive and library materials that have been maintained in inappropriate environments for long periods of time.

An assessment of the present condition may indicate whether items are stable, at risk or actively deteriorating which may provide information on the suitability or unsuitability of the current environment.

The institution will need to collect data relating to the environments in which collections are stored, handled, displayed or loaned, including:

- records of the internal and external temperature and relative humidity;
- records of the levels of visible and ultraviolet light to which items are exposed, and the duration of such exposure;
- records of gaseous and particulate pollutants to which items are exposed;
- where active methods of environmental control are used, such as mechanical ventilation, filtration, heating, cooling, humidification and dehumidification, records shall be made of the control settings and any alterations made to them (e.g. seasonal variations) and the amount of energy used by each of these systems.

Where possible, records should be made of the conditions in each different environment in which collections are housed.