

ISO/TC 107

Secretariat: KATS

Voting begins on:
2015-09-17

Voting terminates on:
2015-11-17

Vitreous and porcelain enamels — Design of bolted steel tanks for the storage or treatment of water or municipal or industrial effluents and sludges

*Émaux vitrifiés — Conception de réservoirs en acier boulonnés pour
le stockage ou le traitement des eaux ou des effluents d'eaux usées
urbains ou industriels*

PREVIEW
iTech STANDARD (standards.iteh.ai)
Full standard available on
<https://standards.iteh.ai/catalog/standards/sist/8aa08ba1-2815-4266-b539-f6d15096923/iso-28765-2015>

Please see the administrative notes on page iii

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.



Reference number
ISO/FDIS 28765:2015(E)

ISO/CEN PARALLEL PROCESSING

This final draft has been developed within the International Organization for Standardization (ISO), and processed under the **ISO-lead** mode of collaboration as defined in the Vienna Agreement. The final draft was established on the basis of comments received during a parallel enquiry on the draft.

This final draft is hereby submitted to the ISO member bodies and to the CEN member bodies for a parallel two-month approval vote in ISO and formal vote in CEN.

Positive votes shall not be accompanied by comments.

Negative votes shall be accompanied by the relevant technical reasons.

iTeh STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/8aa08ba1-ecec-4266-b539-f6d15096923/iso-28765-2016>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2015, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

	Page
Foreword	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Symbols and abbreviated terms	4
5 Units	5
6 Information and requirements to be agreed and documented	5
6.1 General	5
6.2 Information to be provided by the purchaser	6
6.3 Information to be provided by the designer	6
7 Applicable standards	7
8 Loads	7
8.1 General	7
8.2 Contents	7
8.2.1 General	7
8.2.2 Freeboard	8
8.2.3 Hydrostatic pressure	8
8.2.4 Axial wall forces	8
8.2.5 Filling and discharging	8
8.3 Tank structure	8
8.4 Roof	9
8.5 Equipment loads	9
8.5.1 General	9
8.5.2 Static load	9
8.5.3 Dynamic load	9
8.6 Access	9
8.7 Environmental	9
8.7.1 General	9
8.7.2 Seismic action	10
8.7.3 Wind	10
8.7.4 Snow	10
8.7.5 Ice	10
8.8 Ancillary items	10
9 Design	10
9.1 General	10
9.2 Steel	10
9.2.1 Specification	10
9.2.2 Effects of the enamelling process	11
9.3 Tank	11
9.3.1 Load factors	11
9.3.2 Tank walls	11
9.3.3 Tank roof	14
9.3.4 Attachment of walls to floor	15
9.3.5 Tank floor	15
9.3.6 Ancillary items	15
9.3.7 Cathodic protection	16
9.4 Openings	16
9.4.1 Access manway	16
9.4.2 Pipe connections	16
9.4.3 Overflows	16
9.4.4 Reinforcement of manways and pipe connections in the tank shell	16

9.4.5	Connections in the roof.....	17
9.5	Effects of accidents.....	17
9.5.1	Risk assessment.....	17
9.5.2	Explosions.....	17
9.5.3	Uncontrolled fluctuation in input stream characteristics.....	17
10	Vitreous-enamel coating.....	18
10.1	Vitreous enamel.....	18
10.2	Coating.....	18
10.3	Vitreous-enamel quality.....	18
10.3.1	Preparation and test frequency.....	18
10.3.2	Inspection.....	18
10.3.3	On-site rectification.....	19
10.4	Protection during shipping.....	23
10.5	Maintenance.....	23
11	Installation.....	23
11.1	General guidance.....	23
11.2	Foundations.....	23
11.3	Inspection of the vitreous-enamel coating at the construction site.....	23
12	Disinfection.....	23
	Bibliography.....	24

iTeh STANDARD PREVIEW
 (standards.iteh.ai)
 Full standard:
<https://standards.iteh.ai/catalog/standards/sist/8aa08ba1-ecec-4266-b539-f6d15096923/iso-28765-2016>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 107, *Metallic and other inorganic coatings*.

This second edition cancels and replaces the first edition (ISO 28765:2008), which has been technically revised.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Full standard:
<https://standards.iteh.ai/catalog/standards/sist/8aa08ba1-ecec-4266-b539-f6d15096923/iso-28765-2016>

Vitreous and porcelain enamels — Design of bolted steel tanks for the storage or treatment of water or municipal or industrial effluents and sludges

1 Scope

This International Standard establishes the requirements for the design and use of vitreous-enamel-coated bolted cylindrical steel tanks for the storage or treatment of water or municipal or industrial effluents and sludges.

It applies to the design of the tank and any associated roof and gives guidance on the requirements for the design of the foundation.

It applies where

- a) the tank is cylindrical and is mounted on a load-bearing base substantially at or above ground level;
- b) the product of the tank diameter in metres and the wall height in metres lies within the range 5 to 500;
- c) the tank diameter does not exceed 100 m and the total wall height does not exceed 50 m;
- d) the stored material has the characteristics of a liquid, exerting a negligible frictional force on the tank wall; the stored material may be undergoing treatment as part of a municipal or industrial effluent treatment process;
- e) the internal pressure in the headspace above the liquid does not exceed 50 kPa and the internal partial vacuum above the liquid does not exceed 10 kPa;
- f) the walls of the tank are vertical;
- g) the floor of the tank is substantially flat at its intersection with the wall; the floor of the tank may have a rise or fall built in to allow complete emptying of the tank contents, the slope of which does not exceed 1:100;
- h) there is negligible inertial and impact load due to tank filling;
- i) the minimum thickness of the tank shell is 1,5 mm;
- j) the material used for the manufacture of the steel sheets is carbon steel (tanks constructed of sheets made from aluminium or stainless steel are outside the scope of this International Standard);
- k) the temperature of the tank wall during operation is within the range $-50\text{ }^{\circ}\text{C}$ to $+100\text{ }^{\circ}\text{C}$ under all operating conditions.

This International Standard also gives details of procedures to be followed during installation on site and for inspection and maintenance of the installed tank.

It does not apply to chemical-reaction vessels.

It does not cover resistance to fire.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO/FDIS 28765:2015(E)

ISO 2178, *Non-magnetic coatings on magnetic substrates — Measurement of coating thickness — Magnetic method*

ISO 2859-1, *Sampling procedures for inspection by attributes — Part 1: Sampling schemes indexed by acceptance quality limit (AQL) for lot-by-lot inspection*

ISO 4532, *Vitreous and porcelain enamels — Determination of the resistance of enamelled articles to impact — Pistol test*

ISO 6370-2, *Vitreous and porcelain enamels — Determination of the resistance to abrasion — Part 2: Loss in mass after sub-surface abrasion*

ISO 8289:2000, *Vitreous and porcelain enamels — Low voltage test for detecting and locating defects*

ISO 15686-1, *Buildings and constructed assets — Service life planning — Part 1: General principles and framework*

ISO 28706-1:2008, *Vitreous and porcelain enamels — Determination of resistance to chemical corrosion — Part 1: Determination of resistance to chemical corrosion by acids at room temperature*

ISO 28706-2:2008, *Vitreous and porcelain enamels — Determination of resistance to chemical corrosion — Part 2: Determination of resistance to chemical corrosion by boiling acids, boiling neutral liquids and/or their vapours*

ISO 28706-3:2008, *Vitreous and porcelain enamels — Determination of resistance to chemical corrosion — Part 3: Determination of resistance to chemical corrosion by alkaline liquids using a hexagonal vessel*

ISO 28706-4:2008, *Vitreous and porcelain enamels — Determination of resistance to chemical corrosion — Part 4: Determination of resistance to chemical corrosion by alkaline liquids using a cylindrical vessel*

ISO 28763:2008, *Vitreous and porcelain enamels — Regenerative, enamelled and packed panels for air-gas and gas-gas heat exchangers — Specifications*

EN 15771, *Vitreous and porcelain enamels — Determination of surface scratch hardness according to the Mohs scale*

EN 1993-1-6, *Eurocode 3 — Design of steel structures — Part 1-6: Strength and Stability of Shell Structures*

EN 1993-4-1, *Eurocode 3 — Design of steel structures — Part 4-1: Silos*

EN 1993-4-2, *Eurocode 3 — Design of steel structures — Part 4-2: Tanks*

EN 1998-4, *Eurocode 8 — Design of structures for earthquake resistance — Part 4: Silos, tanks and pipelines*

EN 10209:1996, *Cold rolled low carbon steel flat products for vitreous enamelling — Technical delivery conditions*

EN 14430:2004, *Vitreous and porcelain enamels — High voltage test*

EN 15826, *Vitreous and porcelain enamels — Terminology*

ANSI/AWWA D 103, *Factory-Coated Bolted Steel Tanks for Water Storage*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 15826 and the following apply.

3.1 brief

working document which specifies at any point in time the relevant needs and aims of the project, the resources to be provided by the client, the details of the project and any applicable design requirements within which all subsequent briefing (when needed) and designing can take place

3.2**client**

person or organization that requires a tank to be provided, altered or extended and is responsible for initiating and approving the brief

3.3**defect**

break in the surface of the vitreous enamel

3.4**designer**

person or organization responsible for stating the shape and specification of the component to be designed

3.5**design life**

service life intended by the designer

3.6**enamel supplier**

person or organization supplying materials for use by the vitreous enameller in the enamelling process

3.7**freeboard**

distance between the top of the cylindrical-tank vertical shell wall and the surface of the contained liquid at the specified operating level

3.8**headspace pressure**

pressure within a roofed tank above the stored liquid

3.9**inspection area**

area inside a boundary 25 mm from any panel edge or hole and outside a boundary 25 mm from any opening or hole within the body of a panel

3.10**liquid**

bulk substance that exerts substantially the same vertical and horizontal pressures and has no fixed shape

3.11**maintenance**

combination of all technical and associated administrative actions during the service life to retain a tank or its parts in a state in which it can perform its required function

3.12**manufacturer**

person or organization that manufactures the tank or parts of the tank

3.13**purchaser**

person or organization purchasing the tank from the supplier

Note 1 to entry: The purchaser can also be the client.

3.14**rectification**

return of a tank or its parts to an acceptable condition by the renewal, replacement or repair of worn, damaged or degraded parts

**3.15
supplier**

person or organization that supplies the tank or parts of the tank

**3.16
service life**

period of time after installation during which the tank or its parts meets or exceeds the performance requirements

**3.17
tank**

cylindrical, vertical shell for containing liquid, with or without a roof, which is constructed from vitreous-enamelled curved steel panels bolted together on the construction site and mounted on a base which may also form the floor of the container

**3.18
vitreous enameller**

person undertaking and controlling the process of preparing the steel sheets and applying the vitreous-enamel coating to the surfaces of the steel sheets

Note 1 to entry: The vitreous enameller will normally be the manufacturer.

4 Symbols and abbreviated terms

For the purposes of this document, the following symbols and abbreviated terms apply.

D	tank diameter
E	Young's modulus of elasticity
F_H	static hoop force
g	acceleration due to gravity
H	depth of liquid at point under consideration, measured from the liquid surface at the maximum possible filling level
H_0	total vertical wall height
l	length of shell between intermediate stiffeners
I_z	second moment of area of a stiffener
p_n	static liquid pressure at a specified depth
p_h	headspace pressure
r	tank radius
$q_{r,cr}$	critical external buckling pressure
q_{wmax}	maximum stagnation pressure due to wind
w	proportion of dissolved solids in sludge
t	shell plate thickness
ν	Poisson's ratio
γ	partial load factor

ρ	relative density of a liquid
σ	stress
$\sigma_{z,cr}$	critical axial buckling resistance
cr	(subscript) critical
ds	(subscript) dissolved solids
h	(subscript) headspace
max	(subscript) maximum value
n	(subscript) normal to the tank wall
s	(subscript) sludge
w	(subscript) wind
z	(subscript) coincident with the central axis of a shell of revolution
φ	(subscript) coincident with the radial axis of a shell of revolution

5 Units

The use of one of the following sets of consistent units is recommended:

— dimensions:	m, mm
— unit weight:	kN/m ³ , N/mm ³
— forces and loads:	kN, N
— line forces and line loads:	kN/m, N/mm
— pressures and area-distributed actions:	kPa, MPa
— unit mass:	kg/m ³ , kg/mm ³
— acceleration:	km/s ² , m/s ²
— membrane-stress resultants:	kN/m, N/mm
— bending-stress resultants:	kNm/m, Nmm/mm
— stresses and elastic moduli:	kPa, MPa (1 MPa = 1 N/mm ²)

6 Information and requirements to be agreed and documented

6.1 General

For the safe design and manufacture of the tank and associated parts, the specification shall be agreed between the contracting parties.