
**Električne inštalacije za razsvetljavo in radijske javljalnike na letališčih - 1-2. del:
Temeljna načela - Posebne zahteve za zaporedna vezja (IEC 61820-1-2:2024)**

Electrical installations for lighting and beaconing of aerodromes - Part 1-2: Fundamental principles - Particular requirements for series circuits (IEC 61820-1-2:2024)

Elektrische Anlagen für Beleuchtung und Befeuerung von Flugplätzen - Teil 1-2:
Allgemeine Grundsätze - Anforderungen an die Serienkreise (IEC 61820-1-2:2024)

Installations électriques pour l'éclairage et le balisage dans les aérodromes - Partie 1-2 :
Principes fondamentaux - Exigences particulières relatives aux circuits série (IEC 61820-1-2:2024)

Ta slovenski standard je istoveten z: IEC EN IEC 61820-1-2:2024

<https://standards.iteh.ai/catalog/standards/sist/4e3aac75-6821-4e09-b1f2-75a7d24661c9/sist-en-iec-61820-1-2-2024>

ICS:

29.140.50	Instalacijski sistemi za razsvetljavo	Lighting installation systems
49.100	Oprema za servis in vzdrževanje na tleh	Ground service and maintenance equipment
93.120	Gradnja letališč	Construction of airports

SIST EN IEC 61820-1-2:2024**en**

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN IEC 61820-1-2

May 2024

ICS 29.140.50; 93.120

English Version

**Electrical installations for lighting and beaconing of aerodromes -
Part 1-2: Fundamental principles - Particular requirements for
series circuits
(IEC 61820-1-2:2024)**

Installations électriques pour l'éclairage et le balisage dans
les aérodromes - Partie 1-2 : Principes fondamentaux -
Exigences particulières relatives aux circuits série
(IEC 61820-1-2:2024)

Elektrische Anlagen für Beleuchtung und Befeuerung von
Flugplätzen - Teil 1-2: Allgemeine Grundsätze -
Anforderungen an die Serienkreise
(IEC 61820-1-2:2024)

This European Standard was approved by CENELEC on 2024-05-10. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

[SIST EN IEC 61820-1-2:2024](https://standards.iteh.ai/catalog/standards/sist/4e3aac75-6821-4e09-b1f2-75a7d24661c9/sist-en-iec-61820-1-2-2024)

<https://standards.iteh.ai/catalog/standards/sist/4e3aac75-6821-4e09-b1f2-75a7d24661c9/sist-en-iec-61820-1-2-2024>



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN IEC 61820-1-2:2024 (E)**European foreword**

The text of document 97/267/FDIS, future edition 1 of IEC 61820-1-2, prepared by IEC/TC 97 "Electrical installations for lighting and beaconing of aerodromes" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61820-1-2:2024.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2025-02-10 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2027-05-10 document have to be withdrawn

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 61820-1-2:2024 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 60060-3 NOTE Approved as EN 60060-3

IEC 61000-4-5 NOTE Approved as EN 61000-4-5

IEC 61821 NOTE Approved as EN 61821

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cencenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60060	series	High-voltage test techniques	EN 60060	series
IEC 60364	series	Low-voltage electrical installations	HD 60364	series
IEC 61000	series	Electromagnetic compatibility (EMC)	EN 61000	series
IEC 61557	series	Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC - Equipment for testing, measuring or monitoring of protective measures	EN IEC 61557	series
IEC 61820-1	2019	Electrical installations for aeronautical ground lighting at aerodromes - Part 1: Fundamental principles	EN IEC 61820-1	2019
IEC 61820-3-2	-	Electrical installations for lighting and beaconing of aerodromes - Part 3-2: Requirements for power supplies - Particular requirements for series circuits	EN IEC 61820-3-2	-
IEC 61820-3-4	-	Electrical installations for lighting and beaconing of aerodromes - Part 3-4: Safety secondary circuits in series circuits - General safety requirements	EN IEC 61820-3-4	-
IEC 61823	-	Electrical installations for lighting and beaconing of aerodromes - AGL series transformers	EN 61823	-
IEC 63067	-	Electrical installations for lighting and beaconing of aerodromes - Connecting devices - General requirements and tests	EN IEC 63067	-



IEC 61820-1-2

Edition 1.0 2024-04

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Electrical installations for lighting and beaconing of aerodromes –
Part 1-2: Fundamental principles – Particular requirements for series circuits**

**Installations électriques pour l'éclairage et le balisage dans les aérodromes –
Partie 1-2 : Principes fondamentaux – Exigences particulières relatives aux
circuits série**

[SIST EN IEC 61820-1-2:2024](https://standards.iteh.ai/catalog/standards/sist/4e3aac75-6821-4e09-b1f2-75a7d24661c9/sist-en-iec-61820-1-2-2024)

<https://standards.iteh.ai/catalog/standards/sist/4e3aac75-6821-4e09-b1f2-75a7d24661c9/sist-en-iec-61820-1-2-2024>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.140.50, 93.120

ISBN 978-2-8322-8579-4

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 Requirements	9
4.1 General.....	9
4.2 Series circuit power supply	9
4.3 Isolation of field circuit.....	9
4.4 Electrical supply to series circuit power equipment (i.e. CCRs)	11
4.5 Series circuit maximum voltage.....	11
4.6 Overcurrent protection	11
4.7 Open circuit protection.....	11
4.8 System insulation resistance.....	12
4.9 Insulation resistance monitoring.....	12
4.10 Operational insulation resistance value.....	12
4.11 Fault protection.....	12
4.12 Cables	12
4.12.1 General	12
4.12.2 Screened (shielded) cables for the primary circuit.....	12
4.13 Earthing of equipment.....	12
5 Selection and installation of AGL equipment and systems	13
5.1 General.....	13
5.2 Operational conditions	13
5.2.1 Voltage	13
5.2.2 Current	13
5.2.3 Frequency	13
5.2.4 Power	13
5.3 Series circuit communication	13
5.4 Electromagnetic compatibility (EMC).....	13
5.5 Impulse withstand voltage.....	14
5.6 Accessibility.....	14
5.7 Cable, transformer and duct installation	14
5.8 Primary and secondary connecting devices.....	14
5.9 Proximity of cables.....	14
5.10 Labelling.....	15
6 Inspection and testing.....	15
6.1 Initial verification.....	15
6.2 Periodic inspection and testing	15
6.3 Visual inspection.....	16
6.4 Testing	17
6.4.1 General	17
6.4.2 Conductor continuity.....	17
6.4.3 Insulation resistance of field circuit.....	17
6.4.4 SELV and PELV	19
6.4.5 Earth electrode resistance	19

6.4.6	Functional testing	20
6.5	Certification and reporting.....	20
6.6	Records	20
Annex A (informative)	New installation insulation value (under development).....	21
Annex B (informative)	AGL installation certificate.....	23
Annex C (informative)	Schedule of verification	31
Bibliography.....		34
Figure 1 – Field circuit isolator modes of operation		11
Table 1 – Test voltages and insulation resistance values		18
Table A.1 – Theoretical leakage currents in series circuit elements as a function of cable voltage class		21
Table B.1 – AGL installation certificate		23
Table B.2 – AGL periodic inspection and testing report.....		26
Table B.3 – AGL circuit continuity and insulation resistance test results.....		29
Table C.1 – Schedule of verification.....		31

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[SIST EN IEC 61820-1-2:2024](https://standards.iteh.ai/catalog/standards/sist/4e3aac75-6821-4e09-b1f2-75a7d24661c9/sist-en-iec-61820-1-2-2024)

<https://standards.iteh.ai/catalog/standards/sist/4e3aac75-6821-4e09-b1f2-75a7d24661c9/sist-en-iec-61820-1-2-2024>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICAL INSTALLATIONS FOR LIGHTING
AND BEACONING OF AERODROMES –**
**Part 1-2: Fundamental principles –
Particular requirements for series circuits**
FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61820-1-2 has been prepared by IEC technical committee 97: Electrical installations for lighting and beaconing of aerodromes. It is an International Standard.

The text of this International Standard is based on the following documents:

Draft	Report on voting
97/267/FDIS	97/268/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 61820 series, published under the general title *Electrical installations for lighting and beaconing of aerodromes*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

iTeh Standards (<https://standards.iteh.ai>) Document Preview

[SIST EN IEC 61820-1-2:2024](https://standards.iteh.ai/catalog/standards/sist/4e3aac75-6821-4e09-b1f2-75a7d24661c9/sist-en-iec-61820-1-2-2024)

<https://standards.iteh.ai/catalog/standards/sist/4e3aac75-6821-4e09-b1f2-75a7d24661c9/sist-en-iec-61820-1-2-2024>

INTRODUCTION

This document is a part of the IEC 61820 series that describes the minimum requirements for the lifecycle of an aeronautical ground lighting (AGL) system including design, installation, commissioning, maintenance, decommissioning and disposal.

The series circuit normally operates with a constant current and a load dependent variable voltage. The protective measures for series circuits according to this document are adapted to that supply concept and the extreme long cables in the field. They are based in principle on an IT supply concept (floating and separated from ground) and the protection against direct contact to any live part at least for the primary circuit and safety extra low voltage (SELV) or protective extra low voltage (PELV) power supply feeding the light fixtures or other loads of the series circuit. In recognition of possible aviation hazards, an automatic disconnection of the AGL system in case of an electrical failure is not required in general (see details in IEC 61820-1).

People involved in work on AGL electrical systems are knowledgeable of the specific risks and the safety procedures involved in the work related to the applied system design. It is strongly recommended to do a work safety risk analysis considering all local circumstances to define safe work procedures and training to the personnel. Training regarding the hazards of series circuits should be provided to non-electricians (e.g. grass cutters, snow plow operators, etc.)

NOTE 1 For specifications on SELV/PELV power supplies for AGL systems, see IEC 61820-3-4.

NOTE 2 Local/national regulations can be different to these standard provisions.

NOTE 3 In case the power supply is not compliant to SELV or PELV, appropriate measures can be implemented.

NOTE 4 Where the terms "voltage" and "current" are used in this document, they refer to RMS values unless otherwise specified.

iteh Standards
(<https://standards.iteh.ai>)
Document Preview

[SIST EN IEC 61820-1-2:2024](https://standards.iteh.ai/catalog/standards/sist/4e3aac75-6821-4e09-b1f2-75a7d24661c9/sist-en-iec-61820-1-2-2024)

<https://standards.iteh.ai/catalog/standards/sist/4e3aac75-6821-4e09-b1f2-75a7d24661c9/sist-en-iec-61820-1-2-2024>