



**SLOVENSKI STANDARD
SIST EN ISO 12241:2022**

01-september-2022

**Nadomešča:
SIST EN ISO 12241:2008**

**Toplotna izolacija za opremo stavb in industrijske inštalacije - Pravila za računanje
(ISO 12241:2022)**

Thermal insulation for building equipment and industrial installations - Calculation rules
(ISO 12241:2022)

Wärmedämmung an haus- und betriebstechnischen Anlagen - Berechnungsregeln (ISO
12241:2022)

Isolation thermique des équipements de bâtiments et des installations industrielles -
Méthodes de calcul (ISO 12241:2022)

Ta slovenski standard je istoveten z: EN ISO 12241:2022

ICS:

91.120.10	Toplotna izolacija stavb	Thermal insulation of buildings
91.140.01	Napeljave v stavbah na splošno	Installations in buildings in general

SIST EN ISO 12241:2022 en,fr,de

EUROPEAN STANDARD

EN ISO 12241

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2022

ICS 91.120.10; 91.140.01

Supersedes EN ISO 12241:2008

English Version

Thermal insulation for building equipment and industrial installations - Calculation rules (ISO 12241:2022)

Isolation thermique des équipements de bâtiments et des installations industrielles - Méthodes de calcul (ISO 12241:2022)

Wärmedämmung an haus- und betriebstechnischen Anlagen - Berechnungsregeln (ISO 12241:2022)

This European Standard was approved by CEN on 29 May 2022.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

<https://standards.iteh.ai/catalog/standards/sist/001e757e-1b02-4c33-a8a8-257ef460b53f/sist-en-iso-12241-2022>



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	3

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN ISO 12241:2022

<https://standards.iteh.ai/catalog/standards/sist/001e757e-1b02-4c33-a8a8-257ef460b53f/sist-en-iso-12241-2022>

European foreword

This document (EN ISO 12241:2022) has been prepared by Technical Committee ISO/TC 163 "Thermal performance and energy use in the built environment" in collaboration with Technical Committee CEN/TC 89 "Thermal performance of buildings and building components" the secretariat of which is held by SIS.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by December 2022, and conflicting national standards shall be withdrawn at the latest by December 2022.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 12241:2008.

This document has been prepared under a Standardization Request given to CEN by the European Commission and the European Free Trade Association.

Any feedback and questions on this document should be directed to the users' national standards body/national committee. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

<https://standards.iteh.ai/catalog/standards/sist/001e757e-1b02-4c33-a8a8-257ef460b53f/sist-en-iso-12241-2022>

Endorsement notice

The text of ISO 12241:2022 has been approved by CEN as EN ISO 12241:2022 without any modification.

INTERNATIONAL
STANDARD

ISO
12241

Third edition
2022-06

**Thermal insulation for building
equipment and industrial
installations — Calculation rules**

*Isolation thermique des équipements de bâtiments et des installations
industrielles — Méthodes de calcul*

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 12241:2022](https://standards.iteh.ai/catalog/standards/sist/001e757e-1b02-4c33-a8a8-257ef460b53f/sist-en-iso-12241-2022)

<https://standards.iteh.ai/catalog/standards/sist/001e757e-1b02-4c33-a8a8-257ef460b53f/sist-en-iso-12241-2022>



Reference number
ISO 12241:2022(E)

© ISO 2022

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN ISO 12241:2022

<https://standards.iteh.ai/catalog/standards/sist/001e757e-1b02-4c33-a8a8-257ef460b53f/sist-en-iso-12241-2022>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2022

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword.....	iv
Introduction.....	v
1 Scope.....	1
2 Normative references.....	1
3 Terms, definitions and symbols.....	1
3.1 Terms and definitions.....	1
3.2 Symbols.....	1
3.3 Subscripts.....	3
4 Calculation rules and formulae of heat transfer.....	4
4.1 Fundamental formulae for heat transfer.....	4
4.1.1 General.....	4
4.1.2 Thermal conduction.....	4
4.1.3 Surface coefficient of heat transfer.....	9
4.1.4 External surface resistance.....	16
4.1.5 Thermal transmittance.....	16
4.1.6 Heat flow rate.....	18
4.1.7 Temperatures of the layer boundaries.....	18
4.2 Determination of the influence of thermal bridges.....	19
4.2.1 General.....	19
4.2.2 Insulation system related thermal bridges.....	19
4.2.3 Installation related thermal bridges.....	19
4.3 Determination of total heat flow rate for plane walls, pipes and spheres.....	20
4.4 Surface temperature.....	20
4.5 Prevention of surface condensation.....	21
5 Calculation of the temperature change in pipes, vessels, and containers.....	22
5.1 General.....	22
5.2 Longitudinal temperature change in a pipe.....	23
5.3 Temperature change and cooling times in pipes, vessels, and containers.....	23
6 Calculation of cooling and freezing times of stationary liquids.....	24
6.1 Calculation of the cooling time to prevent the freezing of water in a pipe.....	24
6.2 Calculation of the freezing time of water in a pipe.....	25
7 Calculation of heat loss for underground pipelines.....	26
7.1 General.....	26
7.2 Single line without channels.....	26
7.2.1 Uninsulated pipe.....	26
7.2.2 Insulated pipe.....	27
7.3 Other cases.....	28
Annex A (informative) Thermal bridges.....	29
Annex B (informative) Examples.....	43
Bibliography.....	52

ISO 12241:2022(E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 163, *Thermal performance and energy use in the built environment*, Subcommittee SC 2, *Calculation methods*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 89, *Thermal performance of buildings and building components*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This third edition cancels and replaces the second edition (ISO 12241:2008), which has been technically revised.

The main changes are as follows:

- how to calculate the convective part of the external surface coefficient of heat transfer;
- how to introduce thermal bridges in the general heat loss calculation;
- provides detailed data along with the method for calculating fittings (thermal bridges), only informative.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

Methods relating to conduction are direct mathematical derivations from Fourier's law of heat conduction, so no significant difference in the formulae used in the member countries exists. For convection and radiation, however, there are no methods in practical use that are mathematically traceable to Newton's law of cooling or the Stefan-Boltzman law of thermal radiation, without some empirical element. For convection in particular, many different formulae have been developed, based on laboratory data. Different formulae have become popular in different countries, and no exact means are available to select between these formulae.

Within the limitations given below, these methods can be applied to most types of industrial, thermal-insulation, heat-transfer problems.

- a) These methods do not take into account the permeation of air and the transmittance of thermal radiation through transparent media.
- b) The formulae in these methods require for their solution that some system variables be known, given, assumed or measured. In all cases, the accuracy of the results depends on the accuracy of the input variables. This document contains no guidelines for accurate measurement of any of the variables. However, it does contain guides that have proven satisfactory for estimating some of the variables for many industrial thermal systems.
- c) When the steady-state calculations are used in a changing thermal environment (process equipment operating year-round, outdoors, for example), it is necessary to use local weather data based on yearly averages or yearly extremes of the weather variables (depending on the nature of the particular calculation) for the calculations in this document.
- d) In particular, the user should not infer from the methods of this document that either insulation quality or avoidance of dew formation can be reliably assured based on minimal, simple measurements and application of the basic calculation methods given here. For most industrial heat flow surfaces, there is no isothermal state (no one, homogeneous temperature across the surface), but rather a varying temperature profile. Furthermore, the heat flow through a surface at any point is a function of several variables that are not directly related to insulation quality. Among others, these variables include ambient temperature, movement of the air, roughness and emissivity of the heat flow surface, and the radiation exchange with the surroundings (which often vary widely). For calculation of dew formation, variability of the local humidity is an important factor.
- e) Except inside buildings, the average temperature of the radiant background seldom corresponds to the air temperature, and measurement of background temperatures, emissivity and exposure areas is beyond the scope of this document. For these reasons, neither the surface temperature nor the temperature difference between the surface and the air can be used as a reliable indicator of insulation performance or avoidance of dew formation.

[Clauses 4](#) and [5](#) of this document give the methods used for industrial thermal insulation calculations not covered by more specific standards.

[Clauses 6](#) and [7](#) of this document are adaptations of the general formula for specific applications of calculating heat flow, temperature drop, and freezing times in pipes and other vessels. Thermal insulation to heating/cooling systems such as a boiler and refrigerator are not dealt with by this document.

[Annexes A](#) and [B](#) of this document are for information only.

Thermal insulation for building equipment and industrial installations — Calculation rules

1 Scope

This document gives rules for the calculation of heat-transfer-related properties of building equipment and industrial installations, predominantly under steady-state conditions. This document also gives a simplified approach for the calculation of thermal bridges.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 7345, *Thermal performance of buildings and building components — Physical quantities and definitions*

ISO 9346, *Hygrothermal performance of buildings and building materials — Physical quantities for mass transfer — Vocabulary*

ISO 13787, *Thermal insulation products for building equipment and industrial installations — Determination of declared thermal conductivity*

ISO 13788, *Hygrothermal performance of building components and building elements — Internal surface temperature to avoid critical surface humidity and interstitial condensation — Calculation methods*

ISO 23993, *Thermal insulation products for building equipment and industrial installations — Determination of design thermal conductivity*

3 Terms, definitions and symbols

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 7345, ISO 9346, ISO 13787 and ISO 23993 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1.1

thermally separated end disc

end disc used so that the extremities and end caps are not in contact with the object

Note 1 to entry: This construction is used to avoid thermal bridges and the risk of damaging vapour retarders or pipe tracing ^[15].

3.2 Symbols

[Table 1](#) gives the definition and unit of symbols used in this document.

Table 1 — Definition and unit of symbol

Symbol	Definition	Unit
A	area	m^2
A_s	solar absorption coefficient	
a	length of a rectangle	m
a_r	temperature factor	K^3
b	width of a rectangle	m
C_r	radiation coefficient	$W/(m^2 \cdot K^4)$
c_p	specific heat capacity at constant pressure	$J/(kg \cdot K)$
D	diameter	m
d	thickness	m
d_R	insulation layer thickness of the pipe	m
F	overall conversion factor for thermal conductivity	
Gr	Grashof number	
H	height	m
h	surface coefficient of heat transfer	$W/(m^2 \cdot K)$
J_s	solar radiation	W/m^2
K	thermal bridge coefficient	W/K
L	length	m
l	characteristic length	m
l_i	insulation box inside length	m
m	mass	kg
\dot{m}	mass flow rate	kg/s
Nu	Nusselt number	
P	perimeter	m
p	pressure	Pa
p_a	water vapour pressure	Pa
Pr	Prandtl number	
q	density of heat flow rate	W/m^2 or W/m
R	thermal resistance	$m^2 \cdot K/W$ or $m \cdot K/W$ or K/W
Re	Reynolds number	
S	space inside the insulation box	
T	thermodynamic temperature	K
t	time	s
U	thermal transmittance	$W/(m^2 \cdot K)$ or $W/(m \cdot K)$ or W/K
w	velocity of the air or other fluid	m/s
x	Bolt length + 20 mm	mm
α	coefficient of longitudinal temperature drop	m^{-1}
α'	coefficient of cooling time	s^{-1}
Δh	latent heat	J/kg
ε	emissivity	
Φ	heat flow rate	W
λ	thermal conductivity	$W/(m \cdot K)$
λ_d	declared thermal conductivity	$W/(m \cdot K)$
λ_D	design thermal conductivity	$W/(m \cdot K)$

Table 1 (continued)

Symbol	Definition	Unit
θ	Celsius temperature	°C
θ_b	point of measurement of the temperature at the fin base	°C
ρ	density	kg/m ³
φ	relative humidity	%
σ	Stefan-Boltzmann constant (see Reference [8])	W/(m ² ·K ⁴)
ν	kinematic viscosity of air or other fluid	m ² /s
Δ	difference	
ΔA	equivalent area	m ²
ΔL	equivalent length	m
$\Delta\lambda$	extra conductivity due to regularly placed components in the insulation system	W/(m·K)

3.3 Subscripts

Table 2 gives the definition of subscripts used in this document.

Table 2 — Definition of subscripts

A	valve	i	interior (internal)
a	ambient,	in	initial
anc	anchor	Ka	insulation box
av	average	l	linear
B	thermal bridge	lab	laboratory
c	cooling	lam	laminar flow
cv	convection	MRT	mean radiant temperature
cr	critical	P	pump
cs	cross section	p	pipe
d	duct	r	radiation
E	soil	ref	reference
e	exterior (external)	s	surface
ef	effective	sat	saturated vapour
en	entrance	se	exterior surface
ex	exit	si	interior surface
f	fluid	sph	spherical
fa	frontal of the fin	sq	per square
fas	fastener	T	total
FEM	Finite Element Method	tb	insulation related thermal bridge
fi	final	tur	turbulent flow
fin	fin	V	vertical
fl	flange	v	vessel
forced	forced	W	wall
fr	freezing	w	water
free	free	wp	start freezing
H	horizontal		