

SLOVENSKI STANDARD
oSIST prEN ISO 23553-1:2020
01-september-2020

Varnostne in nadzorne naprave za oljne gorilnike in aparate na olje - Posebne zahteve - 1. del: Avtomatski in polavtomatski ventili (ISO/DIS 23553-1:2020)

Safety and control devices for oil burners and oil-burning appliances - Particular requirements - Part 1: Automatic and semi-automatic valves (ISO/DIS 23553-1:2020)

Sicherheits-, Regel- und Steuereinrichtungen für Ölbrenner und Öl verbrennende Geräte - Spezielle Anforderungen - Teil 1: Automatische und halbautomatische Ventile (ISO/DIS 23553-1:2020)

(standards.iteh.ai)

Dispositifs de commande et de sécurité pour brûleurs à combustible liquide et pour appareils à combustible liquide - Exigences particulières - Partie 1: Robinets automatiques et semi-automatiques (ISO/DIS 23553-1:2020)

Ta slovenski standard je istoveten z: prEN ISO 23553-1

ICS:

27.060.10	Gorilniki na tekoče in trdo gorivo	Liquid and solid fuel burners
-----------	------------------------------------	-------------------------------

oSIST prEN ISO 23553-1:2020

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[oSIST prEN ISO 23553-1:2020](https://standards.iteh.ai/catalog/standards/sist/6fd582a5-f929-44cc-a310-6476ba9ae6ab/osist-pren-iso-23553-1-2020)

<https://standards.iteh.ai/catalog/standards/sist/6fd582a5-f929-44cc-a310-6476ba9ae6ab/osist-pren-iso-23553-1-2020>

DRAFT INTERNATIONAL STANDARD

ISO/DIS 23553-1

ISO/TC 161

Secretariat: DIN

Voting begins on:
2020-07-22Voting terminates on:
2020-10-14

Safety and control devices for oil burners and oil-burning appliances — Particular requirements —

Part 1: Automatic and semi-automatic valves

Dispositifs de commande et de sécurité pour brûleurs à combustible liquide et pour appareils à combustible liquide — Exigences particulières —

Partie 1: Robinets automatiques et semi-automatiques

ICS: 27.060.10

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[oSIST prEN ISO 23553-1:2020](https://standards.iteh.ai/catalog/standards/sist/6fd582a5-f929-44cc-a310-6476ba9ae6ab/osist-pren-iso-23553-1-2020)

<https://standards.iteh.ai/catalog/standards/sist/6fd582a5-f929-44cc-a310-6476ba9ae6ab/osist-pren-iso-23553-1-2020>

THIS DOCUMENT IS A DRAFT CIRCULATED FOR COMMENT AND APPROVAL. IT IS THEREFORE SUBJECT TO CHANGE AND MAY NOT BE REFERRED TO AS AN INTERNATIONAL STANDARD UNTIL PUBLISHED AS SUCH.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

This document is circulated as received from the committee secretariat.

ISO/CEN PARALLEL PROCESSING



Reference number
ISO/DIS 23553-1:2020(E)

© ISO 2020

iTeh STANDARD PREVIEW (standards.iteh.ai)

[oSIST prEN ISO 23553-1:2020](https://standards.iteh.ai/catalog/standards/sist/6fd582a5-f929-44cc-a310-6476ba9ae6ab/osist-pren-iso-23553-1-2020)

<https://standards.iteh.ai/catalog/standards/sist/6fd582a5-f929-44cc-a310-6476ba9ae6ab/osist-pren-iso-23553-1-2020>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2020

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	vi
Introduction	vii
1 Scope	1
2 Normative references	1
3 Terms and definitions	4
4 Classification	8
4.1 Classes of control.....	8
4.2 Groups of control.....	8
4.3 Types of DC supplied controls.....	8
5 Test conditions	8
6 Construction	9
6.1 General.....	9
6.2 Construction requirements.....	9
6.2.1 Appearance.....	9
6.2.2 Holes.....	9
6.2.3 Flexible diaphragm, bellows, or similar construction.....	9
6.2.4 Screwed fastenings.....	9
6.2.5 Jointing.....	10
6.2.6 Moving parts.....	10
6.2.7 Sealing caps.....	10
6.2.8 Dismantling and reassembling for servicing and/or adjustment.....	10
6.2.9 Auxiliary channels.....	11
6.2.10 Resistance against pressure.....	11
6.2.11 Connections.....	11
6.3 Materials.....	11
6.3.1 General material requirements.....	11
6.3.2 Springs.....	12
6.3.3 Resistance to corrosion and surface protection.....	12
6.3.4 Impregnation.....	12
6.3.5 Seals for glands for moving parts.....	12
6.3.6 Non-metallic sealing materials.....	12
6.3.7 Actuators.....	13
6.3.8 Enclosures.....	13
6.3.9 Extra low voltage terminals.....	13
6.4 Oil connections.....	13
6.4.1 Making connections.....	13
6.4.2 Connection sizes.....	13
6.4.3 Threads.....	13
6.4.4 Union Joints.....	15
6.4.5 Flanges.....	15
6.4.6 Compression fittings.....	15
6.4.7 Nipples for pressure tests.....	15
6.4.8 Welded connections.....	15
6.5 Strainers.....	15
6.6 Indicator.....	16
6.6.1 Position indicator.....	16
6.6.2 Closed position indicator switch.....	16
7 Performance	16
7.1 General.....	16
7.2 Leak-tightness.....	17
7.2.1 Criteria.....	17
7.2.2 Test for leak-tightness.....	17

ISO/DIS 23553-1:2020(E)

7.3	Torsion and bending	18
7.3.1	General	18
7.3.2	Torsion	18
7.3.3	Bending moment	18
7.3.4	Torsion and bending tests	18
7.3.5	Hydrostatic strength test	22
7.4	Rated oil flow	22
7.4.1	Criteria	22
7.4.2	Test of flow capacity	22
7.5	Durability	22
7.5.1	Elastomers in contact with fuel	22
7.5.2	Resistance to fuel	22
7.5.3	Marking resistance	23
7.5.4	Resistance to scratching	23
7.5.5	Resistance to humidity	24
7.6	Functional requirements	25
7.6.1	Closing function	25
7.6.2	Valve closing time	25
7.6.3	Valve opening time	26
7.7	Endurance	26
7.7.1	General	26
7.7.2	Test of endurance	26
7.7.3	Test of endurance of electrically operated valves	26
8	Electrical Equipment	27
8.1	Heating of oil valves	27
8.1.1	Heating test	27
8.1.2	Blocked output test (temperature)	28
8.1.3	Test conditions	29
8.2	Heating for valves	29
8.3	Burnout test for valves	29
8.4	Blocking of valve mechanism	29
8.4.1	Requirement	29
8.4.2	Test on blocking of the valve mechanism (Burn-out test)	29
8.5	Electrical components	30
8.5.1	Degree of protection	30
8.5.2	Switches	30
8.5.3	Plug connector	30
8.5.4	Power-saving circuit	30
9	Electromagnetic compatibility (EMC)	31
9.1	Protection against environmental influences	31
9.1.1	Requirements	31
9.1.2	Test	32
9.2	Harmonics and interharmonics including mains signalling at a.c. power port, low frequency immunity	32
9.2.1	General	32
9.2.2	Requirements	32
9.2.3	Test	32
9.3	Voltage dips, voltage interruptions and voltage variations in the power supply network	32
9.3.1	Voltage dips and voltage interruptions	32
9.3.2	Test	32
9.3.3	Voltage variation	32
9.4	Test of influence of voltage unbalance	33
9.5	Surge immunity tests	33
9.5.1	General	33
9.5.2	Requirements	33
9.5.3	Test	33
9.6	Electrical fast transient/burst	34

9.6.1	General	34
9.6.2	Requirements	34
9.6.3	Test	34
9.7	Ring wave immunity	34
9.7.1	General	34
9.7.2	Requirements	34
9.7.3	Test	34
9.8	Electrostatic discharge	34
9.8.1	General	34
9.8.2	Requirements	34
9.8.3	Test	34
9.9	Radio-frequency electromagnetic field immunity	35
9.9.1	Immunity to conducted disturbances	35
9.9.2	Immunity to radiated disturbances	35
9.10	Influence of supply frequency variations	35
9.10.1	General	35
9.10.2	Requirements	35
9.10.3	Test	36
9.11	Power frequency magnetic field immunity	36
9.11.1	General	36
9.11.2	Requirements	36
9.11.3	Test	36
9.12	Evaluation of compliance	36
10	Marking, installation and operating instructions	36
10.1	Marking	36
10.2	Installation and operating instructions	37
10.3	Warning notice	37
Annex A	(normative) Test for immunity to power-frequency magnetic fields	39
Annex B	(normative) Specific regional requirements in European countries	40
Annex C	(normative) Specific regional requirements in Canada and USA	42
Annex D	(normative) Specific regional requirements in Japan	45
Bibliography		48

ISO/DIS 23553-1:2020(E)**Foreword**

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html. (standards.iteh.ai)

This document was prepared by Technical Committee ISO/TC 161, controls and protective devices for gas and/or oil.

<https://standards.iteh.ai/catalog/standards/sist/6fd582a5-f929-44cc-a310-1476baf6646c/iso-23553-1:2020>

This third edition cancels and replaces the second edition (ISO 23553-1:2014), which has been technically revised.

The main changes compared to the previous edition are as follows:

- References to a previous version of ISO 23550:2011 have been replaced by the content of ISO 23550:2018 wherever possible.
- All references to IEC 60730-1 have been updated to reflect the current edition IEC 60730-1:2013.
- References to standards are now dated.

A list of all parts in the ISO 2355* series can be found on the ISO website.

Introduction

This updated part of ISO 23553-1 is designed to be used as a stand-alone standard and no longer in combination with ISO 23550 “Safety and control devices for gas burners and gas-burning appliances — General requirements”.

Whereas the previous ISO 23553-1 referred to specific sections in ISO 23550, are those sections now included direct in ISO 23553-1.

Compared to the previous document ISO 23553-1:2014 no technical changes have been done and no further technical requirements have been added.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[oSIST prEN ISO 23553-1:2020](https://standards.iteh.ai/catalog/standards/sist/6fd582a5-f929-44cc-a310-6476ba9ae6ab/osist-pren-iso-23553-1-2020)

<https://standards.iteh.ai/catalog/standards/sist/6fd582a5-f929-44cc-a310-6476ba9ae6ab/osist-pren-iso-23553-1-2020>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[oSIST prEN ISO 23553-1:2020](https://standards.iteh.ai/catalog/standards/sist/6fd582a5-f929-44cc-a310-6476ba9ae6ab/osist-pren-iso-23553-1-2020)

<https://standards.iteh.ai/catalog/standards/sist/6fd582a5-f929-44cc-a310-6476ba9ae6ab/osist-pren-iso-23553-1-2020>

Safety and control devices for oil burners and oil-burning appliances — Particular requirements —

Part 1: Automatic and semi-automatic valves

1 Scope

This part of ISO 23553 specifies safety, constructional and performance requirements and testing of automatic and semi-automatic valves for oil.

It applies to automatic and semi-automatic valves which are:

- normally closed;
- used in combustion plants to interrupt the oil flow with or without delay on closing;
- for use with oil types (e.g. middle distillate fuel oil, crude oil, heavy fuel oil or kerosene) without gasoline;

NOTE 1 For other oil types (e.g. oil emulsions), additional test methods can be agreed between the manufacturer and the test authority.

NOTE 2 Oil types from petroleum refining processes are classified ISO-F-D in ISO 8216-99 and form part of a device having other function(s), such as oil pumps. In this case the test methods apply to those parts or components of the device forming the automatic and semi-automatic valves, i.e. those parts which are necessary for the closing function;

- for use on burners or in appliances using oil;
- directly or indirectly operated, electrically or by mechanical or hydraulic means;
- fitted with or without closed-position indicator switches.

This part of ISO 23553 covers type testing only.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 7-1:1994, *Pipe threads where pressure-tight joints are made on the threads — Part 1: Dimensions, tolerances and designation*

ISO 65:1981, *Carbon steel tubes suitable for screwing in accordance with ISO 7-1*

ISO 228-1:2000, *Pipe threads where pressure-tight joints are not made on the threads — Part 1: Dimensions, tolerances and designation*

ISO 262:1998, *ISO general purpose metric screw threads — Selected sizes for screws, bolts and nuts*

ISO 272:1982, *Fasteners — Hexagon products — Widths across flats*

ISO/DIS 23553-1:2020(E)

ISO 1179-1:2013, *Connections for general use and fluid power — Ports and stud ends with ISO 228-1 threads with elastomeric or metal-to-metal sealing — Part 1: Threaded ports*

ISO 1179-2:2013, *Connections for general use and fluid power — Ports and stud ends with ISO 228-1 threads with elastomeric or metal-to-metal sealing — Part 2: Heavy-duty (S series) and light-duty (L series) stud ends with elastomeric sealing (type E)*

ISO 1179-3:2007, *Connections for general use and fluid power — Ports and stud ends with ISO 228-1 threads with elastomeric or metal-to-metal sealing — Part 3: Light-duty (L series) stud ends with sealing by O-ring with retaining ring (types G and H)*

ISO 1179-4:2007, *Connections for general use and fluid power — Ports and stud ends with ISO 228-1 threads with elastomeric or metal-to-metal sealing — Part 4: Stud ends for general use only with metal-to-metal sealing (type B)*

ISO 3601-5:2015, *Fluid power systems — O-rings — Part 5: Specification of elastomeric materials for industrial applications*

ISO 6149-1:2006, *Connections for hydraulic fluid power and general use — Ports and stud ends with ISO 261 metric threads and O-ring sealing — Part 1: Ports with truncated housing for O-ring seal*

ISO 6149-3:2006, *Connections for hydraulic fluid power and general use — Ports and stud ends with ISO 261 metric threads and O-ring sealing — Part 3: Dimensions, design, test methods and requirements for light-duty (L series) stud ends*

ISO 6708:1995, *Pipework components — Definition and selection of DN (nominal size)*

ISO 7005-1:2011, *Pipe flanges — Part 1: Steel flanges for industrial and general service piping systems*

ISO 7005-2:1988, *Metallic flanges — Part 2: Cast iron flanges*

ISO 7005-3:1988, *Metallic flanges — Part 3: Copper alloy and composite flanges*

ISO/TR 7620:2005, *Rubber materials — Chemical resistance*

ISO 8216-99:2002, *Petroleum products — Fuels (class F) — Classification — Part 99: General*

ISO 8434-1:2007, *Metallic tube connections for fluid power and general use — Part 1: 24 degree cone connectors*

ISO 8434-2:2007, *Metallic tube connections for fluid power and general use — Part 2: 37 degree flared connectors*

ISO 8434-3:2005, *Metallic tube connections for fluid power and general use — Part 3: O-ring face seal connectors*

ISO 8434-6:2009, *Metallic tube connections for fluid power and general use — Part 6: 60 degree cone connectors with or without O-ring*

ISO 9974-1:1996, *Connections for general use and fluid power — Ports and stud ends with ISO 261 threads with elastomeric or metal-to-metal sealing — Part 1: Threaded ports*

ISO 9974-3:1996, *Connections for general use and fluid power — Ports and stud ends with ISO 261 threads with elastomeric or metal-to-metal sealing — Part 3: Stud ends with metal-to-metal sealing (type B)*

ISO 10763:1994, *Hydraulic fluid power - Plain-end, seamless and welded precision steel tubes - Dimensions and nominal working pressures*

ISO 23936-1:2009, *Petroleum, petrochemical and natural gas industries — Non-metallic materials in contact with media related to oil and gas production — Part 1: Thermoplastics*

ISO 23936-2:2011, *Petroleum, petrochemical and natural gas industries — Non-metallic materials in contact with media related to oil and gas production — Part 2: Elastomers*

- IEC 60534-1:2005, *Industrial-process control valves— Part 1: Control valve terminology and general considerations IEC 60534-2-3*
- IEC 60534-2-3:2015, *Industrial-process control valves - Part 2-3: Flow capacity - Test procedures*
- IEC 60730-1:2013, *Automatic electrical controls for household and similar use — Part 1: General Requirements*
- EN 1057:2006, *Copper and copper alloys — Seamless, round copper tubes for water and gas in sanitary and heating applications*
- EN 1092-1:2007, *Flanges and their joints — Circular flanges for pipes, valves, fittings and accessories, PN designated — Part 1: Steel flanges*
- EN 1092-2:1997, *Flanges and their joints — Circular flanges for pipes, valves, fittings and accessories, PN designated — Part 2: Cast iron flanges*
- EN 1092-3:2003, *Flanges and their joints — Circular flanges for pipes, valves, fittings and accessories PN designated — Part 3: Copper alloy flanges*
- EN 1092-4:2002, *Flanges and their joints — Circular flanges for pipes, valves, fittings and accessories, PN designated — Part 4: Aluminum alloy flanges*
- EN 1254-1:1998, *Copper and copper alloys — Plumbing fittings — Part 1: Fittings with ends for capillary soldering or capillary brazing to copper tubes*
- EN 1254-2:1998, *Copper and copper alloys — Plumbing fittings — Part 2: Fittings with compression ends for use with copper tubes*
- EN 1254-3:1998, *Copper and copper alloys — Plumbing fittings — Part 3: Fittings with compression ends for use with plastics pipes*
- EN 1254-5:1998, *Copper and copper alloys — Plumbing fittings — Part 5: Fittings with short ends for capillary brazing to copper tubes*
- EN 10226-1:2004, *Pipe threads where pressure tight joints are made on the threads — Part 1: Taper external threads and parallel internal threads; Dimensions, tolerances and designation*
- EN 10226-2:2005, *Pipe threads where pressure tight joints are made on the threads — Part 2: Taper external threads and taper internal threads - Dimensions, tolerances and designation*
- EN 10241:2000, *Steel threaded pipe fittings*
- EN 10242:1994, *Threaded pipe fitting in malleable cast iron*
- EN 10284:2000, *Malleable cast iron fittings with compression ends for polyethylene (PE) piping systems*
- EN 10305-1:2016, *Steel tubes for precision applications — Technical delivery conditions — Part 1: Seamless cold drawn tubes*
- EN 10305-2:2010, *Steel tubes for precision applications — Technical delivery conditions — Part 2: Welded cold drawn tubes*
- EN 10305-3:2016, *Steel tubes for precision applications — Technical delivery conditions — Part 3: Welded cold sized tubes*
- EN 10305-4:2016, *Steel tubes for precision applications — Technical delivery conditions — Part 4: Seamless cold drawn tubes for hydraulic and pneumatic power systems*
- EN 10305-6:2016, *Steel tubes for precision applications — Technical delivery conditions — Part 6: Welded cold drawn tubes for hydraulic and pneumatic power systems*
- EN 12516:2014, *(all parts), Industrial valves — Shell design strength*

ISO/DIS 23553-1:2020(E)

EN 12627:2017, *Industrial valves — Butt welding ends for steels valves*

EN 12760:2016, *Valves — Socket welding ends for steel valves*

prEN 10344:2006, *Malleable cast iron fittings with compression ends for steel pipes*

prEN 12514-4:2009, *Parts for supply systems for consuming units with liquid fuels — Part 4: Safety requirements and tests — Pipings and parts within pipelines*

ANSI/ASME B 1.1:2003, *Unified inch screw threads (UN and UNR thread form)*

ANSI/ASME B1.20.1:1983, *Pipe threads, general purpose (inch)*

ANSI/ASME B 16.1:1998, *Cast iron pipe flanges and flanged fittings, class 25, 125, 250 and 800*

ANSI/ASME B 16.5:2017, *Pipe Flanges and Flanged Fittings NPS 1/2 Through NPS 24 Metric/Inch Standard*

ANSI/SAE J 512:1997, *Automotive tube fittings*

ANSI/SAE J 514:2012, *Hydraulic tube fittings*

ASTM D 396:2019, *Standard Specification for Fuel Oils*

NEMA 250:2014, *Enclosures for Electrical Equipment (1 000 V Maximum)*

UL 50:2015, *Standard for Safety Enclosures for Electrical Equipment, Non-Environmental Considerations*

iTeh STANDARD PREVIEW
(standards.iteh.ai)

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://standards.iteh.ai/catalog/standards/sist/6fd582a5-f929-44cc-a310-910610101010>
- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1**breather hole**

orifice which allows atmospheric pressure to be maintained within a compartment of variable volume

3.2**closure member**

movable part of the valve which shuts off the oil flow

3.3**control**

device which directly or indirectly controls the oil flow and/or provides a safety function within a oil burner or oil-burning appliance

3.4**external leak-tightness**

leak-tightness of a oil-carrying compartment with respect to the atmosphere

3.5**internal leak-tightness**

leak-tightness of the closure member (in the closed position) sealing an oil-carrying compartment with respect to another compartment or to the outlet of the control

3.6**inlet pressure**

pressure at the inlet of the control

3.7**outlet pressure**

pressure at the outlet of the control

3.8**pressure difference**

difference between the inlet and outlet pressures

3.9**maximum working pressure**

highest inlet pressure declared by the manufacturer at which the control may be operated

3.10**minimum working pressure**

lowest inlet pressure declared by the manufacturer at which the control may be operated

3.11**flow rate**

volume flowing through the control divided by time

3.12**maximum ambient temperature**

highest temperature of the surrounding air declared by the manufacturer at which the control may be operated

3.13**minimum ambient temperature**

lowest temperature of the surrounding air declared by the manufacturer at which the control may be operated

3.14**mounting position**

position declared by the manufacturer for mounting the control

iTeh STANDARD PREVIEW
(standards.iteh.ai)

oSIST prEN ISO 23553-1:2020

<https://standards.iteh.ai/catalog/standards/sist/6fd582a5-f929-44cc-a310-4761b9e7eb/mounting-position-iso-23553-1-2020>

Note 1 to entry: Mounting positions are, for example, as follows:

- upright: single position on a horizontal axis with respect to the inlet connection, as specified by the manufacturer;
- horizontal: any position on a horizontal axis with respect to the inlet connection;
- vertical: any position on a vertical axis with respect to the inlet connection;
- limited horizontal: any position from upright to 90° (1,57 rad) from upright on a horizontal axis with respect to the inlet connection;
- multi poise: any position on a horizontal, vertical or intermediate axis with respect to the inlet connection

3.15**diameter nominal****DN****nominal size**

alphanumeric designation of size for components of a pipework system, which is used for reference purposes, comprising the letters DN followed by a dimensionless whole number which is indirectly related to the physical size, in millimetres, of the bore or outside diameter of the end connections

Note 1 to entry: The number following the letters DN does not represent a measurable value and should not be used for calculation purposes except where specified in the relevant standard.

Note 2 to entry: In those standards which use the DN designation system, any relationship between DN and component dimensions should be given, e.g. DN/OD or DN/ID.

Note 3 to entry: Adapted from ISO 6708:1995, definition 2.1.