



**SLOVENSKI STANDARD**  
**SIST EN 13126-13:2022**

**01-maj-2022**

**Nadomešča:**  
**SIST EN 13126-13:2012**

---

**Stavbno okovje - Okovje za okna in zastekljena vrata - Zahteve in preskusne metode - 13. del: Ravnotežje drsnih oken**

Building hardware - Hardware for windows and door height windows - Requirements and test methods - Part 13: Sash balances

Baubeschläge - Beschläge für Fenster und Fenstertüren - Anforderungen und Prüfverfahren - Teil 13: Ausgleichgewichte für Vertikal-Schiebefenster

Quincaillerie pour le bâtiment - Ferrures de fenêtres et portes-fenêtres - Exigences et méthodes d'essai - Partie 13: Contrepoids pour mécanismes à guillotine

[SIST EN 13126-13:2022](https://standards.iteh.ai/catalog/standards/sist/8ba44581-6719-481c-a0a2-1a5a4c0be34e/sist-en-13126-13-2022)

**Ta slovenski standard je istoveten z: EN 13126-13:2022**

---

**ICS:**

91.190            Stavbna oprema            Building accessories

**SIST EN 13126-13:2022**            **en,fr,de**

**iTeh STANDARD  
PREVIEW  
(standards.iteh.ai)**

[SIST EN 13126-13:2022](https://standards.iteh.ai/catalog/standards/sist/8ba44581-b7f9-48fc-a0a2-1a5a4c0be34e/sist-en-13126-13-2022)

[https://standards.iteh.ai/catalog/standards/sist/8ba44581-  
b7f9-48fc-a0a2-1a5a4c0be34e/sist-en-13126-13-2022](https://standards.iteh.ai/catalog/standards/sist/8ba44581-b7f9-48fc-a0a2-1a5a4c0be34e/sist-en-13126-13-2022)

EUROPEAN STANDARD

EN 13126-13

NORME EUROPÉENNE

EUROPÄISCHE NORM

January 2022

ICS 91.190

Supersedes EN 13126-13:2012

English Version

## Building hardware - Hardware for windows and door height windows - Requirements and test methods - Part 13: Sash balances

Quincaillerie pour le bâtiment - Ferrures de fenêtres et portes-fenêtres - Partie 13 : Exigences et méthodes d'essai - Partie 13 : Contrepoids pour mécanismes à guillotine

Baubeschläge - Beschläge für Fenster und Fenstertüren - Anforderungen und Prüfverfahren - Teil 13: Ausgleichgewichte für Vertikal Schiebefenster

This European Standard was approved by CEN on 19 December 2021.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

## Contents

	Page
European foreword.....	3
<b>1</b> <b>Scope</b> .....	<b>6</b>
<b>2</b> <b>Normative references</b> .....	<b>6</b>
<b>3</b> <b>Terms and definitions</b> .....	<b>6</b>
<b>4</b> <b>Classification</b> .....	<b>6</b>
4.1 <b>General</b> .....	6
4.2 <b>Durability (1 – first box)</b> .....	7
4.3 <b>Mass (2 – second box)</b> .....	7
4.4 <b>Corrosion resistance (3 – third box)</b> .....	7
4.5 <b>Test Sizes (4 – fourth box)</b> .....	7
4.6 <b>Rating (5 – fifth box)</b> .....	7
4.7 <b>Example of classification for sash balances</b> .....	7
<b>5</b> <b>Requirements</b> .....	<b>8</b>
5.1 <b>Dangerous substances</b> .....	8
5.2 <b>Integrated maximum opening stop</b> .....	8
5.3 <b>Free movement test</b> .....	8
5.4 <b>Durability</b> .....	8
5.5 <b>Rating – Resistance to manually applied load test</b> .....	8
5.6 <b>Corrosion resistance test</b> .....	9
<b>6</b> <b>Test equipment and preparation for the test</b> .....	<b>9</b>
6.1 <b>Sash balances installed in the test specimen</b> .....	9
6.2 <b>Test specimens from the sash balance manufacturer</b> .....	9
6.3 <b>Test rig</b> .....	9
6.4 <b>Hardware</b> .....	9
<b>7</b> <b>Test methods</b> .....	<b>10</b>
7.1 <b>Samples</b> .....	10
7.2 <b>Free movement test procedure</b> .....	10
7.3 <b>Durability</b> .....	10
7.3.1 <b>Durability test procedure</b> .....	10
7.3.2 <b>Durability test – acceptance criteria</b> .....	10
7.4 <b>Resistance to manually applied load test procedure</b> .....	11
7.5 <b>Corrosion resistance test</b> .....	11
<b>8</b> <b>Marking</b> .....	<b>11</b>
<b>Annex A (informative) Test procedures</b> .....	<b>12</b>
<b>Annex B (informative) Flowchart of test procedure</b> .....	<b>14</b>
<b>Bibliography</b> .....	<b>15</b>

## European foreword

This document (EN 13126-13:2022) has been prepared by Technical Committee CEN/TC 33 “Doors, windows, shutters, building hardware and curtain walling”, the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by July 2022, and conflicting national standards shall be withdrawn at the latest by July 2022.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

The performance tests incorporated in this document are considered to be reproducible and as such will provide a consistent and objective assessment of the performance of these products throughout CEN Member States.

This document supersedes EN 13126-13:2012.

With regard to EN 13126-13:2012, the following significant changes were made:

- EN 13126-13 is now independent from EN 13126-1; all necessary information is included without the need of any further information from EN 13126-1;
- several editorial changes in the wording for a better understanding;
- new terms and definitions added under 3.3 (sash width) and 3.4 (sash height);
- under 4.1 classification system changed completely:
  - former digit 1 (Category of use) changed into box 1 (Durability);
  - former digit 2 (Durability) changed into box 2 (Mass);
  - former digits 3, 4 and 5 deleted;
  - former digit 6 (Corrosion resistance) changed into box 3 (Corrosion resistance);
  - former digits 7 deleted;
  - former digit 8 (Application) changed into box 4 (Test sizes);
  - former digit 9 (Test sizes) changed into box 5 (Rating);
- under 4.2 new grades for the number of cycles defined; H1 (5 000), H2 (10 000) and H3 (20 000);
- under 4.7 new example of classification added in accordance with the new classification system; two alternative ways (table or alphanumeric) to show the classification defined;
- under 5.4 information regarding new grades for durability added;
- under 5.5 headline and grades in Table 3 modified;
- under 5.6 the wording changed and information regarding corrosion resistance added;

**EN 13126-13:2022 (E)**

- under Clause 6 headline modified;
- under 6.2 wording modified; new sentence added at the beginning;
- under 7.1 wording modified;
- under 7.3 several changes in the structure and the wording;
- under 7.3.1 headline modified;
- under 7.3.2 new headline added for a new subclause with the acceptance criteria;
- under 7.5 new subclause added with information regarding corrosion resistance;
- under Clause 8 new clause added regarding marking with information from the current version of EN 13126-1.

This document is one of a series of European Standards for building hardware products for windows and door height windows. This document is independent of EN 13126-1.

EN 13126 consists of the following parts:

- EN 13126-1, *Building hardware — Hardware for windows and door height windows — Requirements and test methods — Part 1: Requirements common to all types of hardware;*
- EN 13126-2, *Building hardware — Hardware for windows and door height windows — Requirements and test methods — Part 2: Window fastener handles;*
- EN 13126-3, *Building hardware — Hardware for windows and door-height windows — Requirements and test methods — Part 3: Handles, primarily for Tilt and Turn, Tilt-First and Turn-Only hardware;*
- EN 13126-4, *Building hardware — Requirements and test methods for windows and door height windows — Part 4: Espagnolettes;*
- EN 13126-5, *Building hardware — Hardware for windows and door height windows — Requirements and test methods — Part 5: Devices that restrict the opening of windows and door height windows;*
- EN 13126-6, *Building hardware — Hardware for windows and door height windows — Requirements and test methods — Part 6: Variable geometry stay hinges (with or without a friction stay);*
- EN 13126-7, *Building hardware — Requirements and test methods for windows and door height windows — Part 7: Finger catches;*
- EN 13126-8, *Building hardware — Hardware for windows and door height windows — Part 8: Requirements and test methods for tilt and turn, Tilt-First and Turn-Only hardware;*
- EN 13126-9, *Building hardware — Requirements and test methods for windows and door height windows — Part 9: Hardware for horizontal and vertical pivot windows;*
- EN 13126-10, *Building hardware — Requirements and test methods for windows and door height windows — Part 10: Arm-balancing systems;*
- EN 13126-11, *Building hardware — Requirements and test methods for windows and door height windows — Part 11: Top hung projecting reversible hardware;*

- EN 13126-12, *Building hardware — Requirements and test methods for windows and door height windows — Part 12: Side hung projecting reversible hardware*;
- EN 13126-13, *Building hardware — Hardware for windows and balcony door — Requirements and test methods — Part 13: Sash balances*;
- EN 13126-14, *Building hardware — Hardware for windows and door height windows — Requirements and test methods — Part 14: Sash fasteners*;
- EN 13126-15, *Building hardware — Hardware for windows and door height windows — Requirements and test methods — Part 15: Rollers for sliding and hardware for sliding folding windows*;
- EN 13126-16, *Building hardware — Hardware for windows and door height windows — Requirements and test methods — Part 16: Hardware for Lift and Slide windows*;
- EN 13126-17, *Building hardware — Hardware for windows and door height windows — Requirements and test methods — Part 17: Hardware for Tilt and Slide windows*;
- EN 13126-19, *Building hardware — Requirements and test methods for windows and door height windows — Part 19: Sliding Closing Devices*.

A full contribution to the preparation of this European Standard series has been made by the European manufacturers' organization "ARGE" and national standards bodies.

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

**EN 13126-13:2022 (E)****1 Scope**

This document specifies requirements and test methods for durability, strength, security and function of sash balances.

**2 Normative references**

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1670, *Building hardware — Corrosion resistance — Requirements and test methods*

EN 13126-5, *Building hardware — Hardware for windows and door height windows — Requirements and test methods — Part 5: Devices that restrict the opening of windows and door height windows*

**3 Terms and definitions**

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

**3.1 sash balance**  
device, generally fitted in a pair and used to counter-balance the mass of a vertically moving sash throughout its full travel

**3.2 manually applied force**  
externally applied vertical force required to cause movement of the sliding sash when the sash balances are mounted in the test specimen

**3.3 sash width**  
total horizontal outer dimension of the sash

**3.4 sash height**  
total vertical outer dimension of the sash

**4 Classification****4.1 General**

Sash balances shall be classified in accordance with the five-box classification system (see Table 1).

**Table 1 — Classification system of hardware**

box	1	2	3	4	5
characteristic	Durability	Mass	Corrosion resistance	Test sizes	Rating



#### 4.2 Durability (1 – first box)

The first box shall display the grade applied to the durability test in accordance with 5.4:

- grade H1: 5 000 cycles
- grade H2: 10 000 cycles
- grade H3: 20 000 cycles

#### 4.3 Mass (2 – second box)

The second box shall display the maximum tested sash-mass (weight) in accordance with Table 2.

The mass of the test sash shall be determined in accordance with the claims made by the hardware manufacturer.

#### 4.4 Corrosion resistance (3 – third box)

The third box shall display the grade regarding corrosion resistance in accordance with 5.6.

#### 4.5 Test Sizes (4 – fourth box)

The fourth box shall display the test sizes which were used for testing the sash balances in accordance with Table 2:

SW = sash width in mm / SH = sash height in mm

EXAMPLE 1 100 SW x 1 200 SH

Table 2 – Test sash size and mass

Test size A	Test size B	Test size C
SW X SH 800 × 1 100	SW X SH 1 100 × 1 200	SW X SH 1 500 × 1 000
20 kg	30 kg	35 kg

#### 4.6 Rating (5 – fifth box)

The fifth box shall display the grade representing the rating in accordance with Table 3 under 5.5.

#### 4.7 Example of classification for sash balances

a) Alternative 1: Table with boxes

Standard	Box				
	1	2	3	4	5
EN 13126-13:YYYY	H3	030	3	1 100/1 200	5

In accordance with Clause 8 the information regarding the classification by using a table with boxes shall always be shown together with the number of this document, EN 13126-13.

**EN 13126-13:2022 (E)**

b) Alternative 2: Alphanumerical

**EN 13126-13:YYYY H3-030-3-1 100/1 200**

This denotes sash balances, which have:

- box 1 durability grade H3 (20 000 cycles)
- box 2 mass 30 kg
- box 3 corrosion resistance grade 3
- box 4 test sizes SW = 1 100 mm, SH = 1 200 mm
- box 5 rating grade 5 (>30 %) in accordance with Table 3

**5 Requirements****5.1 Dangerous substances**

Materials in products should not release any dangerous substances in excess of the maximum levels specified in the European material standards and any national regulations.

**5.2 Integrated maximum opening stop**

Where sash balances are fitted with an integrated maximum opening stop, the opening stop shall also be tested in accordance with EN 13126-5.

**5.3 Free movement test**

The test specified in 7.2 shall be used to ensure the sash balances may support the mass of the sash.

Upon completion of the free movement test in accordance with 7.2, the maximum travel distance shall not exceed 25 mm.

**5.4 Durability**

The test specified in 7.3 shall be used to ensure the sash balances are capable of continued operation after cycling in accordance with one of the three grades specified following, and with regard given to normal maintenance.

The manufacturer specifies one of the following three grades for the number of cycles, with which the durability test shall be carried out:

- grade H1: 5 000 (+1 %) cycles
- grade H2: 10 000 (+1 %) cycles
- grade H3: 20 000 (+1 %) cycles

Upon completion of the durability test in accordance with 7.3, the sash balances shall continue to function normally.

**5.5 Rating – Resistance to manually applied load test**

The test specified in 7.4 shall be used to ensure the sash balances are graded in relation to the ease of sash movement.

Upon completion of the manually applied load test in accordance with 7.4, the manually applied force shall not exceed the value given in Table 3.