

DRAFT INTERNATIONAL STANDARD

ISO/DIS 3008-3

ISO/TC 92/SC 2

Secretariat: ANSI

Voting begins on:
2015-09-14

Voting terminates on:
2015-12-14

Fire Resistance Test — Door and Shutter Assemblies —

Part 3: Horizontally oriented

Essais de résistance au feu

ICS: 13.220.50; 91.060.50

iTeh STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/00e8947e-5a9b-436d-bc1d-7acd4e2ddd16/iso-3008-3-2016>

THIS DOCUMENT IS A DRAFT CIRCULATED FOR COMMENT AND APPROVAL. IT IS THEREFORE SUBJECT TO CHANGE AND MAY NOT BE REFERRED TO AS AN INTERNATIONAL STANDARD UNTIL PUBLISHED AS SUCH.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.



Reference number
ISO/DIS 3008-3:2015(E)

© ISO 2015

iTeh STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/00e8947e-5a9b-436d-bc1d-7acd4e2ddd16/iso-3008-3-2016>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2015, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

Page

Foreword	v
Introduction.....	vi
1 Scope	1
2 Normative References.....	1
3 Terms and definitions	1
4 Test equipment	2
5 Test conditions	2
6 Test specimen.....	3
6.1 Size of specimen	3
6.2 Design of specimen.....	3
6.3 Verification	3
7 Installation of test specimen	3
7.1 General	3
7.2 Supporting construction.....	4
7.3 Test construction	4
7.3.1 General	4
7.4 Gaps.....	4
8 Conditioning	4
8.1 Moisture content.....	4
8.2 Mechanical	5
9 Application of instrumentation	5
9.1 Temperature measurements	5
9.1.1 Furnace temperature measuring instrument.....	5
9.1.2 Unexposed face thermocouples	5
9.2 Maximum temperature	6
9.3 Pressure measurements	7
9.4 Heat flux measurement.....	7
9.4.1 General	7
9.4.2 Apparatus.....	7
9.4.3 Procedure	8
9.4.4 Measurement	8
9.5 Loading.....	8
9.6 Deflection	9
10 Test procedure.....	9
10.1.1 Gap measurements	9
10.1.2 Test Measurements	9
11 Performance criteria.....	10
11.1 Integrity.....	10
11.2 Insulation.....	10
11.3 Loadbearing capacity.....	10
12 Test report.....	10
13 Field of direct application of test results	11

13.1	General.....	11
13.2	Timber constructions	11
13.3	Steel constructions	12
13.4	Glazed constructions	12
13.5	Fixings/Hardware	12
Annex A	(normative) Conditioning requirements for supporting constructions	13
A.1	General.....	13
A.2	Requirements	13
Annex B	(informative) Estimation of radiant heat flux using measured surface temperature and Stefan-Boltzmann law	14
B.1	Introduction	14
B.2	Application	14
B.2.1	Specimen temperature measurement	15
B.2.2	Specimen emissivity	15
B.3	Example calculation	15

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Full standard:
<https://standards.iteh.ai/catalog/standards/sist/00e8947e-5a9b-436d-bc1d-7acd4e2ddd16/iso-3008-3-2016>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 3008-3 was prepared by Technical Committee ISO/TC 92, *Fire Standards*, Subcommittee SC 2, *Fire Containment*.

ISO 3008 consists of the following parts, under the general title *Fire Resistance Test — Door and Shutter Assemblies*:

- Part 1: *Door and Shutter Assemblies*
- Part 2: *Lift Landing Door Assemblies*
- Part 3: *Horizontally Oriented*

Introduction

This document contains specific requirements for fire resistance testing which are unique to the elements of building construction described as horizontally oriented doors and shutters. The requirements for these doors and shutters are intended to be applied in appropriate conjunction with the detailed and general requirements contained in the Standards ISO 834-1 and ISO 3008-1.

iTeh STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/00e8947e-5a9b-436d-bc1d-7acd4e2ddd16/iso-3008-3-2016>

Fire Resistance Test - — Door and Shutter Assemblies — Part 3: Horizontally Oriented

CAUTION – The attention of all persons concerned with managing and carrying out this fire-resistance test is drawn to the fact that fire testing may be hazardous and that there is a possibility that toxic and/or harmful smoke and gases may be evolved during the test. Mechanical and operational hazards may also arise during the construction of test elements or structures, their testing and disposal of test residues.

An assessment of all potential hazards and risks to health shall be made by the laboratory and safety precautions shall be identified and provided. Written safety instructions shall be issued. Appropriate training shall be given to relevant personnel. Laboratory personnel shall ensure that they follow written safety instructions at all times.

1 Scope

This part of ISO 3008 specifies the method of test for determining the fire resistance of horizontally oriented door and shutter assemblies which may be exposed to a fire from the underside. The procedure applies to all types of door and shutter assemblies installed in a horizontal orientation within floor or roof assemblies requiring fire-resistance ratings in buildings.

The procedure allows for the measurement of integrity and, if required, the measurement of radiation and thermal insulation. In addition, this method of test includes measurement of the load-carrying ability of the test specimens subjected to a standard fire-resistance test.

2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 834-1, *Fire-resistance tests – Elements of building construction – Part 1: General requirements*

ISO 834-5, *Fire-resistance tests – Elements of building construction – Part 5: Specific requirements for loadbearing horizontal separating elements*

ISO 3008-1, *Fire-resistance tests – Part 1 - Door and shutter assemblies*

ISO 3009, *Fire-resistance tests – Elements of building construction: Glazed Elements*

ISO 13943, *Fire safety – Vocabulary*

3 Terms and definitions

For the purposes of this document, the following terms and definitions given in ISO 834-1, ISO 3008-1, ISO 13943 and the following apply

3.1

Associated supporting construction

specific construction in which the door or shutter assembly is installed as intended for use in practice and which is used to close off the furnace and provide the levels of restraint and thermal heat transfer to be experienced in normal use

3.2

Door assembly

a combination of a door, a frame, hardware, closers, sealing materials and other accessories installed in a horizontal plane, which together provide a specific degree of fire-resistance to a through opening in a fire-resistance rated floor or roof.

3.3

Shutter assembly

a complete assembly consisting of rolling, folded or sliding panels or slats including guides, rollers, tracks, other accessories, operating mechanism and housings intended for installation in a horizontal plane.

3.4

Standard supporting construction

form of construction used to close off the furnace and to support the door assembly being evaluated and has a quantifiable influence on both the thermal heat transfer between the construction and the test specimen and provides known resistance to thermal distortion.

3.5

Door length

the direction of the door panel, door assembly or shutter which has the greatest dimension.

3.6

Door width

the direction of the door panel, door assembly or shutter which has the shortest dimension.

4 Test equipment

4.1 The test equipment shall be as specified in ISO 834-1. The furnace used shall be related to the orientation of the test specimen. For horizontal specimens, the floor furnace is applicable.

4.2 Measurement of heat flux from the unexposed surface of specimens shall be made as described in 9.4.

5 Test conditions

Test conditions require the application of the heating and pressure conditions of the standard test for a loadbearing horizontal separating element as defined in ISO 834-1.

6 Test specimen

6.1 Size of specimen

The test specimen and all its components shall be full size. When this is restricted by the size of the opening of the furnace (which is normally 3 m x 4 m), the door or shutter assembly shall be tested at the maximum size possible and the fire resistance of the full sized assembly shall be derived by an extended application analysis. However, the minimum dimensions of supporting construction shall not be less than that prescribed in 7.3.1.1.

6.2 Design of specimen

6.2.1 The design of the test specimen and the choice of supporting construction shall take into account the requirements of 7.3 if the widest field of direct application is to be achieved.

6.2.2 The test specimen shall be fully representative of the door or shutter assembly as intended for use in practice, including any appropriate surface finishes and fittings which are an essential part of the specimen and may influence its behaviour in a test construction.

6.2.3 If the test specimen is intended for use at an incline other than horizontal, the guidance for inclined specimens in ISO 3009 shall be followed.

6.3 Verification

6.3.1 The sponsor shall provide a specification to a level of detail sufficient to allow the laboratory to conduct a detailed examination of the specimen before the test and to agree on the accuracy of the information supplied. ISO 834-1 provides detailed guidance on verification of the test specimen.

6.3.2 When the method of construction precludes a detailed survey of the specimen without having to permanently damage it, or if it is considered that it will subsequently be impossible to evaluate construction details from a post-test examination, then one of two options shall be exercised by the laboratory, either:

- The laboratory shall oversee the manufacture of the door or shutter assembly(ies) that is to be the subject of the test; or
- The sponsor shall, at the discretion of the laboratory, be requested to supply an additional assembly or that part of the assembly which cannot be verified (e.g. a door leaf) in addition to the number required for the testing. The laboratory shall then choose freely which of these shall be subjected to the testing and which shall be used to verify the construction.

7 Installation of test specimen

7.1 General

7.1.1 The test specimen shall be installed in a manner as intended for use in practice, incorporating all hardware and other items, which may influence the performance of the specimen.

7.1.2 The test specimen shall be mounted in a supporting construction, the field of application of which covers the type (see 7.3.1.1) in which it is intended to be used. The design of the connection between the test specimen and the supporting construction, including any fixings and materials used to make the connection shall be as intended for use in practice and shall be regarded as part of the test specimen.

7.1.3 The whole area of the test specimen, together with at least the minimum dimensions of the supporting construction required by 7.3.1.1 shall be exposed to the heating conditions.

7.2 Supporting construction

The fire resistance of any supporting construction shall not be determined from a test in conjunction with a test specimen and shall be at least commensurate with that anticipated for the test specimen.

7.3 Test construction

7.3.1 General

7.3.1.1 Associated and supporting construction

The space between the specimen and the frame shall be filled with either

- associated construction or
- supporting construction.

There shall be a minimum zone of supporting construction of 200 mm wide exposed within the furnace, each side and over the top of the aperture into which the test specimen is to be fixed. The thickness of the supporting construction may be increased outside of the 200 mm zone. The test construction may incorporate more than one test specimen providing that there is minimum separation of 200 mm between each specimen and between the specimens and the edge of the furnace.

7.3.1.2 Associated construction

When the test specimen is always installed in a specific, normally proprietary, form of construction, that is permanently associated with its intended use in practice, then the specimen shall be installed in a sample of this supporting construction.

7.3.1.3 Supporting construction

7.3.1.3.1 Where the test specimen is not permanently associated with a specific form of construction, the area between the test specimen and the support frame shall be filled with a rigid or flexible standard supporting construction as specified in ISO 834-5.

7.3.1.3.2 The choice of standard supporting construction shall reflect the range of intended use for the door or shutter assembly. The rules governing the applicability of the chosen standard supporting construction to other end use situations are given in Clause 13.

7.4 Gaps

7.4.1 The adjustment of the door leaf, leaves or shutter and gaps shall be within the tolerances of the design values stipulated by the sponsor. These shall be representative of those used as intended for use in practice so that appropriate clearances exist, e.g. between the fixed and moveable components.

7.4.2 In order to generate the widest field of direct application, the gaps shall be set between the middle value and the maximum value within the range of gaps given by the sponsor.

8 Conditioning

8.1 Moisture content

The test specimen shall be conditioned in accordance with ISO 834-1. Requirements for conditioning of supporting constructions are given in Annex A.