

INTERNATIONAL STANDARD

NORME INTERNATIONALE

BASIC EMC PUBLICATION

PUBLICATION FONDAMENTALE EN CEM

**Electromagnetic compatibility (EMC) –
Part 4-14: Testing and measurement techniques – Voltage fluctuation immunity
test for equipment with input current not exceeding 16 A per phase**

**Compatibilité électromagnétique (CEM) –
Partie 4-14: Techniques d'essai et de mesure – Essai d'immunité aux
fluctuations de tension pour le matériel dont le courant d'entrée est inférieur ou
égal à 16 A par phase**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2009 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00



INTERNATIONAL STANDARD

NORME INTERNATIONALE

BASIC EMC PUBLICATION
PUBLICATION FONDAMENTALE EN CEM

**Electromagnetic compatibility (EMC) –
Part 4-14: Testing and measurement techniques – Voltage fluctuation immunity
test for equipment with input current not exceeding 16 A per phase**

**Compatibilité électromagnétique (CEM) –
Partie 4-14: Techniques d'essai et de mesure – Essai d'immunité aux
fluctuations de tension pour le matériel dont le courant d'entrée est inférieur ou
égal à 16 A par phase**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references.....	6
3 General.....	6
3.1 Effects of voltage fluctuations.....	6
3.2 Sources.....	7
4 Definitions.....	7
5 Test levels.....	7
6 Test equipment.....	8
6.1 Test generator.....	8
6.2 Characteristics and performance of the test generator.....	9
6.3 Verification of the test generator.....	9
7 Test set-up.....	9
8 Test procedure.....	9
8.1 Climatic conditions.....	10
8.2 Execution of the test.....	10
9 Evaluation of test results.....	10
10 Test report.....	11
Annex A (informative) Electromagnetic environment classes.....	16
Bibliography.....	17
Figure 1a – Test diagram.....	12
Figure 1b – Example of a voltage step for falling voltage.....	13
Figure 1c – Example of a voltage step for rising voltage.....	13
Figure 1d – Example of a complete voltage fluctuation.....	14
Figure 1 – Example of test sequences of voltage fluctuations.....	14
Figure 2 – Example of successive applications of voltage fluctuations.....	14
Figure 3 – Schematic (single-phase) of test instrumentation for voltage fluctuations, with power amplifier.....	15
Figure 4 – Example of test generator verification load.....	15
Table 1 – Test levels.....	8
Table 2 – Characteristics of the test generator.....	9

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTROMAGNETIC COMPATIBILITY (EMC) –

Part 4-14: Testing and measurement techniques – Voltage fluctuation immunity test for equipment with input current not exceeding 16 A per phase

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61000-4-14 has been prepared by subcommittee 77A: Low frequency phenomena, of IEC technical committee 77: Electromagnetic compatibility.

This standard forms part 4-14 of IEC 61000 series. It has the status of basic EMC publication in accordance with IEC Guide 107.

This consolidated version of IEC 61000-4-14 consists of the first edition (1999) [documents 77A/263/FDIS and 77A/268/RVD], its amendment 1 (2001) [documents 77B/291+293/FDIS and 77B/298+300/RVD] and its amendment 2 (2009) [documents 77A/669/CDV and 77A/685/RVC].

The technical content is therefore identical to the base edition and its amendments and has been prepared for user convenience.

It bears the edition number 1.2.

A vertical line in the margin shows where the base publication has been modified by amendments 1 and 2.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 61000-4-14:1999](#)

<https://standards.iteh.ai/catalog/standards/iec/713ce667-167a-446e-99e2-1bb3e7773274/iec-61000-4-14-1999>

INTRODUCTION

IEC 61000 is published in separate parts according to the following structure:

Part 1: General

General considerations (introduction, fundamental principles)
Definitions, terminology

Part 2: Environment

Description of the environment
Classification of the environment
Compatibility levels

Part 3: Limits

Emission limits
Immunity limits (insofar as these limits do not fall under the responsibility of the product committees)

Part 4: Testing and measurement techniques

Measurement techniques
Testing techniques

Part 5: Installation and mitigation guidelines

Installation guidelines
Mitigation methods and devices

Part 6: Generic standards

Part 9: Miscellaneous

Each part is further subdivided into several parts, published either as International Standards, or as technical reports, some of which have already been published as sections. Others will be published with the part number followed by a dash and a second number identifying the subdivision (example 61000-6-1).

ELECTROMAGNETIC COMPATIBILITY (EMC) –

Part 4-14: Testing and measurement techniques – Voltage fluctuation immunity test for equipment with input current not exceeding 16 A per phase

1 Scope

This part of IEC 61000 is a basic electromagnetic compatibility (EMC) publication. It considers immunity tests for electrical and/or electronic equipment in their electromagnetic environment. Only conducted phenomena are considered, including immunity tests for equipment connected to public and industrial power supply networks.

This part aims to establish a reference for evaluating the immunity of electric and electronic equipment when subjected to positive and negative low amplitude voltage fluctuations.

The voltage fluctuations considered by this standard do not include flicker, which is a physiological phenomenon due to lighting luminance fluctuations.

This standard applies to electrical and/or electronic equipment that have a rated input current up to 16 A per phase. It does not apply to electrical and/or electronic equipment connected to d.c. or a.c. 400 Hz distribution networks. Tests concerning these networks will be covered by other IEC standards.

The immunity test levels required for a specific electromagnetic environment, together with the performance criteria, are indicated in the product, product family or generic standards as applicable. However, most product groups do not have a history of being susceptible to voltage fluctuations. Consequently, testing for these phenomena is often not required.

<https://standards.iteh.ai/catalog/standards/iec/713ce667-167a-446e-99e2-1bb3e7773274/iec-61000-4-14-1999>

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050(161), *International Electrotechnical Vocabulary (IEV) – Chapter 161: Electromagnetic compatibility*

IEC 60068-1, *Environmental testing – Part 1: General and guidance*

IEC 61000-2-4, *Electromagnetic compatibility (EMC) – Part 2: Environment – Section 4: Compatibility levels in industrial plants for low-frequency conducted disturbances*

3 General

3.1 Effects of voltage fluctuations

Electrical and electronic equipment may be affected by voltage fluctuations. Examples of these effects include the following:

- degradation of performances in equipment using storage devices (e.g. capacitors);
- loss of function in control systems;

- instability of internal voltages and currents in equipment;
- increased ripple.

3.2 Sources

There is a significant number of domestic appliances in the low-voltage network. However, fluctuations caused by these appliances are not generally significant.

Fluctuations are mainly produced by

- a) continuously but randomly varying large loads such as:
 - 1) resistance welding machines;
 - 2) rolling mills;
 - 3) large motors with varying loads;
 - 4) arc furnaces;
 - 5) arc welding plant;
- b) single on/off switching of loads (e.g. motors);
- c) step voltage changes (due to tap voltage regulators of transformers).

These industrially produced fluctuations can affect a large number of consumers. Such equipment operates continuously or infrequently. The public supply network impedance has wide variations, consequently the transmission of the disturbances will be different for different networks.

4 Definitions

For the purpose of this part of IEC 61000, the following definitions and terms apply. They are applicable only to the field of voltage fluctuations; not all of them are included in IEC 60050(161).

4.1

immunity

ability of a device, equipment or system to perform without degradation of performance in the presence of an electromagnetic disturbance [IEV 161-01-20]

4.2

voltage fluctuations

series of voltage changes or a cyclic variation of the voltage envelope [IEV 161-08-05]

5 Test levels

This test may apply to all equipment intended for connection to public networks, industrial networks and electricity plants that are likely to be sensitive to this type of disturbance.

It can be assumed that step voltage changes are the most disturbing type of voltage fluctuations.

The equipment under test (EUT) is initially operated using a steady supply voltage and is then subjected to repetitive step voltage changes according to figure 1a.

The initial voltage is set to

$$U_n, U_n - 10 \% U_n, U_n + 10 \% U_n$$

NOTE U_n is the nominal voltage.

The magnitude of the voltage steps is chosen as follows:

Class 1: no test required.

Class 2: $\Delta U = 8 \% U_n$ for equipment intended for connection to public networks or other lightly disturbed networks. This test level is specified for class 2.

Class 3: $\Delta U = 12 \% U_n$ for equipment connected to heavily disturbed networks (i.e. industrial networks). This test level is specified for class 3.

Classes 1, 2 and 3 are defined in annex A.

Table 1 gives the test levels for the different initial voltages:

$$U_n, U_n - 10 \% U_n, U_n + 10 \% U_n$$

Table 1 – Test levels

Class	U_n	$U_n - 10 \% U_n$	$U_n + 10 \% U_n$
1	No test required		
2	$\Delta U = \pm 8 \% U_n$	$\Delta U = +8 \% U_n$	$\Delta U = -8 \% U_n$
3	$\Delta U = \pm 12 \% U_n$	$\Delta U = +12 \% U_n$	$\Delta U = -12 \% U_n$
x	x	x	x
NOTE The levels for class "x" are open.			

The repetition period T and the duration t of the voltage fluctuations are specified as $T = 5$ s and $t = 2$ s (see Figure 1d).

The changes from the initial voltage to the test voltage, or from the test voltage back to the initial voltage are achieved through five successive voltage steps in five consecutive cycles of the mains supply, see Figure 1d. Each voltage step is of $\Delta U/5$ and occurs over $\pi/2$ radians of the period of the nominal frequency, f_n , (e.g. 5 ms for 50 Hz) see Figure 1b and Figure 1c.

For falling voltage changes, the voltage step begins at phase angle $\varphi = 270^\circ$ and finishes at $\varphi = 360^\circ$, see Figure 1b.

For rising voltage changes, the voltage step begins at phase angle $\varphi = 180^\circ$ and finishes at $\varphi = 270^\circ$, see Figure 1c.

x is an open test level. This value may be defined by the product standard in order to cover situations other than the normal operating conditions of the network.

All of the levels can be proposed by the product committee, but for equipment for use in public supply systems, the values shall not be lower than those specified for class 2.

NOTE The upper and lower voltage operation limits defined by the product manufacturer should not be exceeded.

6 Test equipment

6.1 Test generator

The generator used for the test shall have provisions to prevent the emission of heavy disturbances which, if injected into the power supply network, may influence the test results.

6.2 Characteristics and performance of the test generator

Table 2 – Characteristics of the test generator

Output voltage capability	$U_n \pm 15 \%$
Voltage accuracy	$\pm 1 \%$
Zero crossing accuracy	250 μ s at zero voltage crossover
Output current capability	The generator shall be able to supply enough current according to the type of EUT in the test voltage range.
Overshoot/undershoot of the actual voltage	Less than 5 % of the change in voltage
Voltage rise (and fall) time during switching	Under 1 ms
Maximum interphase error (three-phase power supply)	2,5°
Frequency accuracy	2,5 % of f_n (50 Hz or 60 Hz)
NOTE The generator with a power amplifier specified in IEC 61000-4-11 is suitable for this test. An over-voltage capability of $U_n + 15 \%$ is necessary.	

6.3 Verification of the test generator

Test generators with different output power capabilities may be used.

The test generator shall be verified that it complies with the characteristics and specifications listed in Table 2.

Performance of the test generator shall be verified with a resistive load drawing an r.m.s. current of no more than the output capability of the generator. For example, a 230 V/16 A generator shall be verified with a 14,3 Ω load.

In addition, the generator's output current capability shall be verified as being able to provide a crest factor of at least 3 when U_n is applied to a single phase load drawing an r.m.s. current of no more than the output capability of the generator. Each output phase of the generator shall be verified in turn. An example of a suitable 230 V/16 A verification load is given in Figure 4.

7 Test set-up

Figure 3 shows the test configuration for mains supply simulation.

Waveform generators and power amplifiers may be used.

Tests on three-phase EUT are carried out using three synchronised generators.

8 Test procedure

Before starting the test of a given equipment, a test plan shall be prepared.

It is recommended that the test plan include the following:

- description of the EUT;
- information on possible connections (plugs, terminals, etc.) and corresponding cables and peripherals;
- input power port of the EUT;
- representative operational modes of the EUT for the test;