



Designation: F571 – 87(Reapproved 2008)

Standard Practice for Installation of Exit Devices in Security Areas¹

This standard is issued under the fixed designation F571; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice provides information for the installation of exit devices used in areas of security to achieve the greatest security possible without violating the requirements and spirit of NFPA 101.

1.2 Security of a high level is not always possible with these products but the use of certain types and functions of exit devices will afford a much higher degree of security than the use of other types and functions.

1.3 The values as stated in inch-pound units are to be regarded as the standard. The values given in parentheses are for information only.

2. Referenced Documents

2.1 *ASTM Standards*:²

F476 Test Methods for Security of Swinging Door Assemblies (Withdrawn 2011)³

2.2 *Builders Hardware Manufacturers Association Standards*:

BHMA A 156.3 Exit Devices⁴

BHMA A 156.5 Auxiliary Locks and Associated Products⁴

2.3 *National Fire Protection Agency Standards*:

NFPA 80 Fire Doors and Windows⁵

NFPA 101 Code for Safety to Life from Fire in Buildings and Structures⁵

2.4 *Underwriters Laboratories Standards*:

UL 305 Panic Hardware⁶

UL 1034 Burglary Resistant Electric Locking Mechanisms⁶

3. Terminology

3.1 *Definitions of Terms Specific to This Standard*:

3.1.1 *astragal*—a vertical molding attached to the meeting edge of a leaf or both leaves of a pair of doors.

3.1.2 *coordinator*—a device that holds the active door of a pair open until the inactive door has preceded it in the closing cycle.

3.1.3 *exit device*—a locking device always operable from the inside (egress side) by pushing on an activating mechanism usually called a push pad or cross bar.

3.1.4 *mortise device*—a lock mechanism that is installed into a cavity provided in the edge of a door.

3.1.5 *mullion*—a vertical member in an opening for two doors permitting each door to be operated independently from the other.

3.1.6 *rim device*—a single lock mechanism applied to the surface of a door.

3.1.7 *vertical rod device*—a top and bottom lock mechanism connected by rods, either surface or concealed, to the activating mechanism.

4. Significance and Use

4.1 This practice is not meant to include products other than exit devices except to the extent that such products directly relate to the use of exit devices. When other products are described, the security attributes of the other products are described generally in the documents referenced in Section 2.

5. General

5.1 NFPA 101 and many building codes require exit devices in certain locations and should be consulted.

5.2 UL 305 and BHMA A156.3 have specific requirements for the performance of exit devices and should be consulted.

5.3 Exit devices for fire doors require a label designating them as “fire exit hardware.” This means they have been investigated for both fire resistance and panic. Exit devices used on non-fire doors require a listing for panic. These labels

¹ This practice is under the jurisdiction of ASTM Committee F12 on Security Systems and Equipment and is the direct responsibility of Subcommittee F12.50 on Locking Devices.

Current edition approved Oct. 1, 2008. Published February 2009. Originally approved in 1979. Last previous edition approved in 2001 as F571 – 87 (2001). DOI: 10.1520/F0571-87R08.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ The last approved version of this historical standard is referenced on www.astm.org.

⁴ Available from Builders Hardware Manufacturers Association, 60 E. 42nd St., Rm 1807, New York, NY, 10017.

⁵ Available from the Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

⁶ Available from Underwriters Laboratory, Inc., 333 Pfingsten Road, Northbrook, IL 60062.