

---

**Visokonapetostne stikalne in krmilne naprave - 105. del: Kombinacije stikal za izmenični tok z varovalkami za naznačene napetosti nad 1 kV do vključno 52 kV (IEC 62271-105:2021)**

High-voltage switchgear and controlgear - Part 105: Alternating current switch-fuse combinations for rated voltages above 1 kV up to and including 52 kV (IEC 62271-105:2021)

Hochspannungs-Schaltgeräte und -Schaltanlagen - Teil 105: Wechselstrom-Lastschalter-Sicherungs-Kombinationen für Bemessungsspannungen über 1 kV bis einschließlich 52 kV (IEC 62271-105:2021)

Appareillage à haute tension - Partie 105: Combinés interrupteurs-fusibles pour courant alternatif de tensions assignées supérieures à 1 kV et jusqu'à 52 kV inclus (IEC 62271-105:2021)

<https://standards.ieh.ai/catalog/standards/sist/c028c9a1-9d2f-45d9-94fb-f28d206180ef/sist-en-iec-62271-105-2024>

**Ta slovenski standard je istoveten z: EN IEC 62271-105:2023**

**ICS:**

29.130.10	Visokonapetostne stikalne in krmilne naprave	High voltage switchgear and controlgear
-----------	--	---

**SIST EN IEC 62271-105:2024** en



EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

**EN IEC 62271-105**

November 2023

ICS 29.130.10

Supersedes EN 62271-105:2012

English Version

**High-voltage switchgear and controlgear - Part 105: Alternating  
current switch-fuse combinations for rated voltages above 1 kV  
up to and including 52 kV  
(IEC 62271-105:2021)**

Appareillage à haute tension - Partie 105: Combinés  
interrupteurs-fusibles pour courant alternatif de tensions  
assignées supérieures à 1 kV et jusqu'à 52 kV inclus  
(IEC 62271-105:2021)

Hochspannungs-Schaltgeräte und -Schaltanlagen -  
Teil 105: Wechselstrom-Lastschalter-Sicherungs-  
Kombinationen für Bemessungsspannungen über 1 kV bis  
einschließlich 52 kV  
(IEC 62271-105:2021)

This European Standard was approved by CENELEC on 2021-07-20. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

<https://standards.iteh.ai/catalog/standards/sist/c028c9a1-9d2f-45d9-94fb-f28d206180ef/sist-en-iec-62271-105-2024>



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

## EN IEC 62271-105:2023 (E)

### European foreword

The text of document 17A/1300/FDIS, future edition 3 of IEC 62271-105, prepared by SC 17A "Switching devices" of IEC/TC 17 "High-voltage switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62271-105:2023.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2024-05-10 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2026-11-10 document have to be withdrawn

This document supersedes EN 62271-105:2012 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

### Endorsement notice

The text of the International Standard IEC 62271-105:2021 was approved by CENELEC as a European Standard without any modification. In the official version, for Bibliography, the following note has to be added for the standard indicated:

IEC 62271-202      NOTE      Harmonized as EN 62271-202

[SIST EN IEC 62271-105:2024](https://standards.iteh.ai/catalog/standards/sist/c028c9a1-9d2f-45d9-94fb-f28d206180ef/sist-en-iec-62271-105-2024)

<https://standards.iteh.ai/catalog/standards/sist/c028c9a1-9d2f-45d9-94fb-f28d206180ef/sist-en-iec-62271-105-2024>

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: [www.cencenelec.eu](http://www.cencenelec.eu).

*Clause 2 of EN 62271-1:2017 applies with the following additions:*

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-441	-	International Electrotechnical Vocabulary. Switchgear, controlgear and fuses	-	-
IEC 60282-1	2020	High-voltage fuses - Part 1: Current-limiting fuses	EN IEC 60282-1	2020
IEC 62271-1	2017	High-voltage switchgear and controlgear - Part 1: Common specifications for alternating current switchgear and controlgear	EN 62271-1	2017
IEC 62271-100	2021	High-voltage switchgear and controlgear - Part 100: Alternating-current circuit-breakers	EN IEC 62271-100	2021
IEC 62271-102	2018	High-voltage switchgear and controlgear - Part 102: Alternating current disconnectors and earthing switches	EN IEC 62271-102	2018
IEC 62271-103	2021	High-voltage switchgear and controlgear - Part 103: Alternating current switches for rated voltages above 1 kV up to and including 52 kV	EN IEC 62271-103	2023

**EN IEC 62271-105:2023 (E)****Annex ZB**  
(informative)**A-deviations**

**A-deviation:** National deviation due to regulations, the alteration of which is for the time being outside the competence of the CEN and/or CENELEC member.

This European Standard does not fall under any Directive/Regulation of the EU.

In the relevant CEN and/or CENELEC countries, these A-deviations are valid instead of the respective provisions of the European Standard until the national situation causing the A-deviation has changed

<u>Clause</u>	<u>Deviation</u>
General	<p><b>Italy</b></p> <p>CAPITOLO VSR 8.B D.M. 1 DICEMBRE 1980 e succ. Modifiche</p> <p>Disciplina dei contenitori a pressione di gas con membrane miste di materiale isolante e di materiale metallico, contenenti parti attive di apparecchiature elettriche.</p> <p>Gas filled compartments having a design pressure exceeding 0,5 bar (gauge) or a volume exceeding 2 m<sup>3</sup> shall be designed according to the Italian pressure vessel code for electrical switchgear.</p>

iTeh Standards  
(<https://standards.itih.ai>)  
Document Preview

[SIST EN IEC 62271-105:2024](https://standards.itih.ai/catalog/standards/sist/c028c9a1-9d2f-45d9-94fb-f28d206180ef/sist-en-iec-62271-105-2024)

<https://standards.itih.ai/catalog/standards/sist/c028c9a1-9d2f-45d9-94fb-f28d206180ef/sist-en-iec-62271-105-2024>



IEC 62271-105

Edition 3.0 2021-06

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

**High-voltage switchgear and controlgear –  
Part 105: Alternating current switch-fuse combinations for rated voltages above  
1 kV up to and including 52 kV**

**Appareillage à haute tension –  
Partie 105: Combinés interrupteurs-fusibles pour courant alternatif de tensions  
assignées supérieures à 1 kV et jusqu'à 52 kV inclus**

[SIST EN IEC 62271-105:2024](https://standards.iteh.ai/catalog/standards/sist/c028c9a1-9d2f-45d9-94fb-f28d206180ef/sist-en-iec-62271-105-2024)

<https://standards.iteh.ai/catalog/standards/sist/c028c9a1-9d2f-45d9-94fb-f28d206180ef/sist-en-iec-62271-105-2024>

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

ICS 29.130.10

ISBN 978-2-8322-9864-0

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD .....	5
1 Scope .....	7
2 Normative references .....	8
3 Terms and definitions .....	8
3.1 General terms and definitions .....	8
3.2 Assemblies of switchgear and controlgear .....	8
3.3 Parts of assemblies .....	8
3.4 Switching devices .....	8
3.5 Parts of switchgear and controlgear .....	9
3.6 Operational characteristics of switchgear and controlgear .....	10
3.7 Characteristic quantities .....	10
3.101 Fuses .....	13
4 Normal and special service conditions .....	14
5 Ratings .....	14
5.1 General .....	14
5.2 Rated voltage ( $U_r$ ) .....	15
5.3 Rated insulation level ( $U_d$ , $U_p$ , $U_s$ ) .....	15
5.4 Rated frequency ( $f_r$ ) .....	15
5.5 Rated continuous current ( $I_r$ ) .....	15
5.6 Rated short-time withstand current ( $I_k$ ) .....	15
5.7 Rated peak withstand current ( $I_p$ ) .....	15
5.8 Rated duration of short-circuit ( $t_k$ ) .....	15
5.9 Rated supply voltage of auxiliary and control circuits ( $U_a$ ) .....	15
5.10 Rated supply frequency of auxiliary and control circuits .....	15
5.11 Rated pressure of compressed gas supply for controlled pressure systems .....	15
5.101 Rated short-circuit breaking current .....	16
5.102 Rated short-circuit making current .....	16
5.103 Rated transfer current (striker operation) ( $I_{rtransfer}$ ) .....	16
5.104 Rated take-over current for release-operated combinations ( $I_{rto}$ ) .....	16
6 Design and construction .....	16
6.1 Requirements for liquids in switch-fuse combinations .....	16
6.2 Requirements for gases in switch-fuse combinations .....	16
6.3 Earthing of switch-fuse combinations .....	16
6.4 Auxiliary and control equipment and circuits .....	17
6.5 Dependent power operation .....	17
6.6 Stored energy operation .....	17
6.7 Independent unlatched operation (independent manual or power operation) .....	17
6.8 Manually operated actuators .....	17
6.9 Operation of releases .....	17
6.10 Pressure/level indication .....	17
6.11 Nameplates .....	17
6.12 Locking devices .....	19
6.13 Position indication .....	19
6.14 Degrees of protection provided by enclosures .....	19



6.15	Creepage distances for outdoor insulators .....	19
6.16	Gas and vacuum tightness .....	19
6.17	Tightness for liquid systems .....	19
6.18	Fire hazard (flammability) .....	19
6.19	Electromagnetic compatibility (EMC) .....	19
6.20	X-ray emission .....	19
6.21	Corrosion .....	19
6.22	Filling levels for insulation, switching and/or operation .....	19
6.101	Linkages between the fuse striker(s) and the switch release .....	19
6.102	Low over-current conditions (long fuse-pre-arcing time conditions) .....	19
7	Type tests .....	20
7.1	General .....	20
7.1.1	Basics .....	20
7.1.2	Information for identification of test objects .....	20
7.1.3	Information to be included in type-test reports .....	20
7.2	Dielectric tests .....	21
7.3	Radio interference voltage (RIV) test .....	21
7.4	Resistance measurement .....	21
7.5	Continuous current tests .....	21
7.6	Short-time withstand current and peak withstand current tests .....	21
7.7	Verification of the protection .....	21
7.8	Tightness tests .....	21
7.9	Electromagnetic compatibility tests (EMC) .....	21
7.10	Additional tests on auxiliary and control circuits .....	21
7.11	X-radiation test for vacuum interrupters .....	21
7.101	Making and breaking tests .....	22
7.101.1	General .....	22
7.101.2	Conditions for performing the tests .....	22
7.101.3	Test-duty procedures .....	28
7.101.4	Behaviour of the combination during tests .....	33
7.101.5	Condition of the apparatus after testing .....	34
7.102	Mechanical operation tests .....	35
7.103	Mechanical shock tests on fuses .....	35
7.104	Thermal test with long pre-arcing time of fuse .....	35
7.105	Extension of validity of type tests .....	36
7.105.1	Dielectric .....	36
7.105.2	Continuous current tests .....	36
7.105.3	Making and breaking .....	36
8	Routine tests .....	36
8.101	Mechanical operating tests .....	37
9	Guide to the selection of switch-fuse combinations (informative) .....	37
9.101	Guide to the selection of switch-fuse combination for transformer protection .....	37
9.101.1	General .....	37
9.101.2	Rated short-circuit breaking current .....	38
9.101.3	Primary fault condition caused by a solid short-circuit on the transformer secondary terminals .....	38
9.102	Coordination of switch and fuses for extension of the reference list of fuses .....	39
9.102.1	General .....	39
9.102.2	Rated continuous current .....	39

9.102.3	Low over-current performance .....	39
9.102.4	Transfer current .....	39
9.102.5	Take-over current .....	39
9.102.6	Extension of the validity of type tests .....	40
10	Information to be given with enquiries, tenders and orders (informative) .....	40
10.1	General .....	40
10.2	Information with enquiries and orders .....	40
10.3	Information with tenders .....	40
11	Transport, storage, installation, operating instructions and maintenance .....	40
12	Safety .....	41
13	Influence of the product on the environment .....	41
Annex A (informative)	Example of the coordination of fuses, switch and transformer .....	42
Annex B (normative)	Procedures for determining transfer current .....	45
B.1	Background .....	45
B.2	Mathematical determination of $\Delta T$ .....	45
B.3	Simplified method for determination of transfer current .....	48
Annex C (normative)	Tolerances on test quantities for type tests .....	50
Bibliography	.....	52
Figure 1	– Arrangement of test circuits for test duties $TD_{I_{SC}}$ and $TD_{I_{Wmax}}$ .....	23
Figure 2	– Arrangement of test circuits for test-duty $TD_{I_{transfer}}$ .....	24
Figure 3	– Arrangement of test circuits for test-duty $TD_{I_{to}}$ .....	24
Figure 4	– Determination of power-frequency recovery voltage .....	26
Figure 5	– Representation of a specified TRV by a two-parameter reference line and a delay line .....	27
Figure 6	– Example of a two-parameter reference line for a TRV .....	28
Figure 7	– Characteristics for determining take-over current .....	32
Figure 8	– Transfer current in relation to the primary fault current $I_{SC}$ due to a solid short circuit in the transformer secondary terminal .....	38
Figure A.1	– Characteristics relating to the protection of an 11 kV, 400 kVA transformer .....	43
Figure A.2	– Discrimination between HV and LV fuses .....	44
Figure B.1	– Practical determination of the transfer current .....	46
Figure B.2	– Determination of the transfer current with the iterative method .....	48
Table 1	– Nameplate information .....	18
Table 2	– Summary of the conditions for combining tests and alternative procedures .....	23
Table 3	– Values of prospective TRV for test-duty $TD_{I_{transfer}}$ based on practice in Europe .....	30
Table 4	– Values of prospective TRV for test-duty $TD_{I_{transfer}}$ based on practice in the United States of America .....	31
Table 5	– Summary of test parameters for test duties .....	33
Table C.1	– Tolerances on test quantities for type tests .....	50

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –****Part 105: Alternating current switch-fuse combinations  
for rated voltages above 1 kV up to and including 52 kV**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62271-105 has been prepared by subcommittee 17A: Switching devices, of IEC technical committee 17: High-voltage switchgear and controlgear. It is an International Standard.

This third edition cancels and replaces the second edition published in 2012. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) the document has been updated to be in alignment with the second edition of IEC 62271-1:2017;
- b) rated TRV has been removed (TRV is only a test parameter), as in the latest revision of IEC 62271-100;

- c) differentiation has been introduced between requirements expressed for fulfilling the function expected from a switch-fuse combination, from requirements only relevant when the function is performed by a stand-alone device. The goal is to avoid duplication or conflicts of requirements with a standard dealing with assemblies, when the function is implemented within such an assembly.

The text of this International Standard is based the following documents:

FDIS	Report on voting
17A/1300/FDIS	17A/1306/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/standardsdev/publications](http://www.iec.ch/standardsdev/publications).

This document is to be read in conjunction with IEC 62271-1:2017, to which it refers and which is applicable unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 62271-1:2017. Amendments to these clauses and subclauses are given under the same numbering, whilst additional subclauses are numbered from 101.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- [reconfirmed](https://www.iec.ch/standards/sist/c028c9a1-9d2f-45d9-94fb-f28d206180ef/sist-en-iec-62271-105-2024),
- withdrawn,
- replaced by a revised edition, or
- amended.

## HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

### Part 105: Alternating current switch-fuse combinations for rated voltages above 1 kV up to and including 52 kV

#### 1 Scope

This part of IEC 62271 applies to three-pole units for public and industrial distribution systems which are functional assemblies of switches composed of switches or switch-disconnectors and current-limiting fuses designed so as to be capable of

- breaking, at the rated voltage, any current up to and including the rated short-circuit breaking current;
- making, at the rated voltage, circuits to which the rated short-circuit breaking current applies.

It does not apply to combinations of fuses with circuit-breakers, contactors or circuit switchers, nor for combinations for motor-circuits nor to combinations incorporating single capacitor bank switches.

This document applies to combinations designed with rated voltages above 1 kV up to and including 52 kV for use on three-phase alternating current systems of either 50 Hz or 60 Hz.

In this document, the word "combination" is used for a combination in which the components constitute a functional assembly. Each association of a given type of switch and a given type of fuse defines one type of switch-fuse combination. Different types of fuses can be combined with one type of switch, which give several combinations with different characteristics, in particular concerning the rated continuous currents.

A switch-fuse combination is therefore defined by its type designation and a list of selected fuses defined by the manufacturer, the so-called "reference list of fuses". Compliance with this document of a given combination means that every combination using one of the selected fuses is proven to be in compliance with this document.

The fuses are incorporated in order to extend the short-circuit breaking rating of the combination beyond that of the switch alone. They are fitted with strikers in order both to open automatically all three poles of the switch on the operation of a fuse and to achieve a correct operation at values of fault current above the minimum melting current but below the minimum breaking current of the fuses. In addition to the fuse strikers, the combination can be fitted with either an over-current release or a shunt release.

NOTE In this document the term "fuse" is used to designate either the fuse or the fuse-link where the general meaning of the text does not result in ambiguity.

Fuses are in accordance with IEC 60282-1:2020.

Devices that require dependent manual operation are not covered by this document.

Switches, including their specific mechanism, are in accordance with IEC 62271-103 except for the short-time current and short-circuit making requirements where the current-limiting effects of the fuses are taken into account.

Earthing switches forming an integral part of a combination are covered by IEC 62271-102.

In addition, switches which include other functions (not covered by IEC 62271-103) are covered by their relevant standards (e.g. IEC 62271-102 for disconnectors and earthing switches).

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

Clause 2 of IEC 62271-1:2017 applies with the following additions:

IEC 60050-441, *International Electrotechnical Vocabulary (IEV) – Part 441: Switchgear, controlgear and fuses* (available at <http://www.electropedia.org>)

IEC 60282-1:2020, *High-voltage fuses – Part 1: Current-limiting fuses*

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-100:2021, *High-voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers*

IEC 62271-102:2018, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

IEC 62271-103:2021, *High-voltage switchgear and controlgear – Part 103: Switches for rated voltages above 1 kV up to and including 52 kV*

## 3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-441 and the following apply:

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

NOTE Some of the terms given in IEC 60050-441 are listed hereunder.

### 3.1 General terms and definitions

Subclause 3.1 of IEC 62271-1:2017 applies.

### 3.2 Assemblies of switchgear and controlgear

Subclause 3.2 of IEC 62271-1:2017 applies.

### 3.3 Parts of assemblies

Subclause 3.3 of IEC 62271-1:2017 applies.

### 3.4 Switching devices

Subclause 3.4 of IEC 62271-1:2017 applies, with the following additions: