



**Environmental Engineering (EE);
Monitoring and Control Interface for Infrastructure Equipment
(Power, Cooling and Building Environment Systems used in
Telecommunication Networks)
Part 1: Generic Interface**

[ETSI ES 202 336-1 V1.3.1 \(2025-04\)](https://standards.iteh.ai/catalog/standards/etsi/948bff55-1979-4e4e-a9aa-ac21f99ff08b/etsi-es-202-336-1-v1-3-1-2025-04)

<https://standards.iteh.ai/catalog/standards/etsi/948bff55-1979-4e4e-a9aa-ac21f99ff08b/etsi-es-202-336-1-v1-3-1-2025-04>

Reference

RES/EE-02105

Keywords

control, interface, management, power, system

ETSI

650 Route des Lucioles
F-06921 Sophia Antipolis Cedex - FRANCE

Tel.: +33 4 92 94 42 00 Fax: +33 4 93 65 47 16

Siret N° 348 623 562 00017 - APE 7112B
Association à but non lucratif enregistrée à la
Sous-Préfecture de Grasse (06) N° w061004871

Important notice

The present document can be downloaded from the
[ETSI Search & Browse Standards](#) application.

The present document may be made available in electronic versions and/or in print. The content of any electronic and/or print versions of the present document shall not be modified without the prior written authorization of ETSI. In case of any existing or perceived difference in contents between such versions and/or in print, the prevailing version of an ETSI deliverable is the one made publicly available in PDF format on [ETSI deliver](#) repository.

Users should be aware that the present document may be revised or have its status changed, this information is available in the [Milestones listing](#).

If you find errors in the present document, please send your comments to the relevant service listed under [Committee Support Staff](#).

If you find a security vulnerability in the present document, please report it through our [Coordinated Vulnerability Disclosure \(CVD\)](#) program.

Notice of disclaimer & limitation of liability

The information provided in the present deliverable is directed solely to professionals who have the appropriate degree of experience to understand and interpret its content in accordance with generally accepted engineering or other professional standard and applicable regulations.

No recommendation as to products and services or vendors is made or should be implied.

No representation or warranty is made that this deliverable is technically accurate or sufficient or conforms to any law and/or governmental rule and/or regulation and further, no representation or warranty is made of merchantability or fitness for any particular purpose or against infringement of intellectual property rights.

In no event shall ETSI be held liable for loss of profits or any other incidental or consequential damages.

Any software contained in this deliverable is provided "AS IS" with no warranties, express or implied, including but not limited to, the warranties of merchantability, fitness for a particular purpose and non-infringement of intellectual property rights and ETSI shall not be held liable in any event for any damages whatsoever (including, without limitation, damages for loss of profits, business interruption, loss of information, or any other pecuniary loss) arising out of or related to the use of or inability to use the software.

Copyright Notification

No part may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm except as authorized by written permission of ETSI.

The content of the PDF version shall not be modified without the written authorization of ETSI.

The copyright and the foregoing restriction extend to reproduction in all media.

© ETSI 2025.
All rights reserved.

Contents

Intellectual Property Rights	7
Foreword.....	7
Modal verbs terminology.....	8
Executive summary	8
Introduction	8
1 Scope	9
2 References	9
2.1 Normative references	9
2.2 Informative references.....	10
3 Definition of terms, symbols and abbreviations.....	12
3.1 Terms.....	12
3.2 Symbols.....	14
3.3 Abbreviations	14
4 Monitoring and Control (M&C) overview	16
4.0 General	16
4.1 Infrastructure equipment management network general description.....	17
4.2 Site Internal Communication Architecture.....	18
4.3 Infrastructure Equipment Monitoring & Control management network example.....	21
4.4 Infrastructure Equipment Monitoring & Control management scenario	22
5 Infrastructure equipment monitoring & control management interface and network architecture	25
5.0 General	25
5.1 Distributed intelligence	26
5.2 CU, DGU, LMA management interface.....	26
5.3 Interface and protocol diversity	26
5.4 Open interface and software.....	28
5.5 Interface levels	28
5.5.1 Alarm and state loops interface on CU or DGU output	28
5.5.2 Low level protocol equipment CU mediation by DGU	29
5.5.3 CU and DGU high level protocol interface	29
5.6 Transport Control Layer.....	30
5.7 Physical and network layer.....	30
5.8 Network Management system upgrade	30
6 Infrastructure equipment monitoring & control main goals.....	31
6.1 Data in the infrastructure equipment monitoring & control network	31
6.1.0 General.....	31
6.1.1 Mandatory data in the infrastructure equipment monitoring & control network	32
6.1.2 Optional data in the infrastructure equipment monitoring & control network.....	33
6.3 High level application and data structure flexibility.....	33
6.4 Data interface complexity and structure	34
6.4.1 Information	34
6.4.2 Status and event	35
6.4.3 Alarm severity and event class	35
7 Infrastructure equipment monitoring & control management typical content subsets.....	35
7.0 General	35
7.1 DC power system ETSI ES 202 336-2	38
7.2 AC UPS power system ETSI ES 202 336-3.....	38
7.3 AC distribution switchboard ETSI ES 202 336-4	38
7.4 AC diesel back-up generator ETSI ES 202 336-5.....	38
7.5 Thermal environment and cooling system ETSI ES 202 336-6	38
7.6 Other utilities system ETSI ES 202 336-7.....	38
7.7 Remote power feeding system ETSI ES 202 336-8	38

7.8	Alternative power systems ETSI ES 202 336-9	38
7.9	AC inverter power system ETSI ES 202 336-10.....	38
7.10	Battery system with integrated control and monitoring information model ETSI ES 202 336-11.....	38
7.11	ICT equipment power, energy, and environmental parameters monitoring information model ETSI ES 202 336-12.....	38
8	Principle of Power, Energy, Environmental parameters (PEE) measurement	39
8.0	General	39
8.1	Power and energy consumption measurement	39
8.2	Voltage, current measurement	40
8.3	Accuracy of PEE measurement	40
8.3.1	Electrical measurement accuracy.....	40
8.3.2	Compatibility with IEC standard	41
8.4	Local acquisition record	42
8.5	Accuracy verification	42
8.6	Data transmission period	43
8.7	Local record saving	43
9	Supervisor functions and performance.....	43
9.0	General	43
10	Data structure format for exchange between CU or DGU and LMA or RMA by infrastructure equipment monitoring & control agent	44
10.0	General	44
10.1	Standard elements of any equipment, system or subsystem	45
10.1.1	Standard elements.....	45
10.1.2	Alarm and event message	45
10.1.3	The <description_table> element.....	46
10.1.4	The <alarm_table> element	48
10.1.5	The <event_table> element.....	49
10.1.6	The <data_table> element.....	50
10.1.7	The <data_record_table> element.....	51
10.1.8	The <config_table> element	53
10.1.9	The <control_table> element.....	53
10.2	The <site> element	54
10.2.0	General.....	54
10.2.1	Recommendation about the <description_table> of the <site> element.....	54
10.3	The <energy_system> element.....	55

Annex A (informative): Communication between LMA/RMA and infrastructure equipment monitoring & control agent using YANG/NETCONF and REST57

A.0	Introduction	57
A.1	Communication initiated by the LMA/RMA	58
A.1.0	Introduction	58
A.1.1	The GET method.....	58
A.1.2	The POST method	60
A.2	Communication initiated by DGU/CU.....	60

Annex B (informative): Data Coherence and reliability for infrastructure equipment monitoring & control.....61

B.0	Introduction	61
B.1	Data integrity, coherence and management network reliability	61
B.2	Application data coherence and integrity	61
B.3	Naming and data origin	62
B.4	CU, DGU reliability	62
B.5	LMA reliability	62

B.6	RMA reliability	63
B.7	Ethernet and IP network reliability	63
B.8	Computer and OS reliability.....	63
B.9	Application reliability.....	63
Annex C (informative):	Network element functions and software architecture and choices	65
C.1	General description.....	65
C.2	Functions of the RMA.....	66
C.3	Data analysis	66
C.4	Safety monitoring input provision.....	67
C.5	Software working and development environment.....	67
Annex D (informative):	Network capacity and timing.....	68
D.0	Introduction	68
D.1	Management and Network Capacity	68
D.2	Memory capacity.....	68
D.3	Timing performance	68
Annex E (informative):	Overview of the XML format	70
E.0	Introduction	70
E.1	XML	70
E.2	XML declaration	70
E.3	XML element, XML root element and XML child element	70
E.4	XML document	71
E.5	XML Attribute.....	71
E.6	XML Schema	71
E.7	XML Schema Datatypes	71
E.8	XSL Languages	72
E.9	XSLT	73
E.10	XPath.....	73
Annex F (informative):	Hints about the choice of OSI or IP models, physical network layers and intranet-Ethernet access protocols.....	74
F.0	Introduction	74
F.1	OSI and IP models.....	74
F.2	Details on IP layers.....	75
F.2.1	Application Layer.....	75
F.2.2	Transport Layer.....	76
F.2.3	Network Layer.....	76
F.2.4	Link Layer	76
F.3	Internet- Ethernet access protocol PPPoE, PPPoA, PoS	77
F.3.1	PPPoE.....	77
F.3.2	PPP service.....	78
F.3.3	Other PPP	78

Annex G (informative):	Common API.....	79
Annex H (informative):	State of the art of power, energy measurement and monitoring systems	81
H.0	Introduction	81
H.1	Acquisition and remote metering principles.....	81
H.2	General description of measurement	83
H.2.1	General principle	83
H.2.2	Measurement sensors	83
Annex I (informative):	Bibliography.....	88
Annex (informative):	Change history	89
History		90

i T h S t a n d a r d s
(h t t p s : / / s t a n d a r d s . i t
D o c u m e n t i e P w r

E T S I E S 1 2 0 2 1 3 (3 2 6 0 - 2 1 5 - 0 4)

h t t p s : / / s t a n d a r d s . i t / e s 1 2 0 2 1 3 (3 2 6 0 - 2 1 5 - 0 4)

Intellectual Property Rights

Essential patents

IPRs essential or potentially essential to normative deliverables may have been declared to ETSI. The declarations pertaining to these essential IPRs, if any, are publicly available for **ETSI members and non-members**, and can be found in ETSI SR 000 314: *"Intellectual Property Rights (IPRs); Essential, or potentially Essential, IPRs notified to ETSI in respect of ETSI standards"*, which is available from the ETSI Secretariat. Latest updates are available on the [ETSI IPR online database](#).

Pursuant to the ETSI Directives including the ETSI IPR Policy, no investigation regarding the essentiality of IPRs, including IPR searches, has been carried out by ETSI. No guarantee can be given as to the existence of other IPRs not referenced in ETSI SR 000 314 (or the updates on the ETSI Web server) which are, or may be, or may become, essential to the present document.

Trademarks

The present document may include trademarks and/or tradenames which are asserted and/or registered by their owners. ETSI claims no ownership of these except for any which are indicated as being the property of ETSI, and conveys no right to use or reproduce any trademark and/or tradename. Mention of those trademarks in the present document does not constitute an endorsement by ETSI of products, services or organizations associated with those trademarks.

DECT™, **PLUGTESTS™**, **UMTS™** and the ETSI logo are trademarks of ETSI registered for the benefit of its Members. **3GPP™**, **LTE™** and **5G™** logo are trademarks of ETSI registered for the benefit of its Members and of the 3GPP Organizational Partners. **oneM2M™** logo is a trademark of ETSI registered for the benefit of its Members and of the oneM2M Partners. **GSM®** and the GSM logo are trademarks registered and owned by the GSM Association.

Foreword

This ETSI Standard (ES) has been produced by ETSI Technical Committee Environmental Engineering (EE).

The present document is part 1 of a multi-part deliverable covering Environmental Engineering (EE); Monitoring and Control Interface for Infrastructure Equipment (power, cooling and building environment systems used in telecommunication networks), as identified below:

Part 1: "Generic Interface";

Part 2: "DC power system control and monitoring information model";

Part 3: "AC UPS power system control and monitoring information model";

Part 4: "AC distribution power system control and monitoring information model";

Part 5: "AC diesel back-up generator system control and monitoring information model";

Part 6: "Air Conditioning System control and monitoring information model";

Part 7: "Other utilities system control and monitoring information model";

Part 8: "Remote Power Feeding System control and monitoring information model";

Part 9: "Alternative Power Systems";

Part 10: "AC inverter power system control and monitoring information model";

Part 11: "Battery system with integrated control and monitoring information model";

Part 12: "ICT equipment power, energy and environmental parameters monitoring information model".