

SLOVENSKI STANDARD oSIST prEN ISO 16639:2019

01-januar-2019

Nadzorovanje koncentracije aktivnosti radioaktivnih snovi v zraku na delovnem mestu v jedrskih postrojih (ISO 16639:2017)

Surveillance of the activity concentrations of airborne radioactive substances in the workplace of nuclear facilities (ISO 16639:2017)

Überwachung der Aktivitätskonzentrationen von luftgetragenen radioaktiven Substanzen an Arbeitsplätzen kerntechnischer Einrichtungen (ISO 16639:2017)

Surveillance de l'activité volumique des substances radioactives dans l'air des lieux de travail des installations nucléaires (ISO 16639:2017)

b5823a94c8e/sist-en-iso-16639-2019

Ta slovenski standard je istoveten z: prEN ISO 16639

ICS:

13.040.30	Kakovost zraka na delovnem mestu	Workplace atmospheres
13.280	Varstvo pred sevanjem	Radiation protection
27.120.20	Jedrske elektrarne. Varnost	Nuclear power plants. Safety

oSIST prEN ISO 16639:2019 en,fr,de

oSIST prEN ISO 16639:2019

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>SIST EN ISO 16639:2019</u> https://standards.iteh.ai/catalog/standards/sist/96b5a960-768e-48e5-b77e-0b5823a94c8e/sist-en-iso-16639-2019

INTERNATIONAL STANDARD

ISO 16639

First edition 2017-01

Surveillance of the activity concentrations of airborne radioactive substances in the workplace of nuclear facilities

Surveillance de l'activité volumique des substances radioactives dans l'air des lieux de travail des installations nucléaires

(standards.iteh.ai)

<u>SIST EN ISO 16639:2019</u> https://standards.iteh.ai/catalog/standards/sist/96b5a960-768e-48e5-b77e-0b5823a94c8e/sist-en-iso-16639-2019



Reference number ISO 16639:2017(E) ISO 16639:2017(E)

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>SIST EN ISO 16639:2019</u>

https://standards.iteh.ai/catalog/standards/sist/96b5a960-768e-48e5-b77e-0b5823a94c8e/sist-en-iso-16639-2019



© ISO 2017, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office Ch. de Blandonnet 8 • CP 401 CH-1214 Vernier, Geneva, Switzerland Tel. +41 22 749 01 11 Fax +41 22 749 09 47 copyright@iso.org www.iso.org

Contents

Page

Introduction v 1 Scope 1 2 Normative references 2 3 Terms and definitions 2 4 Symbols 2 5 Developing the surveillance program 2 5.1 Reasons for conducting a surveillance programme 2 5.1.1 General 2 5.1.2 Sampling to establish air contamination areas 6 5.1.3 Graded approach to sampling 5 5.2 Graded approach to sampling 5 5.3 Frequency of sampling 6 5.3.1 General 2 5.3.3 Continuous sampling 6 5.3.4 Prompt analysis of cartain samples 6 5.4 Substitutes for air sampling 2 6 Location of samplers and monitors 2 6.1 General 2 6.2.2 Qualitative airflow studies 2 6.3.3 Quanitative airflow studies 6 6.4 Location of samplers for evaluating committed effective dose 10 6.3.2 Q	Fore	word		v	
1 Scope 1 2 Normative references 2 3 Terms and definitions 2 4 Symbols 5 5 Developing the surveillance program 5 5.1 Reasons for conducting a surveillance programme 5 5.1.2 Sampling when respiratory protective equipment is used 6 5.1.3 Sampling to establish air contamination areas 6 5.1.4 Air sampling for early warning of elevated air concentrations 6 5.2 Graded approach to sampling 5 5.3 Frequency of sampling 6 5.3.1 General 6 5.3.2 Grab vs. continuous sampling 6 5.3.3 Continuous monitoring of activity concentrations 6 5.3.4 Prompt analysis of certain samples 6 6.4 Location of samplers and monitors 6 6.1 General 6 6.2 Types of air flow studies 6 6.3 Location of samplers for estimating committed effective dose 10 6.4 Location of samplers for posting of air contamination are	Intro	oductio	n	vi	
2 Normative references 2 3 Terms and definitions 2 4 Symbols 5 5 Developing the surveillance program 5 5.1 Reasons for conducting a surveillance programme 5 5.1.1 General 6 5.1.2 Sampling to establish air contamination areas 6 5.1.3 Sampling for early warning of elevated air concentrations 6 5.2.1 General 6 5.3.1 General 6 5.3.2 Grab vs. continuous sampling 6 5.3.3 General 6 5.3.4 Prompt analysis of certain samples 6 5.3.4 Prompt analysis of certain samples 6 6.1 General 6 6.2 Types of air flow studies 6 6.2.1 General 6 6.3 Location of samplers for estimating committed effective dose 11 6.4 Location of samplers for establing effectiveness of containment 11 6.5 Location of samplers for estimating committed effective dose 11 6.	1	Scop	е	1	
3 Terms and definitions 2 4 Symbols 5 5 Developing the surveillance program 5 5.1 Reasons for conducting a surveillance programme 5 5.1 Reasons for conducting a surveillance programme 5 5.1.1 General 5 5.1.2 Sampling to establish air contamination areas 6 5.1.3 Sampling as a basis for determining worker intakes 6 5.2 Graded approach to sampling 5 5.3 Frequency of sampling 5 5.3.4 Foropt sampling 6 5.3.4 Foropt sandysis of certain samples 6 6 Location of samplers and monitors 6 6.1 General 6 6.2.1 6.2.2 Qualitative airflow studies 6 6.2.3 Qualitative airflow studies 6 6.3.4 Location of samplers for evaluating effectiveness of containment 11 6.4 Location of samplers for evaluating effectiveness of containment 11 6.5.1 Location of samplers for evaluating effectiveness of containment 12	2	Norn	native references	2	
4 Symbols 5 5 Developing the surveillance program 5 5.1 Reasons for conducting a surveillance programme 5 5.1.1 General 5 5.1.2 Sampling when respiratory protective equipment is used 6 5.1.3 Sampling to establish air contamination areas 6 5.1.4 Air sampling to establish air contamination areas 6 5.1.5 Air monitoring for early warning of elevated air concentrations 6 5.2 Graded approach to sampling 7 5.3 Frequency of sampling 6 5.3.1 General 6 5.3.2 Grab vs. continuous sampling 6 5.3.3 Continuous monitoring of activity concentrations 6 5.3.4 Prompt analysis of certain samples 9 6.4 Location of samplers and monitors 9 6.1 General 6 6.2 Types of air flow studies 10 6.2.1 General 10 6.2.2 Qualitative airflow studies 11 6.3 Location of samplers for estimating committed effective	3	Term	us and definitions	2	
** Symbols 5 Developing the surveillance program 5 5.1 Reasons for conducting a surveillance programme 5 5.1.1 General 5 5.1.2 Sampling when respiratory protective equipment is used 6 5.1.3 Sampling to establish air contamination areas 6 5.1.4 Air sampling for early warning of elevated air concentrations 6 5.2 Graded approach to sampling 5 5.3 Frequency of sampling of activity concentrations 6 5.3.3 General 6 5.3.4 General 6 5.3.5 Grab vs. continuous sampling 6 5.3.4 Prompt analysis of certain samples 6 6 Location of samplers and monitors 6 6.1 General 6 6.2 Types of air flow studies 6 6.3.4 General 6 6.2.5 Qualitative airflow studies 6 6.2.6 Types of air flow studies 6 6.2.7 General 11 6.5 Location of samplers for estimating	4	Sumh			
5 Developing the Surveillance programme	-+ -	Sym		J	
5.1 Renoral 5 5.1.2 Sampling when respiratory protective equipment is used 6 5.1.3 Sampling to establish air contamination areas 6 5.1.4 Air sampling as a basis for determining worker intakes 6 5.1.5 Air monitoring for early warning of elevated air concentrations 7 5.2 Graded approach to sampling 7 5.3 Frequency of sampling 6 5.3.1 General 6 5.3.2 Grab vs. continuous sampling 6 5.3.3 Continuous monitoring of activity concentrations 6 5.3.4 Prompt analysis of certain samples 9 6.1 General 9 6.2 Quantitative airflow studies 11 6.3 Location of samplers for estimating committed effective dose 11 6.3 Location of samplers for posting of air contamination areas 11 6.4 Location of samplers for continuous monitoring of the activity concentration 12 6.3 Location of samplers for costinating committed effective dose 11 6.4 Location of samplers for costination areas 11	5	Deve	Ioping the surveillance program		
5.1.2 Sampling when respiratory protective equipment is used 6 5.1.3 Sampling to establish air contamination areas 6 5.1.4 Air sampling as a basis for determining worker intakes 6 5.1.5 Air monitoring for early warning of elevated air concentrations 6 5.2 Graded approach to sampling 7 5.3 Frequency of sampling 6 5.3.1 General 6 5.3.2 Continuous monitoring of activity concentrations 8 5.3.3 Continuous monitoring of activity concentrations 8 5.3.4 Prompt analysis of certain samples 9 6 Location of samplers and monitors 9 6.1 General 9 6.2.1 General 9 6.3.2 Qualitative airflow studies 10 6.4 Location of samplers for estimating committed effective dose 11 6.3 Location of samplers for posting of air contamination areas 11 6.4 Location of samplers for posting of air contamination areas 11 6.5 Location of Samplers 12 7.1 General <td< td=""><td></td><td>5.1</td><td>5 1 1 General</td><td></td></td<>		5.1	5 1 1 General		
5.1.3 Sampling to establish air contamination areas 6 5.1.4 Air sampling as a basis for determining worker intakes 6 5.1.5 Air monitoring for early warning of elevated air concentrations 7 5.2 Graded approach to sampling 7 5.3 Frequency of sampling 6 5.3.1 General 6 5.3.2 Grab vs. continuous sampling 6 5.3.3 Continuous monitoring of activity concentrations 6 5.3.4 Prompt analysis of certain samples 9 6.1 General 9 6.2.1 General 9 6.3.2 Qualitative airflow studies 11 6.4 Location of samplers for evaluating effectiveness of containment 11 6.5 Location of samplers for evaluating effectiveness of containment 11 6.6 Location of samplers for posting of air contamination areas 11 6.6 Location of samplers 12 7.1 General 12 7.2 Sampling of aerosol particles 12 7.3 Gas applers for posting of air contanination areas 11 <td></td> <td></td> <td>5.1.2 Sampling when respiratory protective equipment is used</td> <td></td>			5.1.2 Sampling when respiratory protective equipment is used		
5.1.4 Air sampling as a basis for determining worker intakes 6 5.1.5 Air monitoring for early warning of elevated air concentrations 6 5.2 Graded approach to sampling 7 5.3 Frequency of sampling 6 5.3.1 General 6 5.3.2 Grab vs. continuous sampling 6 5.3.3 Continuous monitoring of activity concentrations 6 5.3.4 Prompt analysis of certain samples 6 5.4 Substitutes for air sampling 6 6 Location of samplers and monitors 6 6.1 General 6 6.2.1 General 6 6.2.2 Qualitative airflow studies 6 6.2.3 Quantitative airflow studies 10 6.2.4.1 General 11 6.5 Location of samplers for evaluating committed effective dose 11 6.4 Location of samplers for posting of air contamination areas 11 6.5 Location of CAM for continuous monitoring of the activity concentration 12 7 Collection of samplers 12 7.1			5.1.3 Sampling to establish air contamination areas		
5.1.5 Air monitoring for early warning of elevated air concentrations 6 5.2 Graded approach to sampling 7 5.3 Frequency of sampling 8 5.3.1 General 8 5.3.2 Grab vs. continuous sampling 8 5.3.3 Continuous monitoring of activity concentrations 8 5.3.4 Prompt analysis of certain samples 9 6.1 General 9 6.2 Types of air flow studies 9 6.3 Location of samplers and monitors 9 6.4.1 General 9 6.2.2 Qualitative airflow studies 9 6.3 Location of samplers for estimating committed effective dose 11 6.4 Location of samplers for posing of air contamination areas 11 6.5 Location of portable samplers 12 6.6 Location of portable samplers 12 7.1 General 12 7.2 Sampling results 12 7.4 General 12 7.5 Gas Sampling 12 7.2 Sampling			5.1.4 Air sampling as a basis for determining worker intakes	6	
5.2 Graded approach to sampling 7 5.3 Frequency of sampling 6 5.3.1 General 8 5.3.2 Grab vs. continuous sampling 6 5.3.3 Continuous monitoring of activity concentrations 6 5.3.4 Prompt analysis of certain samples 9 6.1 General 9 6.2 Types of air flow studies 9 6.3.1 General 9 6.4 Location of samplers for estimating committed effective constraints 11 6.5 General 12 6.2.3 Qualitative airflow studies 12 6.4 Location of samplers for estimating committed effective dose 11 6.5 Location of samplers for evaluating effectiveness of containment 11 6.5 Location of famplers 12 7.1 General 12 7.2 Sampling of aerosol particles 12 7.3 Gas Sampling 13 7.4 General 12 7.5 Collection of samplers 12 7.1 General 12 </td <td></td> <td></td> <td>5.1.5 Air monitoring for early warning of elevated air concentrations</td> <td>6</td>			5.1.5 Air monitoring for early warning of elevated air concentrations	6	
5.3 Frequency of sampling 8 5.3.1 General 8 5.3.2 Grab vs. continuous sampling 8 5.3.3 Continuous monitoring of activity concentrations 8 5.4 Prompt analysis of certain samples 9 5.4 Substitutes for air sampling 9 6 Location of samplers and monitors 9 6.1 General 9 6.2 Types of air flow studies 9 6.2.3 Qualitative airflow studies 9 6.4 Location of samplers for estimating committed effective dose 10 6.3 Location of samplers for evaluating effectiveness of containment 11 6.4 Location of samplers for posting of air contamination areas 11 6.5 Location of portable samplers 12 6.4 Location of for continuous monitoring of the activity concentration 12 7 Collection of samplers for posting of air contamination areas 11 6.4 Location of continuous monitoring of the activity concentration 12 7.1 General 12 7.3 Gas Sampling results 14		5.2	Graded approach to sampling	7	
5.3.1 General 8 5.3.2 Grab vs. continuous sampling 8 5.3.3 Continuous monitoring of activity concentrations 8 5.3.4 Prompt analysis of certain samples 9 5.4 Substitutes for air sampling 9 6 Location of samplers and monitors 9 6.1 General 9 6.2.7 Types of air flow studies 9 6.2.1 General 9 6.2.2.9 Qualitative airflow studies 9 6.3 Location of samplers for estimating committed effective dose 10 6.4 Location of samplers for estimating effectiveness of containment 11 6.5 Location of samplers for continuous monitoring of the activity concentration 12 6.4 Location of samplers for continuous monitoring of the activity concentration 12 7.1 General 12 7.2 Sampling of aerosol particles 12 7.3 Gas Sampling 12 7.4 General 12 7.5 General 12 7.6 Guation of samplers for continuous monitor		5.3	Frequency of sampling		
5.3.2 Gradovs. continuous sampling 6 5.3.4 Prompt analysis of certain samples 6 5.4 Substitutes for air sampling 6 6 Location of samplers and monitors 6 6.1 General 6 6.2 Types of air flow studies 6 6.2.1 General 6 6.2.2 Qualitative airflow studies 6 6.3.3 Location of samplers for estimating committed effective dose 10 6.4 Location of samplers for estimating committed effective dose 10 6.4 Location of samplers for posting of air contamination areas 11 6.5 Location of orable samplers 12 6.7 Location of CAM for continuous monitoring of the activity concentration 12 7.1 General 12 7.3 Gas Sampling results 14 8.1 Determining the average activity concentration 14 8.1 Determining the average activity concentration over time 15 8.5 Review of sampling results 15 9 Evaluating the effectiveness of the sampling program 16 <			5.3.1 General	8	
5.3.3 Orompt analysis of certain samples C 5.4 Substitutes for air sampling C 6 Location of samplers and monitors C 6.1 General C 6.2 Types of air flow studies C 6.1.1 General C 6.2.2 Qualitative airflow studies C 6.3.1 General C 6.4.2 Qualitative airflow studies C 6.3.3 Quantitative airflow studies C 6.4 Location of samplers for estimating committed effective dose 11 6.5 Location of samplers for posting of air contamination areas 11 6.6 Location of portable samplers 12 7.1 General 12 7.2 Sampling of aerosol particles 12 7.3 Gas Sampling 13 8 Evaluation of sampler sor correcting for radon progeny interference 12 7.3 Gas Sampling results 14 8.1 Determining the average activity concentration 14 8.2 Uncertainty 14 8.3			5.3.2 Grad vs. continuous sampling	δ Ω	
5.4 Substitutes for air sampling. 9 6 Location of samplers and monitors 9 6.1 General 9 6.2 Types of air flow studies 9 6.2.1 General 9 6.2.3 Qualitative airflow studies 9 6.3 Location of samplers for estimating committed effective dose 10 6.4 Location of samplers for evaluating effectiveness of containment 11 6.5 Location of samplers for posting of air contamination areas 11 6.6 Location of Samplers for posting of the activity concentration 12 6.4 Location of CAM for continuous monitoring of the activity concentration 12 7.1 General 12 7.3 Gas Sampling 13 7.3 Gas Sampling results 14 8.1 Determining the average activity concentration 14 8.1 Determining changes in activity concentration over time 15 8.4 Evaluating changes in activity concentration over time 15 8.5 Review of sampling results 15 9 Evaluating the effectiveness of the sampli			5.3.4 Prompt analysis of certain samples	0 Q	
6 Location of samplers and monitors 9 6.1 General 9 6.2 Types of air flow studies 9 6.2.1 General 9 6.2.3 Qualitative airflow studies 9 6.3 Location of samplers for estimating committed effective dose 10 6.4 Location of samplers for evaluating effectiveness of containment 11 6.5 Location of samplers for posting of air contamination areas 11 6.6 Location of portable samplers 12 6.7 Location of for CAM for continuous monitoring of the activity concentration 12 7.1 General 12 7.2 Sampling of aerosol particles 12 7.3 Gas Sampling 13 8 Evaluation of sampling results 14 8.1 Determining the average activity concentration 14 8.2 Uncertainty 14 8.3 Techniques for correcting for radon progeny interference 15 8.4 Evaluating changes in activity concentration over time 15 8.4 Evaluating changes in activity concentration over time 16 </td <td></td> <td>5.4</td> <td>Substitutes for air sampling</td> <td>9</td>		5.4	Substitutes for air sampling	9	
6 Location of samplers and monitors 5 6.1 General 5 6.2 Types of air flow studies 5 6.2.1 General 5 6.2.3 Qualitative airflow studies 6 6.3 Location of samplers for estimating committed effective dose 10 6.4 Location of samplers for evaluating effectiveness of containment 11 6.5 Location of samplers for posting of air contamination areas 11 6.6 Location of portable samplers 12 6.7 Location of CAM for continuous monitoring of the activity concentration 12 7.1 General 12 7.2 Sampling of aerosol particles 12 7.3 Gas Sampling 12 7.4 Betermining the average activity concentration 14 8.1 Determining the average activity concentration 14 8.2 Uncertainty 14 8.3 Techniques for correcting for radon progeny interference 15 8.4 Evaluating changes in activity concentration over time 15 8.5 Review of sampling results 15	6	Local	tion of complete and mentionered a 4 a la a 3	0	
6.1 General 5 6.2 Types of air flow studies 5 6.2.1 General 5 6.2.3 Quantitative airflow studies 10 6.3 Location of samplers for estimating committed effective dose 10 6.4 Location of samplers for evaluating effectiveness of containment 11 6.5 Location of samplers for posting of air contamination areas 11 6.6 Location of portable samplers 12 6.7 Location of famplers 12 6.6 Location of portable samplers 12 6.7 Location of CAM for continuous monitoring of the activity concentration 12 7.1 General 12 7.3 Gas Sampling 12 7.3 Gas Sampling results 14 8.1 Determining the average activity concentration 14 8.2 Uncertainty 14 8.3 Techniques for correcting for radon progeny interference 15 8.4 Evaluating changes in activity concentration over time 15 8.5 Review of sampling results 15 9 <t< td=""><td>0</td><td>LOCA</td><td>Lion of sampler's and monitor's</td><td>9</td></t<>	0	LOCA	Lion of sampler's and monitor's	9	
6.2 1 General Sixt 150,150,150,150,150,150,150,150,150,150,		6.2	Types of air flow studies		
http 6.2.2 m. Qualitative airflow studies 0 6.2.3 Quantitative airflow studies 10 6.3 Location of samplers for estimating committed effective dose 10 6.4 Location of samplers for evaluating effectiveness of containment 11 6.5 Location of samplers for posting of air contamination areas 11 6.6 Location of portable samplers 12 6.7 Location of CAM for continuous monitoring of the activity concentration 12 7 Collection of samples 12 7.1 General 12 7.2 Sampling of aerosol particles 12 7.3 Gas Sampling 13 8 Evaluation of sampler for radon progeny interference 14 8.1 Determining the average activity concentration 14 8.2 Uncertainty 14 8.3 Techniques for correcting for radon progeny interference 15 8.4 Evaluating changes in activity concentration over time 15 8.5 Review of sampling results 16 9 Evaluating the effectiveness of the sampling program 16 9.1 General 16 9.2 Dose-based assessment of the adequacy of the sampling program 16 9.1 General 16 9.2 Dose-based assessment of the a		0.2	6.2.1 General SIST EN ISO 16630-2010	9	
6.2.3 Quantitative airflow studies 10 6.3 Location of samplers for estimating committed effective dose 10 6.4 Location of samplers for evaluating effectiveness of containment 11 6.5 Location of samplers for posting of air contamination areas 11 6.6 Location of portable samplers 12 6.7 Location of CAM for continuous monitoring of the activity concentration 12 7.1 General 12 7.3 Gas Sampling of aerosol particles 12 7.3 Gas Sampling results 14 8.1 Determining the average activity concentration 14 8.2 Uncertainty 14 8.3 Techniques for correcting for radon progeny interference 15 8.4 Evaluating changes in activity concentration over time 15 8.5 Review of sampling results 15 9 Evaluating the effectiveness of the sampling program 16 9.1 General 16 9.2 Dose-based assessment of the adequacy of the sampling program 16 9.1 General 16 9.2 Dose-base			6.2.2 no Qualitative airflow studies	9	
6.3 Location of samplers for estimating committed effective dose 10 6.4 Location of samplers for evaluating effectiveness of containment 11 6.5 Location of samplers for posting of air contamination areas 11 6.6 Location of portable samplers 12 6.7 Location of CAM for continuous monitoring of the activity concentration 12 7 Collection of samples 12 7.1 General 12 7.2 Sampling of aerosol particles 12 7.3 Gas Sampling 13 8 Evaluation of sampling results 14 8.1 Determining the average activity concentration 14 8.2 Uncertainty 14 8.3 Techniques for correcting for radon progeny interference 15 8.4 Evaluating changes in activity concentration over time 15 8.5 Review of sampling results 15 9 Evaluating the effectiveness of the sampling program 16 9.1 General 16 9.2 Dose-based assessment of the adequacy of the sampling program 16 9.2 Dose-based			6.2.3 Quantitative airflow studies		
6.4 Location of samplers for evaluating effectiveness of containment. 11 6.5 Location of samplers for posting of air contamination areas. 11 6.6 Location of portable samplers. 12 6.7 Location of CAM for continuous monitoring of the activity concentration 12 7 Collection of samples 12 7.1 General 12 7.2 Sampling of aerosol particles 12 7.3 Gas Sampling 13 8 Evaluation of sampling results 14 8.1 Determining the average activity concentration 14 8.2 Uncertainty 14 8.3 Techniques for correcting for radon progeny interference 15 8.4 Evaluating changes in activity concentration over time 15 8.5 Review of sampling results 15 9 Evaluating the effectiveness of the sampling program 16 9.1 General 16 9.2 Dose-based assessment of the adequacy of the sampling program 16 9.1 General 16 9.2 Dose-based assessment of the adequacy of the sampling program		6.3	Location of samplers for estimating committed effective dose		
6.5 Location of samplers for posting of air contamination areas 11 6.6 Location of portable samplers 12 6.7 Location of CAM for continuous monitoring of the activity concentration 12 7 Collection of samples 12 7.1 General 12 7.2 Sampling of aerosol particles 12 7.3 Gas Sampling 13 8 Evaluation of sampling results 14 8.1 Determining the average activity concentration 14 8.2 Uncertainty 14 8.3 Techniques for correcting for radon progeny interference 15 8.4 Evaluating changes in activity concentration over time 15 8.5 Review of sampling results 15 9 Evaluating the effectiveness of the sampling program 16 9.1 General 16 9.2 Dose-based assessment of the adequacy of the sampling program 16 9.1 General 17 10.1 General 17 10.1 General 17		6.4	Location of samplers for evaluating effectiveness of containment		
6.6 Location of portable samplers. 12 6.7 Location of CAM for continuous monitoring of the activity concentration 12 7 Collection of samples 12 7.1 General 12 7.2 Sampling of aerosol particles 12 7.3 Gas Sampling 13 7.4 Determining the average activity concentration 14 8.1 Determining the average activity concentration 14 8.2 Uncertainty 14 8.3 Techniques for correcting for radon progeny interference 15 8.4 Evaluating changes in activity concentration over time 15 8.5 Review of sampling results 15 9 Evaluating the effectiveness of the sampling program 16 9.1 General 16 9.2 Dose-based assessment of the adequacy of the sampling program 16 9.1 General 17 10.1 General 17 10.1 General 17		6.5	Location of samplers for posting of air contamination areas		
6.7 Location of CAM for continuous monitoring of the activity concentration 12 7 Collection of samples 12 7.1 General 12 7.2 Sampling of aerosol particles 12 7.3 Gas Sampling 13 8 Evaluation of sampling results 14 8.1 Determining the average activity concentration 14 8.2 Uncertainty 14 8.3 Techniques for correcting for radon progeny interference 15 8.4 Evaluating changes in activity concentration over time 15 8.5 Review of sampling results 15 9 Evaluating the effectiveness of the sampling program 16 9.1 General 16 9.2 Dose-based assessment of the adequacy of the sampling program 16 9.1 General 17 10.1 General 17 10.1 General 17		6.6	Location of portable samplers		
7Collection of samples127.1General127.2Sampling of aerosol particles127.3Gas Sampling138Evaluation of sampling results148.1Determining the average activity concentration148.2Uncertainty148.3Techniques for correcting for radon progeny interference158.4Evaluating changes in activity concentration over time158.5Review of sampling results159Evaluating the effectiveness of the sampling program169.1General169.2Dose-based assessment of the adequacy of the sampling program1610Quality assurance and quality control1710.1General17		6.7	Location of CAM for continuous monitoring of the activity concentration	12	
7.1General127.2Sampling of aerosol particles127.3Gas Sampling138Evaluation of sampling results148.1Determining the average activity concentration148.2Uncertainty148.3Techniques for correcting for radon progeny interference158.4Evaluating changes in activity concentration over time158.5Review of sampling results159Evaluating the effectiveness of the sampling program169.1General169.2Dose-based assessment of the adequacy of the sampling program1610Quality assurance and quality control1710.1General17	7	Colle	Collection of samples		
7.2 Sampling of aerosol particles 12 7.3 Gas Sampling 13 8 Evaluation of sampling results 14 8.1 Determining the average activity concentration 14 8.2 Uncertainty 14 8.3 Techniques for correcting for radon progeny interference 15 8.4 Evaluating changes in activity concentration over time 15 8.5 Review of sampling results 15 9 Evaluating the effectiveness of the sampling program 16 9.1 General 16 9.2 Dose-based assessment of the adequacy of the sampling program 16 9.1 General 17 10.1 General 17 10.1 General 17		7.1	General		
7.3 Gas sampling 14 8 Evaluation of sampling results 14 8.1 Determining the average activity concentration 14 8.2 Uncertainty 14 8.3 Techniques for correcting for radon progeny interference 15 8.4 Evaluating changes in activity concentration over time 15 8.5 Review of sampling results 15 9 Evaluating the effectiveness of the sampling program 16 9.1 General 16 9.2 Dose-based assessment of the adequacy of the sampling program 16 9.1 General 16 9.2 Dose-based assessment of the adequacy of the sampling program 16 9.1 General 17 10.1 General 17 10.1 General 17 10.1 General 17		7.2	Sampling of aerosol particles		
 8 Evaluation of sampling results		/.3	Gas Sampling	13	
8.1 Determining the average activity concentration 14 8.2 Uncertainty 14 8.3 Techniques for correcting for radon progeny interference 15 8.4 Evaluating changes in activity concentration over time 15 8.5 Review of sampling results 15 9 Evaluating the effectiveness of the sampling program 16 9.1 General 16 9.2 Dose-based assessment of the adequacy of the sampling program 16 10 Quality assurance and quality control 17 10.1 General 17	8 Eval	Evalı	iation of sampling results		
8.2 Uncertainty		8.1	Determining the average activity concentration		
 8.3 Techniques for correcting for radon progeny interference 8.4 Evaluating changes in activity concentration over time 8.5 Review of sampling results 9 Evaluating the effectiveness of the sampling program 9 Evaluating the effectiveness of the adequacy of the sampling program 16 9.1 General 9.2 Dose-based assessment of the adequacy of the sampling program 10 Quality assurance and quality control 17 10.1 General 		8.2	Uncertainty.		
8.4 Evaluating thatges in activity concentration over time		8.3 0 1	Techniques for correcting for radon progeny interference	15 1 E	
 9 Evaluating the effectiveness of the sampling program 9 General 9.1 General 9.2 Dose-based assessment of the adequacy of the sampling program 10 Quality assurance and quality control 17 10.1 General 		0.4 8 5	Review of sampling results		
9 Evaluating the effectiveness of the sampling program 16 9.1 General 16 9.2 Dose-based assessment of the adequacy of the sampling program 16 10 Quality assurance and quality control 17 10.1 General 17	~	0.5			
 9.1 General 16 9.2 Dose-based assessment of the adequacy of the sampling program 16 10 Quality assurance and quality control 17 10.1 General 17 	9	Evalu	lating the effectiveness of the sampling program		
10 Quality assurance and quality control 17 10.1 General 17		9.1	General	10	
10 Quality assurance and quality control 17 10.1 General 17		9.2	Dose-based assessment of the adequacy of the sampling program		
10.1 General 17	10 Qual 10.1 10.2 10.3	Qual	Quality assurance and quality control		
10.2 Sample identification handling and starses		10.1	General		
10.2 Sampling and monitoring equipment		10.2	Sample identification, nanding, and storage	1/ 17	
10.3.1 General		10.5	10.3.1 General		
10.3.2 Performance of measuring instruments 16		10.3.2 Performance of measuring instruments			

oSIST prEN ISO 16639:2019

ISO 16639:2017(E)

10.3.3 Air in-leakage testing	
	10
Annex A (informative) Examples for the determination of uncertainty, decision threshold and detection limit according to ISO 11929	
Annex B (informative) Correcting for the interference of radon progeny	27
Annex C (informative) Normalized concentration and exposure	
Annex D (informative) Example applications of evaluating sampling program sensitivity from the viewpoint of potential missed exposure	
Bibliography	

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>SIST EN ISO 16639:2019</u> https://standards.iteh.ai/catalog/standards/sist/96b5a960-768e-48e5-b77e-0b5823a94c8e/sist-en-iso-16639-2019

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: <u>www.iso.org/iso/foreword.html</u>.

The committee responsible for this document is ISO/TC 85, *Nuclear energy, nuclear technologies, and radiological protection*, Subcommittee SC 2, *Radiological protection*.

SIST EN ISO 16639:2019 https://standards.iteh.ai/catalog/standards/sist/96b5a960-768e-48e5-b77e-0b5823a94c8e/sist-en-iso-16639-2019

Introduction

Sampling of airborne radionuclides and monitoring of activity concentration in workplaces are critically important for maintaining worker safety at facilities where dispersible radioactive substances are used. Specifically, air sampling and monitoring are critical for evaluation of containment integrity, evaluation of effectiveness of contamination control programs and work practices, providing measurements for qualitative dose assessment, providing a general assessment of the level of the airborne hazard in a room, and for providing workers an immediate warning when the activity concentration exceeds safe levels.

This document sets forth guidelines and performance criteria for sampling airborne radioactive substances and monitoring activity concentration in the workplace of nuclear facilities. Emphasis is on health protection for workers in indoor environments. This document provides best practices and performance-based criteria for the use of sampling devices and systems, including delayed radioactivity measurement samplers and continuous air monitors. Specifically, this document covers air sampling program objectives, design of sampling and monitoring programs to meet program objectives, methods for air sampling and monitoring in the workplace, and quality assurance to ensure system performance toward protecting workers against unnecessary inhalation exposures. Taken together, these activities constitute the sampling or surveillance program.

The primary purpose of the surveillance of airborne activity concentrations in the workplace is to evaluate and mitigate inhalation hazards to workers in facilities where these may become airborne. Results often provide the basis for development and evaluation of control procedures and may indicate if engineering controls or operational changes are necessary.

The surveillance can consist of two general techniques. The first is retrospective sampling, in which constituents of the air are sampled, the collection medium is removed and taken to a radiation detector system and analysed for radioactive substances, and the activity concentration results made available at a later time. In this context, the measured activity concentrations are evaluated retrospectively. The second approach is real-time monitoring, in which activity concentrations are continuously monitored so that workers can be warned that a significant release of airborne activity may have occurred. In implementing an effective sampling program, it is important to achieve a proper balance between the two general approaches of the program. The specific balance depends on the hazard level of the work and the characteristics of each facility.

When designing a surveillance program, the optimization of worker protection minimizes internal and external exposures while balancing social, technical, economic, practical, and public policy considerations that are associated with the use of the radioactive substance.

A comprehensive surveillance program should also consider that the monitoring program is only one element of a comprehensive radiation protection program. Therefore, individuals involved with the monitoring program should interact with personnel working in the other elements of the radiation protection program, such as contamination control and internal dosimetry.

Surveillance of the activity concentrations of airborne radioactive substances in the workplace of nuclear facilities

1 Scope

This document provides guidelines and performance criteria for sampling airborne radioactive substances in the workplace. Emphasis is on health protection of workers in the indoor environment.

This document provides best practices and performance-based criteria for the use of air sampling devices and systems, including retrospective samplers and continuous air monitors. Specifically, this document covers air sampling program objectives, design of air sampling and monitoring programs to meet program objectives, methods for air sampling and monitoring in the workplace, and quality assurance to ensure system performance toward protecting workers against unnecessary inhalation exposures.

The primary purpose of the surveillance of airborne activity concentrations in the workplace is to evaluate and mitigate inhalation hazards to workers in facilities where these can become airborne. A comprehensive surveillance program can be used to

- determine the effectiveness of administrative and engineering controls for confinement,
- measure activity concentrations of radioactive substances,
- alert workers to high activity concentrations in the air,
- aid in estimating worker intakes when bioassay methods are unavailable,
- determine signage or posting requirements for radiation protection, and
- determine appropriate protective equipment and measures.

Air sampling techniques consist of two general approaches. The first approach is retrospective sampling, in which the air is sampled, the collection medium is removed and taken to a radiation detector system and analysed for radioactive substance, and the concentration results made available at a later time. In this context, the measured air concentrations are evaluated retrospectively. The second approach is continuous real-time air monitoring so that workers can be warned that a significant release of airborne radioactivity may have just occurred. In implementing an effective air sampling program, it is important to achieve a balance between the two general approaches. The specific balance depends on hazard level of the work and the characteristics of each facility.

A special component of the second approach which can apply, if properly implemented, is the preparation of continuous air monitoring instrumentation and protocols. This enables radiation protection monitoring of personnel that have been trained and fitted with personal protective equipment (PPE) that permit pre-planned, defined, extended stay time in elevated concentrations of airborne radioactive substances. Such approaches can occur either as part of a planned re-entry of a contaminated area following an accidental loss of containment for accident assessment and recovery, or part of a project which involves systematic or routine access to radioactive substances (e.g. preparing process material containing easily aerosolized components), or handling objects such as poorly characterized waste materials that may contain radioactive contaminants that could be aerosolized when handled during repackaging. In this special case, the role of continuous air monitoring is to provide an alert to health physics personnel that the air concentrations of concern have exceeded a threshold such that the planned level of protection afforded by PPE has been or could be exceeded. This level would typically be many 10's or 100's of times higher than the derived air concentration (DAC) established for unprotected workers. The monitoring alarm or alert would therefore be designed not to be confused with the normal

ISO 16639:2017(E)

monitoring alarm, and the action taken in response would be similarly targeted at the specific site and personnel involved.

The air sampling strategy should be designed to minimize internal exposures and balanced with social, technical, economic, practical, and public policy considerations that are associated with the use of the radioactive substance.

A comprehensive air sampling strategy should also consider that the air sampling program is only one element of a broader radiation protection program. Therefore, individuals involved with the air sampling program should interact with personnel working in other elements of the radiation protection program, such as contamination control and internal dosimetry.

This document does not address outdoor air sampling, effluent monitoring, or radon measurements.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 11929, Determination of the characteristic limits (decision threshold, detection limit and limits of the confidence interval) for measurements of ionizing radiation — Fundamentals and application

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

— IEC Electropedia: available at http://www.electropedia.org/

— ISO Online browsing platform: available at <u>http://www.iso.org/obp</u>60-768e-48e5-b77e-

3.1

accuracy

closeness of agreement between a measured value and a true value

3.2

aerodynamic diameter

Da

diameter of a sphere with density 1 000 kg·m⁻³ that has the same sedimentation velocity in quiescent air as the actual particle of arbitrary shape and density

3.3

aerosol

dispersion of solid or liquid particles in air or other gas

Note 1 to entry: An aerosol is not only the aerosol particles.

3.4

airborne radioactive substance

radioactive substance dispersed in the air in the form of dusts, fumes, particulates, mists, vapours, or gases

3.5

air contamination area

area accessible to individuals where the measured activity concentrations of an airborne radioactive substance exceeds or is likely to exceed the applicable national criteria

3.6

air sampler

device designed to pass a known volume of air containing a radioactive substance through a filter or other media and thereby trapping the airborne radioactive substance on the sampling media

3.7

annual limit on intake

ALI

derived limit for the amount of radioactive substance (in Bq) taken into the body of an adult worker by inhalation or ingestion in a year

3.8 breathing zone BZ

uniform description of the volume of air directly around the worker's upper body and head, which may be drawn into the lungs during the course of breathing

Note 1 to entry: An air sample representative of the breathing zone is usually considered to be representative if drawn from within about 30 cm of the worker's head.

3.9 breathing zone sampler BZA

air sampler located in the breathing zone

Note 1 to entry: Other common terms include "personal air sampler" (PAS), "personal air monitor" (PAM), "lapel air samplers" or "fixed air sampler".

Note 2 to entry: In the case of workers using PPE which includes full face (or even whole body suit) respirator equipment and supplied air, as when preparing for entry into high levels of airborne radioactive substances, special BZA or protective equipment samplers may be needed. Such BZAs are not always mandated then, but the decision should be based on the contaminant levels and types of PPE involved and the potential for contamination entering the suit or air immediately surrounding the suit just as PPE are being doffed.

3.10 continuous air monitor CAM

instrument that continuously monitors the airborne activity concentration on a near real-time basis

3.11

continuous monitoring

active and continual monitoring of activity concentration in room air in near real time

Note 1 to entry: This approach uses continuous air monitors to assess activity concentration in air and can alarm when predetermined levels are exceeded.

3.12 derived air concentration

DAC

concentration of a radionuclide in air that, if breathed over the period of a work year, would result in the intake of one ALI for that radionuclide

Note 1 to entry: The DAC is calculated by dividing the ALI by the volume of air breathed by reference man under light-activity work during a working year (in $Bq \cdot m^{-3}$).

Note 2 to entry: The parameter values recommended by the International Commission on Radiological Protection for calculating the DAC are a breathing rate of 1,2 m³·h⁻¹ and a working year of 2 000 h (i.e. 2 400 m³).

Note 3 to entry: The air concentration can be expressed in terms of a number of DAC. For example, if the DAC for a given radionuclide in a particular form is 0,2 Bq·m⁻³ and the observed concentration is 1,0 Bq·m⁻³, then the observed concentration can also be expressed as 5 DAC (i.e. 1,0 divided by 0,2)

ISO 16639:2017(E)

Note 4 to entry: The derived air concentration-hour (DAC-h) is an integrated exposure and is the product of the concentration of a radioactive substance in air (expressed as a fraction or multiple of DAC for each radionuclide) and the time of exposure to that radionuclide, in hours.

[SOURCE: References [5] and [10], modified]

3.13 detection limit L_D

smallest true value of the measurand which ensures a specified probability of being detectable by the measurement procedure

Note 1 to entry: For a given type-I error (or false alarm probability, i.e. typically 0,05), L_D is the lowest net count (or rate) with the desired probability of detection, i.e. typically 0,95 (otherwise stated as a type-II error of 0,05 or a missed detection probability of 5 %).

Note 2 to entry: The measurand is the quantity subject to measurement.

3.14

grab sample

air sample of a sufficient volume drawn over a relatively short duration

3.15

intake

activity of a radionuclide taken into the body in a given time period or as a result of a given event

[SOURCE: ISO 20553:2006, 3.10]

3.16 personal air monitor personal air sampler breathing zone sampler

SIST EN ISO 16639:2019

3.17 https://standards.iteh.ai/catalog/standards/sist/96b5a960-768e-48e5-b77e-

personal protective equipment 0b5823a94c8e/sist-en-iso-16639-2019

PPE

equipment designed to limit worker exposure to contaminants in the air or that are easily resuspended from contaminated surfaces

Note 1 to entry: Includes partial or full-face respirators, face masks, gloves, boots, whole body anti-contamination coveralls, and self-contained breathing apparatus (SCBA), depending on conditions.

3.18 potential missed exposure

PME

time-integrated activity concentration or maximum activity concentration, as applicable, that can acceptably be missed

Note 1 to entry: The detection limit of the method of measuring the activity concentration shall be less than or equal to the selected PME, which is defined according to ALARA/ALARP principles, and below legal limits.

3.19

sampling

collection of a radioactive substance on media such as filters, absorbers or adsorbers that is analysed for radioactive content after collection

3.20

standard reference conditions

conditions of temperature and pressure to which measurements are referred for standardization

Note 1 to entry: For this document, the standard reference conditions are 25 °C temperature and 101 325 Pa pressure.

Note 2 to entry: Used to convert air densities to a common basis. Other temperature and pressure conditions may be used and should be applied consistently.

3.21

surveillance

air monitoring and sampling, and the evaluation of the activity concentration measurement

4 Symbols

- A activity, in Bq
- *C* activity concentration, defined as activity per volume, in $Bq \cdot m^{-3}$
- *D*_a aerodynamic aerosol particle diameter, in μm
- $E(\tau)$ committed effective dose, in Sv
- e_{inh} dose coefficient for inhalation, in Sv·Bq⁻¹ (committed effective dose per unit intake such as those in Reference [9])
- *L* annual dose limit, in Sv (an annual limit on the total effective dose equivalent to an individual)
- *q* flowrate, in $m^3 \cdot s^{-1}$ or $m^3 \cdot h^{-1}$
- $Q_{\rm B}$ breathing rate, in m³·s⁻¹ or m³·h⁻¹ DARD PREVIEW
- $R_{\rm N}$ net count rate from the assay system, in s⁻¹
- $T_{\rm E}$ annual exposure time, in s
- <u>SIST EN ISO 16639:2019</u>
- $T_{\rm S}$ sampling time span, in s_{ch} ai/catalog/standards/sist/96b5a960-768e-48e5-b77e-
- $\varepsilon_{\rm C}$ collection efficiency 0b5823a94c8e/
- ϵ_r counting (measurement) efficiency of the assay system for a reference standard, in Bq^-1 \cdot s^{-1}
- $\varepsilon_{\rm S}$ efficiency modification factor for counting (measuring) an actual sample as opposed to the reference standard (e.g. the dimensionless alpha self-absorption factor for particulate alpha on glass fiber filters)

5 Developing the surveillance program

5.1 Reasons for conducting a surveillance programme

5.1.1 General

The specific techniques used in a sampling or surveillance program are based on the purpose(s) of the sampling. Even if airborne concentrations are very low, sampling may be conducted routinely due to the potential for high exposures and doses, should releases occur (e.g. in facilities with glove boxes). Sampling in the workplace can be used to determine the following parameters:

effectiveness of engineering and administrative controls for the confinement of radioactive substances;