
Postopki preskušanja optičnega komunikacijskega podsistema - 4-5. del: Vgrajene žične oblike - Izvedba atenuacije merilne naprave z optičnimi kabli, ki se konča z MPO, z uporabo preskusne opreme z vmesniki MPO (IEC 61280-4-5:2020)

Fibre-optic communication subsystem test procedures - Part 4-5: Installed cabling plant - Attenuation measurement of MPO terminated fibre optic cabling plant using test equipment with MPO interfaces (IEC 61280-4-5:2020)

Prüfverfahren für Lichtwellenleiter-Kommunikationsuntersysteme - Teil 4-5: Installierte Kabelanlagen - Dämpfungsmessung an Lichtwellenleiter-Kabelanlagen mit MPO-Abschlüssen mittels Prüfeinrichtungen mit MPO-Steckgesichtern (IEC 61280-4-5:2020)

Procédures d'essai des sous-systèmes de télécommunication fibroniques - Partie 4-5: Installation câblée - Mesure de l'affaiblissement de l'installation câblée fibronique à terminaisons MPO utilisant un équipement d'essai avec interfaces MPO (IEC 61280-4-5:2020)

Ta slovenski standard je istoveten z: EN IEC 61280-4-5:2020

ICS:

33.180.01	Sistemi z optičnimi vlakni na splošno	Fibre optic systems in general
-----------	---------------------------------------	--------------------------------

SIST EN IEC 61280-4-5:2020 en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN IEC 61280-4-5:2020](https://standards.iteh.ai/catalog/standards/sist/407a9866-efae-4e10-af76-1ad6e26d2a12/sist-en-iec-61280-4-5-2020)

<https://standards.iteh.ai/catalog/standards/sist/407a9866-efae-4e10-af76-1ad6e26d2a12/sist-en-iec-61280-4-5-2020>

EUROPEAN STANDARD

EN IEC 61280-4-5

NORME EUROPÉENNE

EUROPÄISCHE NORM

September 2020

ICS 33.180.01

English Version

Fibre-optic communication subsystem test procedures - Part 4-5:
Installed cabling plant - Attenuation measurement of MPO
terminated fibre optic cabling plant using test equipment with
MPO interfaces
(IEC 61280-4-5:2020)

Procédures d'essai des sous-systèmes de
télécommunication fibroniques - Partie 4-5: Installation
câblée - Mesure de l'affaiblissement de l'installation câblée
fibronique à terminaisons MPO utilisant un équipement
d'essai avec interfaces MPO
(IEC 61280-4-5:2020)

Prüfverfahren für Lichtwellenleiter-
Kommunikationsuntersysteme - Teil 4-5: Installierte
Kabelanlagen - Dämpfungsmessung an Lichtwellenleiter-
Kabelanlagen mit MPO-Abschlüssen mittels
Prüfeinrichtungen mit MPO-Steckgesichtern
(IEC 61280-4-5:2020)

iTeh STANDARD PREVIEW
(standards.iteh.ai)

This European Standard was approved by CENELEC on 2020-08-26. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

<https://standards.iteh.ai/catalog/standards/sist/407a9866-efae-4e10-af76-416c2321a50a/iec-61280-4-5:2020>

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN IEC 61280-4-5:2020 (E)**European foreword**

The text of document 86C/1669/FDIS, future edition 1 of IEC 61280-4-5, prepared by SC 86C "Fibre optic systems and active devices" of IEC/TC 86 "Fibre optics" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61280-4-5:2020.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2021-05-26
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2023-08-26

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice**iTeh STANDARD PREVIEW**

The text of the International Standard IEC 61280-4-5:2020 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60793-1-40	NOTE	Harmonized as EN IEC 60793-1-40
IEC 60793-2	NOTE	Harmonized as EN 60793-2
IEC 60793-2-10	NOTE	Harmonized as EN IEC 60793-2-10
IEC 60793-2-50	NOTE	Harmonized as EN IEC 60793-2-50
IEC 60876-1:2014	NOTE	Harmonized as EN 60876-1:2014 (not modified)
IEC 61280-4-2	NOTE	Harmonized as EN 61280-4-2
IEC 61300-3-6	NOTE	Harmonized as EN 61300-3-6
IEC 61300-3-45	NOTE	Harmonized as EN 61300-3-45
IEC 61745	NOTE	Harmonized as EN 61745
IEC 61754-7 (series)	NOTE	Harmonized as EN IEC 61754-7 (series)
IEC 61755-3-31	NOTE	Harmonized as EN 61755-3-31

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60825	series	Safety of laser products	EN 60825	series
IEC 61280-1-3	-	Fibre optic communication subsystem test procedures - Part 1-3: General communication subsystems - Central wavelength and spectral width measurement	EN 61280-1-3	-
IEC 61280-4-1	2019	Fibre-optic communication subsystem test procedures - Part 4-1: Installed cabling plant - Multimode attenuation measurement	EN IEC 61280-4-1	2019
IEC 61300-3-35	-	Fibre optic interconnecting devices and passive components - Basic test and measurement procedures - Part 3-35: Examinations and measurements - Visual inspection of fibre optic connectors and fibre-stub transceivers	EN 61300-3-35	-
IEC 61315	-	Calibration of fibre-optic power meters	EN IEC 61315	-
IEC 61746-1	-	Calibration of optical time-domain reflectometers (OTDR) - Part 1: OTDR for single mode fibres	EN 61746-1	-
IEC 61746-2	-	Calibration of optical time-domain reflectometers (OTDR) - Part 2: OTDR for multimode fibres	EN 61746-2	-

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN IEC 61280-4-5:2020](https://standards.iteh.ai/catalog/standards/sist/407a9866-efae-4e10-af76-1ad6e26d2a12/sist-en-iec-61280-4-5-2020)

<https://standards.iteh.ai/catalog/standards/sist/407a9866-efae-4e10-af76-1ad6e26d2a12/sist-en-iec-61280-4-5-2020>



IEC 61280-4-5

Edition 1.0 2020-07

INTERNATIONAL STANDARD



**Fibre-optic communication subsystem test procedures –
Part 4-5: Installed cabling plant – Attenuation measurement of MPO terminated
fibre optic cabling plant using test equipment with MPO interfaces**

SIST EN IEC 61280-4-5:2020

<https://standards.iteh.ai/catalog/standards/sist/407a9866-efae-4e10-af76-1ad6e26d2a12/sist-en-iec-61280-4-5-2020>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.180.01

ISBN 978-2-8322-8670-8

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	7
1 Scope.....	9
2 Normative references	9
3 Terms, definitions, graphical symbols and abbreviated terms.....	10
3.1 Terms and definitions.....	10
3.2 Graphical symbols	12
3.3 Abbreviated terms.....	14
4 Test methods.....	14
4.1 General.....	14
4.2 Cabling configurations and applicable test methods	15
5 Overview of uncertainties	16
5.1 General.....	16
5.2 Sources of significant uncertainties.....	16
5.3 Consideration of the PM.....	17
5.4 Consideration of test cord connector grade	17
5.5 Typical uncertainty values for multimode testing	17
5.6 Typical uncertainty values for single-mode testing	19
6 Apparatus.....	20
6.1 General.....	20
6.2 Light source	20
6.2.1 General	20
6.2.2 Stability	20
6.2.3 Spectral characteristics (LSPM measurement).....	21
6.3 Launch cord.....	21
6.4 Receive or tail cord.....	22
6.5 Substitution cord.....	22
6.6 Adapter cord	23
6.7 Power meter – LSPM methods only.....	23
6.8 OTDR apparatus.....	24
6.9 Connector end face cleaning and inspection equipment	24
6.10 Adapters	24
7 Procedures.....	24
7.1 General.....	24
7.2 Common procedures.....	25
7.2.1 Care of the test cords	25
7.2.2 Take reference measurements.....	25
7.2.3 Inspect and clean the ends of the optical fibres in the cabling.....	25
7.2.4 Take the measurements	25
7.2.5 Make the calculations	25
7.2.6 Multi-fibre and bi-directional testing	25
7.3 Calibration	26
7.4 Safety	26
8 Calculations.....	26
9 Documentation	26
9.1 Information for each test	26
9.2 Information to be available	26

Annex A (normative) One-cord method	27
A.1 Applicability of the test method	27
A.2 Apparatus	27
A.3 Procedure for unpinned to unpinned cabling with unpinned power meter.....	27
A.4 Procedure for unpinned to pinned cabling with unpinned power meter	28
A.5 Procedure for pinned to pinned cabling with pinned power meter	29
A.6 Procedure for unpinned to unpinned cabling with pinned power meter and gender-neutral test cord	30
A.7 Calculation.....	31
A.8 Components of reported attenuation	31
Annex B (normative) Three-cord method.....	32
B.1 Applicability of the test method	32
B.2 Apparatus	32
B.3 Procedure for unpinned to unpinned cabling	32
B.4 Procedure for unpinned to pinned cabling	33
B.5 Procedure for pinned to pinned cabling	34
B.6 Procedure, channel test (general)	35
B.7 Calculations	36
B.8 Components of reported attenuation	36
Annex C (normative) Adapter-cord method	37
C.1 Applicability of the test method	37
C.2 Apparatus	37
C.3 Procedure for unpinned to unpinned cabling with pinned power meter	37
C.4 Procedure for unpinned to pinned cabling with pinned power meter	38
C.5 Procedure for pinned to unpinned cabling with unpinned power meter	39
C.6 Procedure for pinned to pinned cabling with unpinned power meter	40
C.7 Calculations	41
C.8 Components of reported attenuation	42
Annex D (normative) Equipment cord method	43
D.1 Applicability of the test method	43
D.2 Apparatus	43
D.3 Procedure	43
D.4 Calculation.....	44
D.5 Components of reported attenuation	44
D.6 Typical uncertainty values.....	45
Annex E (normative) Optical time domain reflectometer	46
E.1 Applicability of the test method	46
E.2 Apparatus	46
E.2.1 General	46
E.2.2 OTDR	46
E.2.3 Test cords	47
E.3 Procedure (test method)	47
E.4 Calculation.....	48
E.4.1 General	48
E.4.2 Connection location	48
E.4.3 Definition of the power levels F_1 and F_2	49
E.4.4 Alternative calculation.....	50
E.5 OTDR uncertainties	52

Annex F (normative) Requirements for the multimode source characteristics	53
Annex G (informative) OTDR configuration information	54
G.1 General.....	54
G.2 Other measurement configurations	54
G.2.1 General	54
G.2.2 Measurement with low return loss connectors or short length cabling	54
G.2.3 Measurement with APC connectors	56
Annex H (informative) Test cord, breakout cord, and cassette attenuation verification	58
H.1 General.....	58
H.2 Apparatus	58
H.3 General procedure	58
H.3.1 Overview	58
H.3.2 Test cord verification	59
H.3.3 Cassette and breakout cord verification	60
H.4 Test cord verification prior to cabling measurement	61
H.4.1 General	61
H.4.2 Procedure for unpinned to unpinned cabling measurement	61
H.4.3 Procedure for unpinned to pinned cabling measurement.....	62
H.4.4 Procedure for pinned to pinned cabling measurement.....	63
Annex I (normative) On the use of low attenuation grade test cords.....	66
I.1 General.....	66
I.2 Practical configurations and assumptions.....	66
I.2.1 Component specifications.....	66
I.2.2 Conventions	67
I.2.3 Reference planes	67
I.3 Impact of using low attenuation grade test cords for recommended LSPM methods.....	68
I.4 Examples for LSPM measurements.....	68
I.4.1 Example 1: Configuration Au-u, 1-C method (Annex A).....	68
I.4.2 Example 2: Configuration Du-u, EC method (Annex D)	69
I.5 Impact of using reference grade test cords for different configurations using the OTDR test method	69
I.5.1 Cabling configurations Au-u, Ap-u and Ap-p	69
I.5.2 Cabling configuration Du-u	70
Bibliography.....	72
Figure 1 – Connector and apparatus symbols	13
Figure 2 – Symbol for cabling under test.....	14
Figure 3 – OTDR schematic with external optical switch	24
Figure A.1 – Reference measurement for unpinned to unpinned cabling using unpinned power meter.....	28
Figure A.2 – Test measurement for unpinned to unpinned cabling using unpinned power meter.....	28
Figure A.3 – Reference measurement for unpinned to pinned cabling using unpinned power meter.....	29
Figure A.4 – Test measurement for unpinned to pinned cabling using unpinned power meter.....	29
Figure A.5 – Reference measurement for pinned to pinned cabling using pinned power meter.....	30

Figure A.6 – Test measurement for pinned to pinned cabling using pinned power meter	30
Figure A.7 – Reference measurement for unpinned to unpinned cabling using pinned power meter	31
Figure A.8 – Test measurement for unpinned to unpinned cabling (gender-neutral TC1) using pinned power meter	31
Figure B.1 – Reference measurement for unpinned to unpinned cabling using pinned power meter	33
Figure B.2 – Test measurement for unpinned to unpinned cabling using pinned power meter	33
Figure B.3 – Reference measurement for unpinned to pinned cabling using pinned power meter	34
Figure B.4 – Test measurement for unpinned to pinned cabling using pinned power meter	34
Figure B.5 – Reference measurement for pinned to pinned cabling using unpinned power meter	35
Figure B.6 – Test measurement for pinned to pinned cabling using unpinned power meter	35
Figure B.7 – Reference measurement for channel test using unpinned power meter	36
Figure B.8 – Test measurement for channel test using unpinned power meter	36
Figure C.1 – Reference measurement for unpinned to unpinned cabling using pinned power meter	38
Figure C.2 – Test measurement for unpinned to unpinned cabling using pinned power meter	38
Figure C.3 – Reference measurement for unpinned to pinned cabling using pinned power meter	39
Figure C.4 – Test measurement for unpinned to pinned cabling using pinned power meter	39
Figure C.5 – Reference measurement for unpinned to pinned cabling using unpinned power meter	40
Figure C.6 – Test measurement for unpinned to pinned cabling using unpinned power meter	40
Figure C.7 – Reference measurement for unpinned to pinned cabling using unpinned power meter	41
Figure C.8 – Test measurement for unpinned to pinned cabling using unpinned power meter	41
Figure D.1 – Reference measurement using pinned power meter	44
Figure D.2 – Test measurement using pinned power meter	44
Figure E.1 – OTDR method	48
Figure E.2 – Location of the ports of the cabling under test	49
Figure E.3 – Graphic construction of F_1 and F_2	50
Figure E.4 – Graphic construction of F_1 , F_{11} , F_{12} and F_2	51
Figure G.1 – Attenuation measurement with low return loss connectors	55
Figure G.2 – Attenuation measurement of a short length cabling	56
Figure G.3 – Attenuation measurement with APC MPO connections	57
Figure H.1 – Obtaining reference power level P_1	59
Figure H.2 – Obtaining power level P_2	59
Figure H.3 – Obtaining reference power level P_1	60

Figure H.4 – Obtaining power level P_2	60
Figure H.5 – Test measurement for unpinned to unpinned cabling	61
Figure H.6 – Step 1: obtaining reference power level P_1	61
Figure H.7 – Step 2: verification cords, obtaining power level P_2	62
Figure H.8 – Test measurement for unpinned to pinned cabling	62
Figure H.9 – Step 1: obtaining reference power level P_1	63
Figure H.10 – Step 2: obtaining power level P_2	63
Figure H.11 – Test measurement for pinned to pinned cabling	63
Figure H.12 – Step 1: obtaining reference power level P_1	64
Figure H.13 – Step 2: verification of cords, obtaining power level P_2	64
Figure H.14 – Step 3: verification of receive cord, obtaining power level P_3	65
Figure I.1 – Cabling configurations Au-u, Ap-u and Ap-p tested with OTDR method	70
Figure I.2 – Cabling configuration Du-u tested with OTDR method	71
Table 1 – Cabling configurations	16
Table 2 – Test methods and configurations	16
Table 3 – Measurements bias related to test cord connector grade	17
Table 4 – Uncertainty for a given attenuation at 850 nm using same photodetector	18
Table 5 – Uncertainty for a given attenuation at 850 nm using different photodetectors	19
Table 6 – Uncertainty for a given attenuation at 1 310 nm using same photodetector	19
Table 7 – Uncertainty for a given attenuation at 1 310 nm using different photodetectors	20
Table 8 – Spectral requirements	21
Table D.1 – Uncertainty for a given attenuation when equipment cord method is used	45
Table I.1 – Measurement bias adjustment when using low attenuation grade test cords	68
Table I.2 – Acceptance figure adjustment using low attenuation grade test cords – OTDR method	70

INTERNATIONAL ELECTROTECHNICAL COMMISSION

FIBRE-OPTIC COMMUNICATION SUBSYSTEM TEST PROCEDURES –**Part 4-5: Installed cabling plant –
Attenuation measurement of MPO terminated fibre
optic cabling plant using test equipment with MPO interfaces**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61280-4-5 has been prepared by subcommittee 86C: Fibre optic systems and active devices, of IEC technical committee 86: Fibre optics.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
86C/1669/FDIS	86C/1679/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

A list of all the parts in the IEC 61280 series, under the general title *Fibre-optic communication subsystem test procedures*, can be found on the IEC website.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN IEC 61280-4-5:2020

<https://standards.iteh.ai/catalog/standards/sist/407a9866-efae-4e10-af76-1ad6e26d2a12/sist-en-iec-61280-4-5-2020>

FIBRE-OPTIC COMMUNICATION SUBSYSTEM TEST PROCEDURES –

Part 4-5: Installed cabling plant – Attenuation measurement of MPO terminated fibre optic cabling plant using test equipment with MPO interfaces

1 Scope

This part of IEC 61280 is applicable to the measurement of attenuation and determination of polarity and length of installed multimode and single-mode optical fibre cabling plant, terminated with MPO connectors, using test equipment having an MPO interface. This cabling plant can include multimode or single-mode optical fibres, connectors, adapters, splices, and other passive devices. The cabling can be installed in a variety of environments including residential, commercial, industrial, and data centre premises, as well as outside plant environments.

In this document, the optical fibres that are addressed include sub-categories A1-OM_x, where $x = 2, 3, 4$ and 5 (50/125 μm) multimode optical fibres, as specified in IEC 60793-2-10, and category B-652 and B-657 (9/125 μm) single-mode optical fibres, as specified in IEC 60793-2-50. The attenuation measurements of the other multimode and single-mode categories can also be made using a light source and power meter (LSPM) or optical time domain reflectometer (OTDR) utilising an internal or external optical switch having one MPO interface. Multimode measurements are made with an 850 nm source because transceivers used for parallel optics applications having an MPO interface only operate at 850 nm; 1 300 nm measurements are optional. Single-mode measurements are made with a 1 310 nm and/or 1 550 nm source because transceivers used for parallel optics applications having an MPO interface operate at these wavelengths. This document does not include descriptions of cabling that is not exclusively MPO to MPO.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60825 (all parts), *Safety of laser products*

IEC 61280-1-3, *Fibre optic communication subsystem test procedures – Part 1-3: General communication subsystems – Central wavelength and spectral width measurement*

IEC 61280-4-1:2019, *Fibre-optic communication subsystem test procedures – Part 4-1: Installed cabling plant – Multimode attenuation measurement*

IEC 61300-3-35, *Fibre optic interconnecting devices and passive components – Basic test and measurement procedures – Part 3-35: Examinations and measurements – Visual inspection of fibre optic connectors and fibre-stub transceivers*

IEC 61315, *Calibration of fibre-optic power meters*

IEC 61746-1, *Calibration of optical time-domain reflectometers (OTDR) – Part 1: OTDR for single mode fibres*