



Designation: ~~C1281-99~~ Designation: **C 1281 – 03 (Reapproved 2009)**

Standard Specification for Preformed Tape Sealants for Glazing Applications¹

This standard is issued under the fixed designation C 1281; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This specification describes preformed tape sealants for use in glazing applications. These materials are generally used to serve as components of glazing systems. They are intended to serve as a water and air barrier.

1.2 This specification is not intended for preformed foam tape sealants.

1.3 The values stated in SI units are to be regarded as the standard. The values in parentheses are provided for information purposes only.

1.4

1.4 The subcommittee with jurisdiction is not aware of any similar ISO standard.

1.5 The following precautionary statement pertains only to the test method section of this specification. *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 *ASTM Standards:*²

C 717 Terminology of Building Seals and Sealants

C 765 Test Method for Low-Temperature Flexibility of Preformed Tape Sealants

C 771 Test Method for Weight Loss After Heat Aging of Preformed Tape Sealants

C 772 Test Method for Oil Migration or Plasticizer Bleed-Out of Preformed Tape Sealants

C 879 Test Methods for Release Papers Used with Preformed Tape Sealants

C 908 Test Method for Yield Strength of Preformed Tape Sealants

C 972 Test Method for Compression-Recovery of ~~Preformed Tape Sealants~~² Sealant

C 1016 Test Method for Determination of Water Absorption of Sealant Backing (Joint Filler) Material

C 1266 Test Method for Flow Characteristics of Preformed Tape Sealants

3. Terminology

3.1 *Definitions*—The definitions of the following terms used in this specification are found in Terminology C 717: compression seal, glazing, tape sealant.

4. Materials and Manufacturers

4.1 The preformed tape sealant shall be composed of appropriate raw materials to result in conformance to this specification.

4.2 The preformed tape sealant shall be of uniform dimensions and consistency.

4.3 When properly applied, this material shall form a seal to prevent air and water from entering the system.

5. Requirements

5.1 The tape sealant in the original unopened container shall meet the requirements of this specification and remain suitable for use for a minimum of 12 months from the date of manufacture when stored at a temperature of 26.6°C (80°F) maximum.

5.2 *Physical Properties*—The physical properties of the material shall conform to the requirements specified in Table 1.

¹This specification is under the jurisdiction of ASTM Committee C24 on Building Seals and Sealants and is the direct responsibility of Subcommittee C24.20 on General Sealant Standards.

Current edition approved Jan. 10, 1999. Published April 1999. Originally published as C 1281-94. Last previous edition C 1281-94.

²This specification is under the jurisdiction of ASTM Committee C24 on Building Seals and Sealants and is the direct responsibility of Subcommittee C24.10 on Specifications, Guides and Practices.

Current edition approved Jan. 1, 2009. Published March 2009. Originally approved in 1994. Last previous edition approved in 2003 as C 1281 – 03.

³For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* Vol 04.07 volume information, refer to the standard's Document Summary page on the ASTM website.