



SLOVENSKI STANDARD
SIST EN IEC 62351-8:2020

01-september-2020

Upravljanje elektroenergetskega sistema in pripadajoča izmenjava informacij - Varnost podatkov in komunikacij - 8. del: Kontrola dostopa do elektroenergetskega sistema na podlagi vlog

Power systems management and associated information exchange - Data and communications security - Part 8: Role-based access control for power system management

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN IEC 62351-8:2020](https://standards.iteh.ai/catalog/standards/sist/7a7f4d06-b7fc-451b-8e11-924fc71a164/sist-en-iec-62351-8-2020)

[https://standards.iteh.ai/catalog/standards/sist/7a7f4d06-b7fc-451b-8e11-](https://standards.iteh.ai/catalog/standards/sist/7a7f4d06-b7fc-451b-8e11-924fc71a164/sist-en-iec-62351-8-2020)

[924fc71a164/sist-en-iec-62351-8-2020](https://standards.iteh.ai/catalog/standards/sist/7a7f4d06-b7fc-451b-8e11-924fc71a164/sist-en-iec-62351-8-2020)

Ta slovenski standard je istoveten z: EN IEC 62351-8:2020

ICS:

29.240.30	Krmilna oprema za elektroenergetske sisteme	Control equipment for electric power systems
35.240.50	Uporabniške rešitve IT v industriji	IT applications in industry

SIST EN IEC 62351-8:2020

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN IEC 62351-8:2020](#)

<https://standards.iteh.ai/catalog/standards/sist/7a7f4d06-b7fc-451b-8e11-924fc71a164/sist-en-iec-62351-8-2020>

EUROPEAN STANDARD

EN IEC 62351-8

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2020

ICS 33.200

English Version

Power systems management and associated information
exchange - Data and communications security - Part 8: Role-
based access control for power system management
(IEC 62351-8:2020)

Gestion des systèmes de puissance et échanges
d'informations associés - Sécurité des communications et
des données - Partie 8: Contrôle d'accès basé sur les rôles
pour la gestion de systèmes de puissance
(IEC 62351-8:2020)

Energiemanagementsysteme und zugehöriger
Datenaustausch - IT-Sicherheit für Daten und
Kommunikation - Teil 8: Rollenbasierte Zugriffskontrolle für
Energiemanagementsysteme
(IEC 62351-8:2020)

This European Standard was approved by CENELEC on 2020-06-02. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN IEC 62351-8:2020 (E)**European foreword**

The text of document 57/2180/FDIS, future edition 1 of IEC 62351-8, prepared by IEC/TC 57 "Power systems management and associated information exchange" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62351-8:2020.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2021-03-02
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2023-06-02

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

iTeh STANDARD PREVIEW
Endorsement notice
(standards.iteh.ai)

The text of the International Standard IEC 62351-8:2020 was approved by CENELEC as a European Standard without any modification

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60870-5-104	NOTE	Harmonized as EN 60870-5-104
IEC 61784 (series)	NOTE	Harmonized as EN IEC 61784 (series)
IEC 61850-8-1	NOTE	Harmonized as EN 61850-8-1
IEC 61850-8-2	NOTE	Harmonized as EN IEC 61850-8-2
IEC 61968 (series)	NOTE	Harmonized as EN 61968 (series)
IEC 61970 (series)	NOTE	Harmonized as EN 61970 (series)
IEC 62351-7:2017	NOTE	Harmonized as EN 62351-7:2017 (not modified)
IEC 62351-9	NOTE	Harmonized as EN 62351-9
IEC 62351-14	NOTE	Harmonized as EN IEC 62351-14 ¹
IEC 62443 (series)	NOTE	Harmonized as EN IEC 62443 (series)

¹ To be published. Stage at the time of publication: prEN IEC 62351-14:2019.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61850-7-2	-	Communication networks and systems for power utility automation - Part 7-2: Basic information and communication structure - Abstract communication service interface (ACSI)	EN 61850-7-2	-
IEC/TS 62351-2	-	Power systems management and associated information exchange - Data and communications security - Part 2: Glossary of terms	-	-
IEC 62351-3	2014	Power systems management and associated information exchange - Data and communications security - Part 3: Communication network and system security - Profiles including TCP/IP	EN 62351-3	2014
+ A2	2020		+ A2	2020
IEC 62351-4	-	Power systems management and associated information exchange - Data and communications security - Part 4: Profiles including MMS and derivatives	EN IEC 62351-4	-
IEC/TS 62351-8	2011	Power systems management and associated information exchange - Data and communications security - Part 8: Role-based access control	-	-
RFC 2865	-	Remote Authentication Dial In User Service (RADIUS)	-	-
RFC 5246	-	The Transport Layer Security (TLS) Protocol Version 1.2	-	-

EN IEC 62351-8:2020 (E)

RFC 5288	-	AES Galois Counter Mode (GCM) Cipher Suites for TLS)	-	-
RFC 5289	-	TLS Elliptic Curve Cipher Suites with SHA-256/384 and AES Galois Counter Mode (GCM)	-	-
RFC 5755	-	An Internet Attribute Certificate Profile for Authorization	-	-
RFC 5878	-	Transport Layer Security (TLS) Authorization Extensions	-	-
RFC 6749	-	The OAuth 2.0 Authorization Framework	-	-
RFC 7519	-	JSON Web Token (JWT)	-	-
XACML-RBAC	2014	XACML v3.0 Core and Hierarchical Role Based Access Control (RBAC) Profile Version 1.0, October 2014.	-	-

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN IEC 62351-8:2020](https://standards.iteh.ai/catalog/standards/sist/7a7f4d06-b7fc-451b-8e11-924fc71a164/sist-en-iec-62351-8-2020)

<https://standards.iteh.ai/catalog/standards/sist/7a7f4d06-b7fc-451b-8e11-924fc71a164/sist-en-iec-62351-8-2020>



IEC 62351-8

Edition 1.0 2020-04

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Power systems management and associated information exchange – Data and communications security –
Part 8: Role-based access control for power system management**

**Gestion des systèmes de puissance et échanges d'informations associés –
Sécurité des communications et des données –
Partie 8: Contrôle d'accès basé sur les rôles pour la gestion de systèmes de puissance**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 33.200

ISBN 978-2-8322-8072-0

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	10
3 Terms and definitions	11
4 Abbreviated terms	13
5 RBAC process model.....	14
5.1 Overview of RBAC process model.....	14
5.2 Generic RBAC concepts	15
5.3 Separation of subjects, roles, and permissions	16
5.3.1 RBAC model.....	16
5.3.2 Subject assignment (subject-to-role mapping).....	18
5.3.3 Role assignment (role-to-permission mapping)	18
5.3.4 Permission assignment (mapping of actions to objects)	19
5.4 Criteria for defining roles.....	19
5.4.1 Policies.....	19
5.4.2 Subjects, roles, and permissions	19
5.4.3 Introducing roles reduces complexity	19
6 Definition of roles	20
6.1 Role-to-permission assignment inside the entity in general	20
6.1.1 General	20
6.1.2 Number of supported permissions by a role	20
6.1.3 Number of supported roles	20
6.1.4 Flexibility of role-to-permission mapping	20
6.2 Role-to-permission assignment with respect to power systems	20
6.2.1 Mandatory roles and permissions for IED access control	20
6.2.2 Power utility automation using IEC 61850	23
6.3 Role to permission assignment for specific roles.....	25
6.3.1 General	25
6.3.2 Encoding specific roles	25
6.3.3 Evaluation context	29
6.4 Role-to-permission assignment with respect to other non-power system domains (e.g. industrial process control).....	30
7 RBAC credential distribution using the PUSH model.....	30
7.1 General.....	30
7.2 Secure access to an LDAP-enabled repository.....	31
7.3 Secure access to an identity provider for retrieval of a JWT	31
8 RBAC credential distribution using the PULL model.....	32
8.1 General.....	32
8.2 Secure access to an LDAP-enabled repository.....	33
8.2.1 General	33
8.2.2 PULL model with LDAP	33
8.2.3 LDAP Directory organization.....	34
8.3 Secure access to the RADIUS-enabled repository.....	35
8.3.1 General	35
8.3.2 PULL model with RADIUS.....	35

8.3.3	RADIUS security applying transparent TLS protection	36
8.4	Secure access to the JWT provider.....	39
9	General application of RBAC access token (informative)	39
9.1	General.....	39
9.2	Session-based approach.....	40
9.3	Message-based approach	42
10	Definition of access tokens	42
10.1	General.....	42
10.2	Supported profiles.....	42
10.3	Identification of access token	42
10.4	General structure of the access tokens	43
10.4.1	Mandatory fields in the access tokens	43
10.4.2	Mandatory profile-specific fields.....	43
10.4.3	Optional fields in the access tokens	43
10.4.4	Definition of specific fields	44
10.5	Specific structure of the access tokens	47
10.5.1	Profile A: X.509 Public key certificate	47
10.5.2	Profile B: X.509 Attribute certificate	49
10.5.3	Profile C: JSON Web Token – JWT.....	52
10.5.4	Profile D: RADIUS token.....	54
11	Transport profiles	56
11.1	Usage in TCP-based protocols.....	56
11.2	Usage in non-Ethernet based protocols.....	57
12	Verification of access tokens	57
12.1	General.....	57
12.2	Multiple access token existence	57
12.3	Subject authentication.....	57
12.4	Access token availability	58
12.5	Validity period	58
12.6	Access token integrity	58
12.7	Issuer	58
12.8	RoleID	58
12.9	Revision number	59
12.10	Area of responsibility	59
12.11	Role definition.....	59
12.12	Revocation state	59
12.13	Operation.....	59
12.14	Sequence number.....	59
12.15	Revocation methods	60
12.15.1	General	60
12.15.2	Supported methods	60
13	Conformity.....	61
13.1	General.....	61
13.2	Notation.....	61
13.3	Conformance to access token format	61
13.4	Conformance to access token content.....	61
13.5	Access token distribution	61
13.6	Role information exchange.....	62

13.7	Mapping to existing authorization mechanisms.....	62
13.8	Security events	62
14	Repository interaction for the defined RBAC profiles	62
Annex A (informative)	Informative example for specific role definition	64
A.1	Scope of annex.....	64
A.2	Use case description.....	64
A.3	XACML definition example	64
A.4	Role description	65
A.5	Permission group description	66
A.6	Permission description	67
A.7	Request syntax for PDP	70
Bibliography	72
Figure 1	– Generic framework for access control	15
Figure 2	– Diagram of RBAC with static and dynamic separation of duty (enhanced version of [ANSI INCITS 359-2004]).....	16
Figure 3	– Subjects, roles, permissions, and operations.....	18
Figure 4	– XACML structure.....	26
Figure 5	– Schematic view of authorization mechanism based on RBAC	31
Figure 6	– Schematic view of authorization mechanism based on RBAC PULL model.....	33
Figure 7	– RBAC PULL model using LDAP	34
Figure 8	– RBAC PULL model using RADIUS.....	36
Figure 9	– RBAC model using OAuth2.0 and JWT.....	39
Figure 10	– Session based RBAC approach (simplified IEC 62351-4 end-to-end security).....	41
Table 1	– List of mandatory pre-defined permissions	21
Table 2	– Pre-defined roles.....	22
Table 3	– List of pre-defined role-to-permission assignment.....	23
Table 4	– LISTOBJECTS permission and associated ACSI services	24
Table 5	– Evaluation Context	29
Table 6	– Cipher suites combinations in the context of this document	37
Table 7	– Mandatory general access token components	43
Table 8	– Mandatory profile specific access token components.....	43
Table 9	– Optional access token components	43
Table 10	– AoR fields and format.....	46
Table 11	– Mapping between ID and Attribute Certificate	52
Table 12	– Conformance to access token format.....	61
Table 13	– Conformance to access token distribution	62
Table 14	– Profile comparison.....	63

Document history

Any person intervening in the present document is invited to complete the table below before sending the document elsewhere. The purpose is to allow all actors to see all changes introduced and the intervening persons.

Any important message to IEC editors should also be included in the table below.

Name of intervening person	Document received		Brief description of the changes introduced	Document sent	
	From	Date		To	Date
Steffen Fries	WG15	2017-03-01	Initial Version		
Steffen Fries	WG15	2017-05-30	Enhancement of OID, More details regarding the RADIUS profile. Clarification of relationship to PULL and PUSH models, which led to a re-write of the current description focussing solely on LDAP		
Steffen Fries	WG15	2017-07-28	Enhancement of the area of responsibility section. Standard of profile specific parameters in the access token.		
Frances Cleveland	Steffen Fries	2017-08-31	Editorial updates		2017-9-22
Steffen Fries	Frances Cleveland	2017-09-22	Further Updates of the RADIUS profile with an index option to allow for multiple roles per user with different AoR or Revision Deprecation of Profile C		
Steffen Fries		2017-11-22	Further description of Profile D and application integration examples. Deletion of existing Profile C		
Steffen Fries		2018-02-22	Update on RADIUS, inclusion of custom based role definition		
Steffen Fries		2018-04-30	Refinement of custom based role definition using XACML as proposed in IEC 62351-90-1		
Steffen Fries		2018-06-22	Aligned terminology of rights and permissions throughout the document, refinement of mandatory permissions, inclusion of JWT (based on the contribution of Arijit Bose) as Profile C. Introduction of security events (incidents and warnings) supporting IEC 62351-14.		
Martina Braun	Steffen Fries	2018-06-28	CD doc for circulation	CO	2018-06-28
Steffen Fries		2018-11-28	Incorporation of comment resolution (57/2056/CC) after WG15 meeting in 10/2018	WG15	2018-11-23
Steffen Fries		2018-01-17	Incorporation of final discussion of open issues after WG15 meeting in 01/2019	WG15	
Martina Braun	IEC	2019-05-17	Edited CDV to Project leader for next step	Steffen Fries	2019-05-20
Steffen Fries		2019-05-17	Incorporation of comment resolution for CDV after final discussion during web meeting in WG15 on July 1th, 2019 and discussion with IETF RADEST WG (alignment of port number assignment)	IEC	
Martina Braun	Steffen Fries	2019-08-16	FDIS document upload to IEC for circulation	IEC CO	2019-0-23

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**POWER SYSTEMS MANAGEMENT AND ASSOCIATED INFORMATION
EXCHANGE - DATA AND COMMUNICATIONS SECURITY –****Part 8: Role-based access control for power system management**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62351-8 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

The text of this standard is based on the following documents:

Enquiry draft	Report on voting
57/2180/FDIS	57/2197/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

Recipients of this document are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

This document includes code components i.e components that are intended to be directly processed by a computer. Such content is any text found between the markers <CODE BEGINS> and <CODE ENDS>, or otherwise is clearly labeled in this standard as a code component.

The purchase of this document carries a copyright license for the purchaser to sell software containing code components from this document directly to end users and to end users via distributors, subject to IEC software licensing conditions, which can be found at: <http://www.iec.ch/CCv1>.

In the case of any discrepancy between the document and the code components, the code components take precedence.

In this document, the following print types are used:

Encoding in ASN.1 or XACML: `couriernew`

A list of all the parts in the IEC 62351 series, published under the general title *Power systems management and associated information exchange*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN IEC 62351-8:2020](https://standards.iteh.ai/catalog/standards/sist/7a7f4d06-b7fc-451b-8e11-924fc71a164/sist-en-iec-62351-8-2020)
<https://standards.iteh.ai/catalog/standards/sist/7a7f4d06-b7fc-451b-8e11-924fc71a164/sist-en-iec-62351-8-2020>

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This document provides a standard for access control in power systems. The power system environment supported by this document is enterprise-wide and extends beyond traditional borders to include external providers, suppliers, and other energy partners. Driving factors are the liberalization of the energy sector to include many more stakeholders, the increasingly decentralized generation of energy, and the need to control access to sensitive data of resources and stakeholders. This document supports a distributed security environment in which security is also a distributed service.

The power system sector is continually improving the delivery of energy by leveraging technical advances in computer-based applications. Utility operators, energy brokers and end-users are increasingly accessing multiple applications to deliver, transmit and consume energy in a personalized way. These disparate applications are naturally connected to a common network infrastructure that typically supports protection equipment, substation automation protocols, inter-station protocols, remote access and business-to-business services. Consequently, secure access to these distributed and often loosely coupled applications is even more important than access to an application running on a stand-alone device.

Secure access to computer-based applications involves authentication of the user to the application. After authentication, the types of interactions which that user can perform with the application is then determined. The use of local mechanisms for authorization creates a patchwork of approaches difficult to uniformly administer across the breadth of a power system enterprise. Each application decides with its own logic the authorization process. However, if applications can use a network to help manage access, a database can serve as a trusted source of user's group or role affiliation. Thus, the access to a shared user base can be controlled centrally. Each application can then examine the permissions listed for a subject and corresponding role and determine their level of authorization.

This document defines role-based access control (RBAC) for enterprise-wide use in power systems. It supports a distributed or service-oriented architecture where security is a distributed service and applications are consumers of distributed services.

In this document, the role of a user is transported in a container called an "access token" of that user to the object. Access tokens are created and administered by a (possibly federated) identity management tool. All access tokens have a lifetime and are subject to expiration. Prior to verification of the access token itself, the user transmitting the access token is authenticated by the object. The object trusts the management tool to issue access tokens with suitable lifetime. This enables local verification of the access token's validity at remote sites without the need to access a centralized repository (e.g. a centralized revocation list).

Four different access token formats are supported as four different profiles. Two of them are based on X.509 certificates and were already defined in IEC TS 62351-8. Two new profiles are defined as part of this document. The first new profile uses the JSON to encode the access token and the second new profile uses a vendor specific attribute in RADIUS to provide a migration option for environments already utilizing a RADIUS server to support access control. These access tokens may be bound to a specific transport or to a specific application. Common to all access token formats is the information contained, to allow a migration from one profile to another.

POWER SYSTEMS MANAGEMENT AND ASSOCIATED INFORMATION EXCHANGE - DATA AND COMMUNICATIONS SECURITY –

Part 8: Role-based access control for power system management

1 Scope

The scope of this part of IEC 62351 is to facilitate role-based access control (RBAC) for power system management. RBAC assigns human users, automated systems, and software applications (collectively called "subjects" in this document) to specified "roles", and restricts their access to only those resources, which the security policies identify as necessary for their roles.

As electric power systems become more automated and cyber security concerns become more prominent, it is becoming increasingly critical to ensure that access to data (read, write, control, etc.) is restricted. As in many aspects of security, RBAC is not just a technology; it is a way of running a business. RBAC is not a new concept; in fact, it is used by many operating systems to control access to system resources. Specifically, RBAC provides an alternative to the all-or-nothing super-user model in which all subjects have access to all data, including control commands.

RBAC is a primary method to meet the security principle of least privilege, which states that no subject should be authorized more permissions than necessary for performing that subject's task. With RBAC, authorization is separated from authentication. RBAC enables an organization to subdivide super-user capabilities and package them into special user accounts termed roles for assignment to specific individuals according to their associated duties. This subdivision enables security policies to determine who or what systems are permitted access to which data in other systems. RBAC provides thus a means of reallocating system controls as defined by the organization policy. In particular, RBAC can protect sensitive system operations from inadvertent (or deliberate) actions by unauthorized users. Clearly RBAC is not confined to human users though; it applies equally well to automated systems and software applications, i.e., software parts operating independent of user interactions.

The following interactions are in scope:

- local (direct wired) access to the object by a human user, a local and automated computer agent, or a built-in HMI or panel;
- remote (via dial-up or wireless media) access to the object by a human user;
- remote (via dial-up or wireless media) access to the object by a remote automated computer agent, e.g. another object at another substation, a distributed energy resource at an end-user's facility, or a control centre application.

While this document defines a set of mandatory roles to be supported, the exchange format for defined specific or custom roles is also in scope of this document.

Out of scope for this document are all topics which are not directly related to the definition of roles and access tokens for local and remote access, especially administrative or organizational tasks, such as:

- user names and password definitions/policies;
- management of keys and/or key exchange;
- engineering process of roles;
- assignment of roles;
- selection of trusted certificate authorities issuing credentials (access tokens);