



SLOVENSKI STANDARD
SIST ISO 13344:2018

01-september-2018

Nadomešča:
SIST ISO 13344:1999

Določevanje smrtne toksičnosti dima

Estimation of the lethal toxic potency of fire effluents

iTeh STANDARD PREVIEW
Détermination du pouvoir toxique létal des effluents du feu
(standards.iteh.ai)

Ta slovenski standard je istoveten z: ~~SIST ISO 13344:2015~~ ISO 13344:2015

<https://standards.iteh.ai/catalog/standards/sist/9975673b-9334-4997-81f3-d87034d69a/sist-iso-13344-2018>

ICS:

13.220.99	Drugi standardi v zvezi z varstvom pred požarom	Other standards related to protection against fire
-----------	---	--

SIST ISO 13344:2018

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST ISO 13344:2018

<https://standards.iteh.ai/catalog/standards/sist/9975673b-9334-4997-81f3-f9d87034d69a/sist-iso-13344-2018>

INTERNATIONAL
STANDARD

ISO
13344

Third edition
2015-12-15

**Estimation of the lethal toxic potency
of fire effluents**

Détermination du pouvoir toxique létal des effluents du feu

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST ISO 13344:2018

<https://standards.iteh.ai/catalog/standards/sist/9975673b-9334-4997-81f3-f9d87034d69a/sist-iso-13344-2018>



Reference number
ISO 13344:2015(E)

© ISO 2015

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST ISO 13344:2018

<https://standards.iteh.ai/catalog/standards/sist/9975673b-9334-4997-81f3-f9d87034d69a/sist-iso-13344-2018>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2015, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents		Page
Foreword		iv
Introduction		v
1 Scope		1
2 Normative references		1
3 Terms and definitions		1
4 Principle		2
5 Significance and use		2
6 Apparatus		3
6.1 Physical fire model.....		3
6.2 Gas sampling.....		3
7 Hazards		4
8 Test specimens		4
9 Calibration of the apparatus		4
10 Procedures		4
10.1 General.....		4
10.2 Preparation for tests.....		5
10.3 Test procedure for obtaining data.....		5
11 Calculations		5
11.1 General.....		5
11.2 Calculation of FED.....		5
11.3 Calculation of predicted LC ₅₀		7
12 Test report		8
13 Precision and bias		9
Annex A (informative) Optional bioassay for confirmation of predicted LC₅₀ values		10
Bibliography		13

ISO 13344:2015(E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 92, *Fire safety*, Subcommittee SC 3, *Fire threat to people and environment*.

This third edition cancels and replaces the second edition (ISO 13344:2004), which has been technically revised. The following changes have been made:

- ISO 19702 has been added as a normative reference and citations added in [6.2.3](#) and [9.2.2](#);
- the first paragraph in [4.3](#) has been deleted;
- the note in [13.2](#) has been deleted.

Introduction

The pyrolysis or combustion of every combustible material produces a fire effluent atmosphere, which, in sufficiently high concentration, is toxic. It is, therefore, desirable to establish a standard test method for the estimation of the toxic potency of such fire effluents.

It is further desirable, in view of worldwide resistance to the exposure of animals in standard tests, that this method should not make mandatory the use of such animals in its procedures. The mandatory portion of this standard test does not, therefore, specify the use of animal exposures. It only refers to animal exposure data already reported in the literature, with calculations being employed to express test results as they would have been obtained had animals actually been employed.

For those cases in which confirmation of test results using animal exposures can be justifiably permitted, an optional procedure to do so is presented in [Annex A](#).

The two parameters calculated using this standard are the FED (Fractional Effective Dose) and the LC₅₀. When either of these is used in performing a hazard analysis, certain information must accompany the term to avoid confusion. In the case of the FED, that is the toxicological effect on which the FED is based and the animal species for which the FED has been determined. In the case of the LC₅₀, that information is the length of the exposure and the animal species for which the LC₅₀ has been determined.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST ISO 13344:2018](#)

<https://standards.iteh.ai/catalog/standards/sist/9975673b-9334-4997-81f3-f9d87034d69a/sist-iso-13344-2018>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST ISO 13344:2018

<https://standards.iteh.ai/catalog/standards/sist/9975673b-9334-4997-81f3-f9d87034d69a/sist-iso-13344-2018>

Estimation of the lethal toxic potency of fire effluents

1 Scope

This International Standard provides a means for estimating the lethal toxic potency of the fire effluent produced from a material while exposed to the specific combustion conditions of a physical fire model. The lethal toxic potency values are specifically related to the fire model selected, the exposure scenario and the material evaluated.

Lethal toxic potency values associated with 30-min exposures of rats are predicted using calculations which employ combustion atmosphere analytical data for carbon monoxide (CO), carbon dioxide (CO₂), oxygen (O₂) (vitiation) and, if present, hydrogen cyanide (HCN), hydrogen chloride (HCl), hydrogen bromide (HBr), hydrogen fluoride (HF), sulfur dioxide (SO₂), nitrogen dioxide (NO₂), acrolein and formaldehyde. The chemical composition of the test specimen may suggest additional combustion products to be quantified and included. If the fire effluent toxic potency cannot be attributed to the toxicants analysed ([Annex A](#)), this is an indication that other toxicants or factors must be considered.

This International Standard is applicable to the estimation of the lethal toxic potency of fire effluent atmospheres produced from materials, products or assemblies under controlled laboratory conditions and should not be used in isolation to describe or appraise the toxic hazard or risk of materials, products or assemblies under actual fire conditions. However, results of this test may be used as elements of a fire hazard assessment that takes into account all of the factors which are pertinent to an assessment of the fire hazard of a particular end use; see ISO 19706.

The intended use of fire safety-engineering calculations is for life-safety prediction for people and is most frequently for time intervals somewhat shorter than 30 min. This extrapolation across species and exposure intervals is outside the scope of this International Standard.

This International Standard does not purport to address all of the safety problems associated with its use. It is the responsibility of the user of this International Standard to establish appropriate safety and health practices.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 13571, *Life-threatening components of fire — Guidelines for the estimation of time to compromised tenability in fires*

ISO 13943:2008, *Fire safety — Vocabulary*

ISO 19701, *Methods for sampling and analysis of fire effluents*

ISO 19702, *Guidance for sampling and analysis of toxic gases and vapours in fire effluents using Fourier transform infrared (FTIR) spectroscopy*

ISO 19706, *Guidelines for assessing the fire threat to people*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 13943:2008 apply.

ISO 13344:2015(E)

4 Principle

4.1 This method subjects a test sample to the combustion conditions of a specific physical fire model.

Concentrations of the major gaseous toxicants in the fire effluent atmosphere are monitored over a 30-min period, with $(C \cdot t)$ products for each interval being determined from integration of the areas under the respective concentration vs time plots. The $(C \cdot t)$ product data, along with either the mass charge or the mass loss of the test sample during the test, are then used in calculations to predict the 30-min LC_{50} of the test sample.

4.2 Since there can be toxicants present other than those measured, this value of the LC_{50} is a maximum.

If the chemical formulation and professional experience suggest that additional toxicants might contribute significantly to the LC_{50} value, the accuracy of the predicted LC_{50} may then be experimentally determined using a bioassay (see [Annex A](#)). Agreement within the experimental uncertainty supports attributing the lethality of the smoke to the monitored toxicants.

4.3 Toxic potencies are estimated from combustion product analytical data without the exposure of experimental animals. Such a methodology is based on extensive experimentation using exposure of rats to the common fire gases, both singly and in combinations; see Reference[1]. The principle can be expressed mathematically, as shown in Formula (1); see Reference[2]:

$$L_{\text{FED}} = \sum_{i=1}^n \int_0^t \frac{C_i}{(C \cdot t)_i} dt \quad (1)$$

where

C_i is the concentration, expressed in microlitres per litre, of the toxic component, i ;

$(C \cdot t)_i$ is the concentration-time product, expressed in microlitres per litre times minutes, for the specific exposure doses required to produce the toxicological effect.

When, as in this test method, the time values of 30 min numerically cancel, the FED becomes simply the ratio of the average concentration of a gaseous toxicant to its LC_{50} value for the same exposure time. When the FED is equal to 1, the mixture of gaseous toxicants should be lethal to 50 % of exposed animals.

5 Significance and use

5.1 This test method has been designed to provide data for use in the estimation of lethal toxic fire hazard as a means for the evaluation of materials and products and to assist in their research and development.

The data are not, in themselves, an indication of toxic hazard or relative toxic hazard of a commercial product.

5.2 The method is used to predict the LC_{50} of fire effluents produced upon exposure of a material or product to fire.

Experimental confirmation might be needed to determine whether the major gaseous toxicants can account for the observed toxic effects as well as for the lethal toxic potency (see [Annex A](#)).

5.3 Predicted LC_{50} values determined in this test method are associated only with the physical fire model used.

5.4 This test method does not attempt to address the toxicological significance of changes in particulate/aerosol size, fire effluent transport, distribution or deposition, or changes in the concentration of any fire effluent constituent as a function of time as may occur in a real fire.

5.5 The propensity for fire effluents from any material to have the same effects on humans as on rats in fire situations can only be inferred to the extent that the biological system of the rat is correlated with the human system.

5.6 This test method does not address any other acute sublethal effects of smoke, e.g. sensory and upper-respiratory-tract irritation, reduced motor capability, heat or thermal radiation injury, etc.

5.7 This test method does not address the long-term lethal effects of smoke exposure or the lethal effects of chronic exposures to smoke.

5.8 The FED values, L_{FED} , estimated from this method differ from those obtained using the equations in ISO 13571. The values obtained here are derived from rat lethality data. The FED values from ISO 13571 are derived from consensus estimates of the incapacitating effects of fire gases on people.

6 Apparatus

6.1 Physical fire model

6.1.1 The physical fire model, or laboratory combustion device, and the conditions under which it is operated shall be chosen so as to have demonstrated relevance to one or more of the specific classes or stages of fires identified and characterized in ISO 19706.

6.1.2 When obtaining data on the effluent from the combustion of a commercial product or assembly, i.e. other than a homogeneous material, the configuration and condition of the test specimen in the physical fire model shall be relevant to the appropriate fire exposure of the commercial product or assembly.

6.1.3 Repeatability and interlaboratory reproducibility of the physical fire model shall be demonstrated to be within the uncertainty range for the FED calculations for irritant and asphyxiant gases in ISO 13571.

6.1.4 The physical fire model shall be adaptable to analytical requirements.

6.2 Gas sampling

6.2.1 Continuous gas sampling shall be used to measure CO, CO₂ and O₂ levels.

6.2.2 The gas analysers shall have the following ranges, as a minimum:

- carbon monoxide, 0 % by volume to 1 % by volume (0 µl/l to 10 000 µl/l);
- carbon dioxide, 0 % by volume to 10 % by volume (0 µl/l to 100 000 µl/l);
- oxygen, 0 % by volume to 21 % by volume (0 µl/l to 210 000 µl/l).

6.2.3 Other gas analyses (for example, for HCN, HCl, HBr, NO_x, SO₂, acrolein, formaldehyde and other chemical species) shall be performed, as appropriate to the chemical composition of the test sample and/or expectation of potential combustion products, by a method of choice with guidance from ISO 19701 and ISO 19702.