

SLOVENSKI STANDARD

SIST EN 15004-4:2020

01-december-2020

Nadomešča:

SIST EN 15004-4:2008

Vgrajeni gasilni sistemi - Sistemi za gašenje s plinom - 4. del: Fizikalne lastnosti in načrtovanje sistema za gašenje s plinom za gasilo HFC 125 (ISO 14520-8:2019, spremenjen)

Fixed firefighting systems - Gas extinguishing systems - Part 4: Physical properties and system design of gas extinguishing systems for HFC 125 extinguishant (ISO 14520-8:2019, modified)

iTeh STANDARD PREVIEW

Ortsfeste Brandbekämpfungsanlagen - Löschanlagen mit gasförmigen Löschmitteln - Teil 4: Physikalische Eigenschaften und Anlagenauslegung für Feuerlöschmittel HFC 125 (ISO 14520-8:2019, modifiziert) [SIST EN 15004-4:2020](https://standards.iteh.ai/catalog/standards/sist/fa9c8d91-d64e-4686-b0b9-4f7eae7a6e0b/sist-en-15004-4-2020)

<https://standards.iteh.ai/catalog/standards/sist/fa9c8d91-d64e-4686-b0b9-4f7eae7a6e0b/sist-en-15004-4-2020>

Installations fixes de lutte contre l'incendie - Installations d'extinction à gaz - Partie 4 : Propriétés physiques et conception des systèmes pour agent extincteur HFC 125 (ISO 14520-8:2019, modifiée)

Ta slovenski standard je istoveten z: EN 15004-4:2020

ICS:

13.220.10 Gašenje požara Fire-fighting

SIST EN 15004-4:2020 en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 15004-4:2020

<https://standards.iteh.ai/catalog/standards/sist/fa9c8d91-d64e-4686-b0b9-4f7eae7a6e0b/sist-en-15004-4-2020>

EUROPEAN STANDARD

EN 15004-4

NORME EUROPÉENNE

EUROPÄISCHE NORM

October 2020

ICS 13.220.20

Supersedes EN 15004-4:2008

English Version

Fixed firefighting systems - Gas extinguishing systems -
Part 4: Physical properties and system design of gas
extinguishing systems for HFC 125 extinguishant (ISO
14520-8:2019, modified)

Installations fixes de lutte contre l'incendie -
Installations d'extinction à gaz - Partie 4 : Propriétés
physiques et conception des systèmes pour agent
extincteur HFC 125 (ISO 14520-8:2019, modifiée)

Ortsfeste Brandbekämpfungsanlagen - Löschanlagen
mit gasförmigen Löschmitteln - Teil 4: Physikalische
Eigenschaften und Anlagenauslegung für
Feuerlöschmittel HFC 125 (ISO 14520-8:2019,
modifiziert)

This European Standard was approved by CEN on 17 August 2020.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents		Page
European foreword.....		3
1	Scope	5
2	Normative references	5
3	Terms and definitions	5
4	Characteristics and uses	5
4.1	General.....	5
4.2	Use of HFC 125 systems.....	6
5	Safety of personnel.....	9
6	System design	10
6.1	Fill density	10
6.2	Superpressurization	11
6.3	Extinguishant quantity.....	11
6.4	Other fill density and superpressurization levels.....	12
7	Environmental properties	13

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 15004-4:2020

<https://standards.iteh.ai/catalog/standards/sist/fa9c8d91-d64e-4686-b0b9-4f7eae7a6e0b/sist-en-15004-4-2020>

European foreword

This document (EN 15004-4:2020) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2021, and conflicting national standards shall be withdrawn at the latest by April 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 15004-4:2008.

The main changes in EN 15004-4:2020 compared to EN 15004-4:2008 are the following:

- European foreword: Part 3 was removed from the list;
- Foreword of ISO 14520-8 was removed;
- 6.4, Other fill density and superpressurization levels: new sub-clause added;
- Clause 7, Environmental properties: new clause added.

The text of the International Standard ISO 14520-8:2019 from Technical Committee ISO/TC 21 “Equipment for fire protection and firefighting” of the International Organization for Standardization (ISO) has been taken over as a European Standard by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

EN 15004 will consist of the following parts, under the general title *Fixed firefighting systems — Gas extinguishing systems*:

- Part 1: *Design, installation and maintenance*;
- Part 2: *Physical properties and system design of gas extinguishing systems for FK-5-1-12 extinguishant*;
- Part 4: *Physical properties and system design of gas extinguishing systems for HFC 125 extinguishant*;
- Part 5: *Physical properties and system design of gas extinguishing systems for HFC 227ea extinguishant*;
- Part 6: *Physical properties and system design of gas extinguishing systems for HFC 23 extinguishant*;
- Part 7: *Physical properties and system design of gas extinguishing systems for IG-01 extinguishant*;
- Part 8: *Physical properties and system design of gas extinguishing systems for IG-100 extinguishant*;
- Part 9: *Physical properties and system design of gas extinguishing systems for IG-55 extinguishant*;
- Part 10: *Physical properties and system design of gas extinguishing systems for IG-541 extinguishant*.

EN 15004-4:2020 (E)

The International Standards ISO 14520-2 and ISO 14520-11, which dealt with CF₃I and HFC 236fa extinguishants, respectively, have not been implemented by CEN, as CF₃I is only valid for local application and HFC 236fa extinguishant is only applicable for portable fire extinguishers and local application, respectively, which is not covered by the scope.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 15004-4:2020

<https://standards.iteh.ai/catalog/standards/sist/fa9c8d91-d64e-4686-b0b9-4f7eae7a6e0b/sist-en-15004-4-2020>

1 Scope

This document specifies requirements for gaseous fire-extinguishing systems, with respect to the HFC 125 extinguishant. It includes details of physical properties, specification, usage and safety aspects.

This document is applicable for systems operating at nominal pressures of 25 bar and 42 bar, superpressurized with nitrogen. This does not preclude the use of other systems.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 15004-1:2019, *Fixed firefighting systems — Gas extinguishing systems — Part 1: Design, installation and maintenance (ISO 14520-1:2015, modified)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 15004-1 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <http://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

4 Characteristics and uses

4.1 General

[SIST EN 15004-4:2020
https://standards.iteh.ai/catalog/standards/sist/fa9c8d91-d64e-4686-b0b9-4f7eae7a6e0b/sist-en-15004-4-2020](https://standards.iteh.ai/catalog/standards/sist/fa9c8d91-d64e-4686-b0b9-4f7eae7a6e0b/sist-en-15004-4-2020)

Extinguishant HFC 125 shall comply with the specification shown in Table 1.

HFC 125 is a colourless, almost odourless, electrically non-conductive gas, with a density approximately four times that of air.

The physical properties are shown in Table 2.

HFC 125 extinguishes fires mainly by physical means, but also by some chemical means.

Table 1 — Specification for HFC 125

Property	Requirement
Purity	99,6 % by mass, min.
Acidity	3×10^{-4} % by mass (3 parts per million), max.
Water content	10×10^{-4} % by mass (10 parts per million), max.
Non-volatile residue	0,01 % by mass, max.
Suspended matter or sediment	None visible

Table 2 — Physical properties of HFC 125

Property	Units	Value
Molecular mass	—	120,02
Boiling point at 1,013 bar (absolute)	°C	-48,09
Freezing point	°C	-101
Critical temperature	°C	66,02
Critical pressure	bar abs	36,18
Critical volume	cm ³ /mol	210
Critical density	kg/m ³	573,6
Vapour pressure 20 °C	bar abs	12,05
Liquid density 20 °C	kg/m ³	1 218,0
Saturated vapour density 20 °C	kg/m ³	77,97
Specific volume of superheated vapour at 1,013 bar and 20 °C	m ³ /kg	0,197 2
Chemical formula	CF ₃ CHF ₂	
Chemical name	Pentafluoroethane	

SIST EN 15004-4:2020

4.2 Use of HFC 125 systems

HFC 125 total flooding systems may be used for extinguishing fires of all classes within the limits specified in EN 15004-1:2019, Clause 4.

The extinguishant requirements per volume of protected space are shown in Table 3 for various levels of concentration. These are based on methods shown in EN 15004-1:2019, 7.6.

The extinguishing concentrations and design concentrations for *n*-heptane and surface class A hazards are shown in Table 4.

Table 3 — HFC 125 total flooding quantity

Temperature <i>T</i> °C	Specific vapour volume <i>S</i> m ³ /kg	HFC 125 mass requirements per unit volume of protected space, <i>m/V</i> (kg/m ³)									
		Design concentration (by volume)									
		7 %	8 %	9 %	10 %	11 %	12 %	13 %	14 %	15 %	16 %
-45	0,149 7	0,502 8	0,580 9	0,6607	0,742 2	0,825 6	0,910 9	0,998 2	1,0874	1,178 8	1,272 4
-40	0,153 4	0,490 7	0,566 9	0,6447	0,724 3	0,805 7	0,888 9	0,974 1	1,0612	1,150 4	1,241 7
-35	0,157 2	0,478 8	0,553 2	0,6291	0,706 8	0,786 2	0,867 5	0,950 5	1,0356	1,122 6	1,211 7
-30	0,160 8	0,468 1	0,540 8	0,6151	0,691 0	0,768 6	0,848 0	0,929 3	1,0124	1,097 5	1,184 6
-25	0,164 5	0,457 6	0,528 6	0,601 2	0,675 4	0,751 3	0,829 0	0,908 4	0,989 6	1,072 8	1,157 9
-20	0,168 2	0,447 5	0,517 0	0,588 0	0,660 6	0,734 8	0,810 7	0,888 4	0,967 8	1,049 2	1,132 4
-15	0,171 9	0,437 9	0,505 9	0,575 3	0,646 4	0,719 0	0,793 3	0,869 3	0,947 0	1,026 6	1,108 1
-10	0,175 5	0,428 9	0,495 5	0,563 5	0,633 1	0,704 2	0,777 0	0,851 4	0,927 6	1,005 5	1,085 3
-5	0,179 1	0,420 3	0,485 5	0,552 2	0,620 4	0,690 1	0,761 4	0,834 3	0,908 9	0,985 3	1,063 5
0	0,182 8	0,411 8	0,475 7	0,541 0	0,607 8	0,676 1	0,746 0	0,817 4	0,890 5	0,965 4	1,042 0
5	0,186 4	0,403 8	0,466 5	0,530 6	0,596 1	0,663 1	0,731 6	0,801 6	0,873 3	0,946 7	1,021 9
10	0,190 0	0,396 2	0,457 7	0,520 5	0,584 8	0,650 5	0,717 7	0,786 4	0,856 8	0,928 8	1,002 5
15	0,193 5	0,389 0	0,449 4	0,511 1	0,574 2	0,638 7	0,704 7	0,772 2	0,841 3	0,912 0	0,984 4
20	0,197 1	0,381 9	0,441 2	0,501 8	0,563 7	0,627 1	0,691 9	0,758 1	0,825 9	0,895 3	0,966 4
25	0,200 7	0,375 0	0,433 3	0,492 8	0,553 6	0,615 8	0,679 4	0,744 5	0,811 1	0,879 3	0,949 1
30	0,204 2	0,368 6	0,425 8	0,484 3	0,544 1	0,605 3	0,667 8	0,731 8	0,797 2	0,864 2	0,932 8
35	0,207 8	0,362 2	0,418 5	0,475 9	0,534 7	0,594 8	0,656 2	0,719 1	0,783 4	0,849 2	0,916 6
40	0,211 3	0,356 2	0,411 5	0,468 1	0,525 8	0,584 9	0,645 4	0,707 2	0,770 4	0,835 2	0,901 4
45	0,214 9	0,350 3	0,404 6	0,460 2	0,517 0	0,575 1	0,634 5	0,695 3	0,757 5	0,821 2	0,886 3
50	0,218 4	0,344 6	0,398 2	0,452 8	0,508 8	0,565 9	0,624 4	0,684 2	0,745 4	0,808 0	0,872 1
55	0,221 9	0,339 2	0,391 9	0,445 7	0,500 7	0,557 0	0,614 5	0,673 4	0,733 6	0,795 3	0,858 4
60	0,225 4	0,333 9	0,385 8	0,438 8	0,493 0	0,548 3	0,605 0	0,662 9	0,722 2	0,782 9	0,845 1
65	0,228 9	0,328 8	0,379 9	0,432 1	0,485 4	0,540 0	0,595 7	0,652 8	0,711 2	0,771 0	0,832 1
70	0,232 4	0,323 9	0,374 2	0,425 6	0,478 1	0,531 8	0,586 8	0,643 0	0,700 5	0,759 3	0,819 6
75	0,235 8	0,319 2	0,368 8	0,419 4	0,471 2	0,524 2	0,578 3	0,633 7	0,690 4	0,748 4	0,807 8
80	0,239 3	0,314 5	0,363 4	0,413 3	0,464 3	0,516 5	0,569 8	0,624 4	0,680 3	0,737 4	0,796 0
85	0,242 8	0,310 0	0,358 1	0,407 3	0,457 6	0,509 0	0,561 6	0,615 4	0,670 5	0,726 8	0,784 5
90	0,246 3	0,305 6	0,353 1	0,401 5	0,451 1	0,501 8	0,553 6	0,606 7	0,660 9	0,716 5	0,773 4
95	0,249 8	0,301 3	0,348 1	0,395 9	0,444 8	0,494 8	0,545 9	0,598 2	0,651 7	0,706 4	0,762 5

NOTE This information refers only to the product HFC 125 and does not represent any other products containing pentafluoroethane as a component.